

ADAPTER A-16

Thickness Summary

Component Identifier	Material	Diameter (in)	Length (in)	Nominal t (in)	Design t (in)	Total Corrosion (in)	Joint E	Load
<u>Cylinder #1</u>	SA-240 304	60 ID	2	0.25	0.0774	0	0.70	External
<u>Bolted Cover #1</u>	SA-240 304	68.25 OD	1.5	1.5*	0.9798	0	1.00	External

Nominal t: Vessel wall nominal thickness

Design t: Required vessel thickness due to governing loading + corrosion

Joint E: Longitudinal seam joint efficiency

* Head minimum thickness after forming

Load

internal: Circumferential stress due to internal pressure governs

external: External pressure governs

Wind: Combined longitudinal stress of pressure + weight + wind governs

Seismic: Combined longitudinal stress of pressure + weight + seismic governs

Bolted Cover #1

ASME Section VIII Division 1, 2007 Edition, A09 Addenda

Component: Bolted Cover
Material specification: SA-240 304 (II-D p. 90, In. 4)
Impact test exempt per UHA-51(g)(coincident ratio = 0.02978)

Internal design pressure: $P = 1$ psi @ 302 °F
External design pressure: $P_e = 15$ psi @ 302 °F

Static liquid head:

$P_{lh} = 2.17$ psi (SG=1.0000, $H_s=60$ ", Horizontal test head)

Corrosion allowance: Inner C = 0" Outer C = 0"

Design MDMT = -20 °F No impact test performed
Rated MDMT = -320 °F Material is not normalized
Material is not produced to Fine Grain Practice
PWHT is not performed

Radiography: Category A joints - Seamless No RT

Estimated weight: New = 840.6 lb corr = 840.6 lb

Head diameter, $d = 63.5$ "

Cover thickness, $t = 1.5$ "

Gasket groove depth = 0"

(ASSUMED "O-RING" GASKET DIAM.)

Design thickness, (at 302 °F) UG-34 (c)(2), flange operating

$$t = d \sqrt{C^*P / (S^*E) + 1.9^*W^*h_G / (S^*E^*d^3)} + \text{Corrosion}$$
$$= 63.5^*\sqrt{0.3^*1 / (18,900^*1) + 1.9^*3,165.32^*1.375 / (18,900^*1^*63.5^3)} + 0$$
$$= 0.2663 \text{ in}$$

Design thickness, (at 70 °F) UG-34 (c)(2), gasket seating

$$t = d \sqrt{1.9^*W^*h_G / (S^*E^*d^3)} + \text{Corrosion}$$
$$= 63.5^*\sqrt{1.9^*120,141.6^*1.375 / (20,000^*1^*63.5^3)} + 0$$
$$= 0.4971 \text{ in}$$

Maximum allowable working pressure, (at 302 °F)

$$P = (S^*E / C)^*(t / d)^2 - (1.9^*W^*h_G / (S^*E^*d^3)) - P_s$$
$$= (18,900^*1 / 0.3)^*(1.5 / 63.5)^2 - (1.9^*100,458.9^*1.375 / (18,900^*1^*63.5^3)) - 0$$
$$= 31.74 \text{ psi}$$

Design thickness for external pressure, (at 302 °F) U-2(g)

$$t = d \sqrt{C^*P_a / (S^*E)} + \text{Corrosion}$$
$$= 63.5^*\sqrt{0.3^*15 / (18,900^*1)} + 0$$
$$= 0.9798 \text{ in}$$


Maximum allowable external pressure, (At 302 °F) U-2(g)

$$P_a = (S^*E / C)^*(t / d)^2$$
$$= (18,900^*1 / 0.3)^*(1.5 / 63.5)^2$$

Nozzle #1 (A1)

ASME Section VIII Division 1, 2007 Edition, A09 Addenda

$$t_{w(\text{lower})} = 0.1875 \text{ in}$$
$$\text{Leg}_{41} = 0.25 \text{ in}$$



Note: round inside edges per UG-76(c)

Located on:	Bolted Cover #1
Liquid static head included:	0 psi
Nozzle material specification:	SA-240 304 (II-D p. 90, ln. 4)
Nozzle longitudinal joint efficiency:	1
Nozzle orientation:	0°
Local vessel minimum thickness:	1.5 in
Nozzle inside diameter, new:	44 in
Nozzle nominal wall thickness:	0.25 in
Nozzle corrosion allowance:	0 in
Projection available outside vessel, L _{pr} :	13.81 in
Projection available outside vessel to flange face, L _f :	16.31 in
Distance to head center, R:	0 in

Reinforcement Calculations for External Pressure

UG-39 Area Calculation Summary (in²) For $P_e = 15 \text{ psi @ } 302 \text{ }^\circ\text{F}$ The opening is adequately reinforced							UG-45 Nozzle Wall Thickness Summary (in) The nozzle passes UG-45	
A required	A available	A ₁	A ₂	A ₃	A ₅	A welds	t _{req}	t _{min}
21.5563	23.1412	22.8875	0.1912	--	--	0.0625	0.097	0.25

UG-41 Weld Failure Path Analysis Summary (lb _f)				
All failure paths are stronger than the applicable weld loads				
Weld load W	Weld load W ₁₋₁	Path 1-1 strength	Weld load W ₂₋₂	Path 2-2 strength
-20,244.82	4,794.93	391,733.81	18,969.93	345,142.13

UW-16 Weld Sizing Summary			
Weld description	Required weld size (in)	Actual weld size (in)	Status
Nozzle to shell fillet (Leg ₄₁)	0.175	0.175	weld size is adequate
Nozzle to shell groove (Lower)	0.175	0.1875	weld size is adequate

Calculations for external pressure 15 psi @ 302 °F

Parallel Limits of reinforcement per UG-40

$$\begin{aligned}
 L_R &= \text{MAX}(d, R_n + (t_n - C_n) + (t - C)) \\
 &= \text{MAX}(44, 22 + (0.25 - 0) + (1.5 - 0)) \\
 &= 44 \text{ in}
 \end{aligned}$$

Outer Normal Limits of reinforcement per UG-40

$$\begin{aligned}
 L_H &= \text{MIN}(2.5*(t - C), 2.5*(t_n - C_n) + t_\theta) \\
 &= \text{MIN}(2.5*(1.5 - 0), 2.5*(0.25 - 0) + 0) \\
 &= 0.625 \text{ in}
 \end{aligned}$$

Nozzle required thickness per UG-28 $t_n = 0.097 \text{ in}$

From UG-34 required thickness $t_r = 0.9798 \text{ in}$

Area required per UG-39

Allowable stresses: $S_n = 18,900$, $S_v = 18,900$ psi

$$f_{r1} = \text{lesser of } 1 \text{ or } S_n/S_v = 1$$

$$f_{r2} = \text{lesser of } 1 \text{ or } S_n/S_v = 1$$

$$\begin{aligned} A &= 0.5*(d*t_r*F + 2*t_n*t_r*F*(1 - f_{r1})) \\ &= 0.5*(44*0.9798*1 + 2*0.25*0.9798*1*(1 - 1)) \\ &= \underline{21.5563} \text{ in}^2 \end{aligned}$$

Area available from FIG. UG-37.1

$$A_1 = \text{larger of the following} = \underline{22.8875} \text{ in}^2$$

$$\begin{aligned} &= d*(E_1*t - F*t_r) - 2*t_n*(E_1*t - F*t_r)*(1 - f_{r1}) \\ &= 44*(1*1.5 - 1*0.9798) - 2*0.25*(1*1.5 - 1*0.9798)*(1 - 1) \\ &= 22.8875 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t + t_n)*(E_1*t - F*t_r) - 2*t_n*(E_1*t - F*t_r)*(1 - f_{r1}) \\ &= 2*(1.5 + 0.25)*(1*1.5 - 1*0.9798) - 2*0.25*(1*1.5 - 1*0.9798)*(1 - 1) \\ &= 1.8206 \text{ in}^2 \end{aligned}$$

$$A_2 = \text{smaller of the following} = \underline{0.1912} \text{ in}^2$$

$$\begin{aligned} &= 5*(t_n - t_m)*f_{r2}*t \\ &= 5*(0.25 - 0.097)*1*1.5 \\ &= 1.1472 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*(t_n - t_m)*f_{r2}*t_n \\ &= 5*(0.25 - 0.097)*1*0.25 \\ &= 0.1912 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{41} &= \text{Leg}^2*f_{r2} \\ &= 0.25^2*1 \\ &= \underline{0.0625} \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A_1 + A_2 + A_{41} \\ &= 22.8875 + 0.1912 + 0.0625 \\ &= \underline{23.1412} \text{ in}^2 \end{aligned}$$

As Area \geq A the reinforcement is adequate.

UW-16(d) Weld Check

$$t_{\min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t = 0.25 \text{ in}$$

$$t_{1(\min)} \text{ or } t_{2(\min)} = \text{lesser of } 0.25 \text{ or } 0.7*t_{\min} = \underline{0.175} \text{ in}$$

$$t_{1(\text{actual})} = 0.7*\text{Leg} = 0.7*0.25 = 0.175 \text{ in}$$

The weld size t_1 is satisfactory.

$$t_{2(\text{actual})} = 0.1875 \text{ in}$$

The weld size t_2 is satisfactory.

$$t_1 + t_2 = 0.3625 \geq 1.25 * t_{\min}$$

The combined weld sizes for t_1 and t_2 are satisfactory.

UG-45 Nozzle Neck Thickness Check (Access Opening)

Wall thickness req'd per UG-45(a): $t_{r1} = 0.097$ in

Wall thickness per UG-16(b): $t_{r3} = 0.0625$ in

Available nozzle wall thickness new, $t_n = 0.25$ in

The nozzle neck thickness is adequate.

Allowable stresses in joints UG-45(c) and UW-15(c)

Groove weld in tension: $0.74 * 18,900 = 13,986$ psi

Nozzle wall in shear: $0.7 * 18,900 = 13,230$ psi

Inner fillet weld in shear: $0.49 * 18,900 = 9,261$ psi

Strength of welded joints:

(1) Inner fillet weld in shear

$$(\pi/2) * \text{Nozzle OD} * \text{Leg} * S_i = (\pi/2) * 44.5 * 0.25 * 9,261 = 161,836.98 \text{ lb}_f$$

(3) Nozzle wall in shear

$$(\pi/2) * \text{Mean nozzle dia} * t_n * S_n = (\pi/2) * 44.25 * 0.25 * 13,230 = 229,896.84 \text{ lb}_f$$

(4) Groove weld in tension

$$(\pi/2) * \text{Nozzle OD} * t_w * S_g = (\pi/2) * 44.5 * 0.1875 * 13,986 = 183,305.16 \text{ lb}_f$$

Loading on welds per UG-41(b)(1)

$$\begin{aligned} W &= (A - A_1 + 2 * t_n * f_{r1} * (E_1 * t - F * t_r)) * S_v \\ &= (21.5563 - 22.8875 + 2 * 0.25 * 1 * (1 * 1.5 - 1 * 0.9798)) * 18,900 \\ &= \underline{-20,244.82 \text{ lb}_f} \end{aligned}$$

$$\begin{aligned} W_{1-1} &= (A_2 + A_5 + A_{41} + A_{42}) * S_v \\ &= (0.1912 + 0 + 0.0625 + 0) * 18,900 \\ &= \underline{4,794.93 \text{ lb}_f} \end{aligned}$$

$$\begin{aligned} W_{2-2} &= (A_2 + A_3 + A_{41} + A_{43} + 2 * t_n * t * f_{r1}) * S_v \\ &= (0.1912 + 0 + 0.0625 + 0 + 2 * 0.25 * 1.5 * 1) * 18,900 \\ &= \underline{18,969.93 \text{ lb}_f} \end{aligned}$$

Load for path 1-1 lesser of W or $W_{1-1} = -20244.82 \text{ lb}_f$

Path 1-1 through (1) & (3) = $161,837 + 229,896.8 = \underline{391,733.81 \text{ lb}_f}$

Path 1-1 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 2-2 lesser of W or $W_{2-2} = -20244.82 \text{ lb}_f$

Path 2-2 through (1), (4) = $161,837 + 183,305.2 = \underline{345,142.13 \text{ lb}_f}$

Path 2-2 is stronger than W so it is acceptable per UG-41(b)(2).

External Pressure, (Corroded & at 302 °F) UG-28(c)

$$L / D_o = 16.31 / 44.5 = 0.3665$$

$$D_o / t = 44.5 / 0.097 = 458.5623$$

From table G: A = 0.000392

From table HA-1: B = 5,159 psi

$$\begin{aligned} P_a &= 4*B / (3*(D_o / t)) \\ &= 4*5158.8174 / (3*(44.5 / 0.097)) \\ &= 15 \text{ psi} \end{aligned}$$

Design thickness for external pressure P_a = 15 psi

$$t_a = t + \text{Corrosion} = 0.097 + 0 = 0.097''$$

Weight Summary

Component	Weight (lb) Contributed by Vessel Elements							Surface Area ft ²
	Metal New*	Metal Corroded*	Insulation & Supports	Lining	Piping + Liquid	Operating Liquid	Test Liquid	
Cylinder #1	27.4	27.4	0	0	0	0	247.5	3
Bolted Cover #1	840.6	840.6	0	0	0	0	926.4	16
TOTAL:	868	868	0	0	0	0	1,173.9	18

* Shells with attached nozzles have weight reduced by material cut out for opening.

Component	Weight (lb) Contributed by Attachments							Surface Area ft ²	
	Body Flanges		Nozzles & Flanges		Packed Beds	Trays & Supports	Rings & Clips		Vertical Loads
	New	Corroded	New	Corroded					
Cylinder #1	542.2	542.2	0	0	0	0	0	0	19
Bolted Cover #1	0	0	667.2	667.2	0	0	0	0	23
TOTAL:	542.2	542.2	667.2	667.2	0	0	0	0	23

Vessel operating weight, Corroded: 2,077 lb
 Vessel operating weight, New: 2,077 lb
 Vessel empty weight, Corroded: 2,077 lb
 Vessel empty weight, New: 2,077 lb
 Vessel test weight, New: 3,251 lb
 Vessel surface area: 42 ft²

Vessel center of gravity location - from datum - lift condition

Vessel Lift Weight, New: 2,077 lb
 Center of Gravity: -4.1752"

Vessel Capacity

Vessel Capacity** (New): 24 US gal
 Vessel Capacity** (Corroded): 24 US gal

**The vessel capacity does not include volume of nozzle, piping or other attachments.