

**DUCTLESS AIR CONDITIONER (AC) SCHEDULE**


SYMBOL	ROOM LOCATION	TYPE	COOLING		INDOOR UNIT		OUTDOOR UNIT		MFR	FEATURES		
			TOTAL CAPACITY (BTU)	SEER	MCA (AMPS)	V/PH	MODEL	MOP (AMPS)			V/PH	MODEL
AC-3	LAE-H2	DUCTLESS WALL MOUNT	12,000	15.2	1.0	208/1	PKA-A12HA	15	208/1	PUV-A12NHA3	MITSUBISHI	PROVIDE LOW AMBIENT KIT, CONDENSATE PUMP, WIRED THERMOSTAT
AC-4	LAE-H2	DUCTLESS WALL MOUNT	12,000	15.2	1.0	208/1	PKA-A12HA	15	208/1	PUV-A12NHA3	MITSUBISHI	PROVIDE LOW AMBIENT KIT, WIRED THERMOSTAT

NOTE: OWNER SHALL DETERMINE ELECTRICAL PANEL AND CIRCUIT FOR EQUIPMENT POWER.  
 NOTE: PROVIDE HIGH LEVEL INDICATOR FOR CONDENSATE PUMP. LOCATE INDICATOR LIGHT AS SHOWN ON PLAN.

**SUPPLY FAN (SF) SCHEDULE**

SYMBOL	LOCATION	TYPE	AIRFLOW (CFM)	STATIC PRESSURE (IN WG)	DRIVE	MOTOR		CONTROL	MFR/MODEL	FEATURES	
						HP	RPM				V/PH
SF-2	ABOVE LEVEL ENTRY AIR LOCK	IN-LINE AXIAL	300	0.75	DIRECT	1/2	1870	120/1	VFD/MANUAL ADJUST FOR ROOM PRESSURE	S&P INLINE MIXED FLOW DUCT FAN, SC-TD-250 (107)	PROVIDE WITH ROTARY SPEED CONTROL

NOTE: OWNER SHALL DETERMINE ELECTRICAL PANEL AND CIRCUIT FOR EQUIPMENT POWER.



EQUIPMENT PAD, 4" THICK WITH 6" SQ WWM. SIZE TO MATCH SUPPLIED EQUIPMENT DIMENSIONS PLUS 6" EACH SIDE.

ATTACH UNISTRUT TO HORIZONTAL Z-MEMBERS FOR FAN AND DUCT SUPPORT

DRAWING: LIGO-D1002397-V1