



NOT FOR CONSTRUCTION

- NOTES:**
- 1) ALL CABLETRAY LENGTHS ARE 12'-0" UNLESS OTHERWISE SPECIFIED.
 - 2) ALL CABLE TRAY SHALL BE GROUNDED PER N.E.C.
 - 3) ALL CABLE TRAY SHALL BE FIELD SUPPORTED.
 - 4) CABLE TRAY FOR ION PUMP POWER CABLES SHALL BE LABELED "DANGER HIGH VOLTAGE".

LIGO-D960584-00-V

PROPRIETARY AND CONFIDENTIAL

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION BELONGING TO PROCESS SYSTEMS INTERNATIONAL, INC. OR ITS AFFILIATED COMPANIES AND SHALL BE USED ONLY FOR THE PURPOSE FOR WHICH IT WAS SUPPLIED. IT SHALL NOT BE COPIED, REPRODUCED OR OTHERWISE USED, NOR SHALL SUCH INFORMATION BE FURNISHED IN WHOLE OR IN PART TO OTHERS EXCEPT IN ACCORDANCE WITH THE TERMS OF ANY AGREEMENT UNDER WHICH IT WAS SUPPLIED OR WITH THE PRIOR WRITTEN CONSENT OF PROCESS SYSTEMS INTERNATIONAL, INC. AND SHALL BE RETURNED UPON REQUEST.

DWG. NO.	DESCRIPTION	REFERENCE DRAWINGS
V049-3-002	WASHINGTON OVERALL SITE PLAN	
V049-3-001	GENERAL NOTES & LEGEND	

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES

FRACTIONAL & DECIMALS: 1/16" INCREMENTS

3/16" ROUND 45° BEVEL 45°

1/2" PLACE DECIMAL, 3/8" THICK SURFACE FINISH

WELD CORNERS TO REMOVE ALL BURRS

DO NOT SCALE THIS DRAWING	ISSUE FOR/FR	DATE	BY	CHKD	BRWN	DATE	DCDR
USED ON:	REV	DESCRIPTION	ISSUE DESCRIPTION				

PROCESS SYSTEMS INTERNATIONAL, INC.
30 WALKUP DR. WESTBOROUGH, MASSACHUSETTS 01581 USA

CABLE TRAY PLAN
LIGO VACUUM EQUIPMENT
WASHINGTON SITE
RIGHT MID STATION

CAD FILE: V0493302
DWG NO: V049-3-302
REV: 0
SCALE: 3/16" = 1'-0"
SHEET: 1 OF 1