



PROCESS SYSTEMS INTERNATIONAL
DOCUMENT APPROVAL CHECKLIST
PROJECT NAME: LIGD
PSI DOC. NO. V049-P-332
NOTE: THE REVIEW DOES NOT RELIEVE THE SELLER OR CONTRACTOR OF ANY OBLIGATIONS UNDER THE FOLLOWING CONTRACT:

FA = FINAL APPROVAL
 AS = APPROVED AS NOTED - REVISE & RESUBMIT
 AF = APPROVED FOR FABRICATION
 NA = NOT APPROVED
 RP = RELEASED FOR PROCUREMENT OF MATERIALS ONLY
 RR = REVISE & RESUBMIT

BY: _____ DATE: _____

- 17 COMMUNICATION CONNECTOR AMP CPC 206038-1 (16 PIN)
- 18 EMO OUTPUT
- 16 EDP200 PUMP START/STOP REMOTE INPUT
- 19 EDP200 RUNNING SIGNAL OUTPUT
- 20 EDP200 TEMP HAZARD OUTPUT
- 21 EDP200 LOW N2 FLOW WARN./SHUTDOWN OUTPUT
- 22 EDP200 REMOTE/LOCAL OUTPUT
- 23
- 24
- 26
- 27

PROCESS SYSTEMS INTERNATIONAL
DOCUMENT REVIEW CHECKLIST
PROJECT NAME: _____
PSI DOC. NO. _____

CHK BY / DATE

- PROJECT ENG
- MECHANICAL
- STRESS
- ELECTRICAL
- PROCESS
- MFG. ENG.
- MANUF.
- O.A.
- DRAFTING

No.	Revision	Date	By	Appr.

EDWARDS HIGH WACUUM INTERNATIONAL
GRAND ISLAND, NEW YORK 14077
A Division of the BOC Group, Inc.

Electrical Schematic - LOCAL BOX FOR EDP200 CHEMICAL PUMP IN COMBO WITH EH2600 BOOSTER, GATE VALVE, CONTROLLER AND ACCESSORIES.

Customer: P.S.I.

Doc. No. NGB050150

PRELIMINARY
SUBJECT TO CHANGE

MAY 31 1985

LIGD-296079L-01-V