

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS To the borrower.

ELECTRIC DUCT HEATER SCHEDULE

UNIT NO.	LOCATION	SERVICE		HEATING CAPACITY (KW)	NUMBER OF STAGES	VOLTS/PH/Hz	DUCT SIZE (IN)	MANUFACTURER/ MODEL NO.	REMARKS
		BUILDING	ROOM						
L-CS-107-HC-01	MECH ROOM	LVEA	LASER AREA - 1	75	SCR	460/3/60	48X36	INDEECO TFZU	
L-CS-107-HC-02	MECH ROOM	LVEA	LASER AREA - 2	150	SCR	460/3/60	48X60	INDEECO TFZU	
L-CS-107-HC-03	MECH ROOM	LVEA	LASER AREA - 3	150	SCR	460/3/60	48X60	INDEECO TFZU	
L-CS-107-HC-04	MECH ROOM	LVEA	LASER AREA - 4	100	SCR	460/3/60	48X36	INDEECO TFZU	
L-CS-107-HC-05	MECH ROOM	LVEA	LASER AREA - 5	100	SCR	460/3/60	48X36	INDEECO TFZU	
L-CS-107-HC-06	MECH ROOM	LVEA	MECHANICAL ROOM	50	4	460/3/60	48X24	INDEECO TFZU	
L-CS-107-HC-07	MECH ROOM	LVEA	OUTSIDE AIR SUPPLY	25	4	460/3/60	24X24	INDEECO TFZU	
L-CS-107-HC-08	MECH ROOM	LVEA	OUTSIDE AIR SUPPLY	25	4	460/3/60	24X24	INDEECO TFZU	
L-CS-107-HC-09	AHU-3	OSB	AHU - 3 *	50	4	460/3/60	30X48	INDEECO TFZU	
L-CS-107-HC-10	AHU-3	OSB	AHU - 3 *	50	4	460/3/60	30X48	INDEECO TFZU	
L-CS-107-HC-11	MECH ROOM	OSB	OUTSIDE AIR SUPPLY	12	2	460/3/60	18X12	INDEECO TFZU	
L-CS-107-HC-12	MECH ROOM	OSB	OUTSIDE AIR SUPPLY	12	2	460/3/60	18X12	INDEECO TFZU	
L-CS-160-HC-13	MECH ROOM	AHU-4	OUTSIDE AIR SUPPLY	30	4	460/3/60	32X32	INDEECO TFZU	
L-EA-203-HC-01	END STATION A	END STATION A	OUTSIDE AIR SUPPLY	6	2	460/3/60	18X12	INDEECO TFZU	STANDBY
L-EA-203-HC-02	END STATION A	END STATION A	OUTSIDE AIR SUPPLY	6	2	460/3/60	18X12	INDEECO TFZU	
L-EA-203-HC-03	END STATION A	END STATION A	VEA	75	SCR	460/3/60	30X36	INDEECO TFZU	
L-EA-203-HC-04	END STATION A	END STATION A	EXPERIMENT EQUIPMENT	6	2	460/3/60	24X12	INDEECO TFZU	
L-EA-203-HC-05	END STATION A	END STATION A	CLEANING & CHANGE ROOM	6	2	460/3/60	24X12	INDEECO TFZU	
L-EA-203-HC-06	END STATION A	END STATION A	INSPECTION/SHIP/REC.	6	2	460/3/60	24X12	INDEECO TFZU	
L-EA-203-HC-07	END STATION A	END STATION A	MECHANICAL ROOM	9	2	460/3/60	24X18	INDEECO TFZU	
L-EA-203-HC-08	END STATION A	END STATION A	VACUUM SUPPORT RM.	9	2	460/3/60	18X18	INDEECO TFZU	
L-EB-203-HC-01	END STATION B	END STATION B	OUTSIDE AIR SUPPLY	6	2	460/3/60	18X12	INDEECO TFZU	STANDBY
L-EB-203-HC-02	END STATION B	END STATION B	OUTSIDE AIR SUPPLY	6	2	460/3/60	18X12	INDEECO TFZU	
L-EB-203-HC-03	END STATION B	END STATION B	VEA	75	SCR	460/3/60	30X36	INDEECO TFZU	
L-EB-203-HC-04	END STATION B	END STATION B	EXPERIMENT EQUIPMENT	6	2	460/3/60	24X12	INDEECO TFZU	
L-EB-203-HC-05	END STATION B	END STATION B	CLEANING & CHANGE ROOM	6	2	460/3/60	24X12	INDEECO TFZU	
L-EB-203-HC-06	END STATION B	END STATION B	INSPECTION/SHIP/REC.	6	2	460/3/60	24X12	INDEECO TFZU	
L-EB-203-HC-07	END STATION B	END STATION B	MECHANICAL ROOM	9	2	460/3/60	24X18	INDEECO TFZU	
L-EB-203-HC-08	END STATION B	END STATION B	VACUUM SUPPORT RM.	9	2	460/3/60	18X18	INDEECO TFZU	
L-CS-194-HC-14	CORNER STN	MAINTENANCE	OFFICE	20	4	460/3/60	12X8	INDEECO TFZU	

NOTES:

1. FOR LEGEND, ABBREVIATIONS AND GENERAL NOTES SEE SHEETS LA-H-001 AND LA-H-002.

VAV TERMINAL SCHEDULE - SINGLE DUCT

SIZE	LOCATION	SERVICE	TYPE	INLET SIZE DIA (IN.)	COLD AIR		WARM AIR		HEATING COIL	MANUFACTURER/ MODEL NO.	REMARKS
					MAX ACFM	MIN ACFM	MAX ACFM	MIN ACFM			
01	OSB	OSB	PRESSURE INDEPENDENT	4	100	(1)	0.15	4	2	208/1/60	TITUS ACSV-3000 PROVIDED WITH 36" ATTENUATOR
02	OSB	OSB	PRESSURE INDEPENDENT	5	200	(1)	0.20	4	2	208/1/60	TITUS ACSV-3000 PROVIDED WITH 36" ATTENUATOR
03	OSB	OSB	PRESSURE INDEPENDENT	6	300	(1)	0.30	4	2	208/1/60	TITUS ACSV-3000 PROVIDED WITH 36" ATTENUATOR
04	OSB	OSB	PRESSURE INDEPENDENT	7	450	(1)	0.30	7.5	2	208/1/60	TITUS ACSV-3000 PROVIDED WITH 36" ATTENUATOR
05	OSB	OSB	PRESSURE INDEPENDENT	8	600	(1)	0.30	7.5	2	208/1/60	TITUS ACSV-3000 PROVIDED WITH 36" ATTENUATOR
06	OSB	OSB	PRESSURE INDEPENDENT	9	750	(1)	0.30	13.0	2	460/3/60	TITUS ACSV-3000 PROVIDED WITH 36" ATTENUATOR
07	OSB	OSB	PRESSURE INDEPENDENT	10	950	(1)	0.30	13.0	2	460/3/60	TITUS ACSV-3000 PROVIDED WITH 36" ATTENUATOR
08	OSB	OSB	PRESSURE INDEPENDENT	12	1300	(1)	0.30	19.0	2	460/3/60	TITUS ACSV-3000 PROVIDED WITH 36" ATTENUATOR

(1) SEE FLOOR PLANS

VAV TERMINAL SCHEDULE - DOUBLE DUCT

SIZE	LOCATION	SERVICE	TYPE	INLET SIZE DIA (IN.)	COLD AIR		WARM AIR		MAX BOX AIR PD (IN. WG)	MANUFACTURER/ MODEL NO.	REMARKS
					MAX ACFM	MIN ACFM	MAX ACFM	MIN ACFM			
01	OSB	OSB	PRESSURE INDEPENDENT	4	100	0	100	0	0.15	TITUS EDV-3000	PROVIDED WITH 36" ATTENUATOR
02	OSB	OSB	PRESSURE INDEPENDENT	5	200	0	200	0	0.20	TITUS EDV-3000	PROVIDED WITH 36" ATTENUATOR
03	OSB	OSB	PRESSURE INDEPENDENT	6	300	0	300	0	0.30	TITUS EDV-3000	PROVIDED WITH 36" ATTENUATOR
04	OSB	OSB	PRESSURE INDEPENDENT	7	450	0	450	0	0.30	TITUS EDV-3000	PROVIDED WITH 36" ATTENUATOR
05	OSB	OSB	PRESSURE INDEPENDENT	8	600	0	600	0	0.30	TITUS EDV-3000	PROVIDED WITH 36" ATTENUATOR
06	OSB	OSB	PRESSURE INDEPENDENT	9	750	0	750	0	0.30	TITUS EDV-3000	PROVIDED WITH 36" ATTENUATOR
07	OSB	OSB	PRESSURE INDEPENDENT	10	950	0	950	0	0.30	TITUS EDV-3000	PROVIDED WITH 36" ATTENUATOR
08	OSB	OSB	PRESSURE INDEPENDENT	12	1300	0	1300	0	0.30	TITUS EDV-3000	PROVIDED WITH 36" ATTENUATOR
09	OSB	OSB	PRESSURE INDEPENDENT	14	2200	0	2200	0	0.30	TITUS EDV-3000	PROVIDED WITH 36" ATTENUATOR
10	OSB	OSB	PRESSURE INDEPENDENT	16	3400	0	3400	0	0.30	TITUS EDV-3000	PROVIDED WITH 36" ATTENUATOR

* W/REMOTE PANEL

LIGO-D960964-02-0

LASER INTERFEROMETER GRAVITATIONAL-WAVE OBSERVATORY SITE NO. 2 - LIVINGSTON, LOUISIANA

TITLE	SCALE	CONTRACT NUMBER	PROJECT NUMBER
HVAC EQUIPMENT SCHEDULES SHEET 3	NONE	PPI50969	8094
SHEET NUMBER	L A - H - 005		REVISIONS

ISSUED FOR CONSTRUCTION	CLP	11-15-96
DRAWN	MN	10-25-96
CHECKED	AA	1-23-96
ENGINEER	TDM	11-15-96
PROJ		

AS-BUILT DRAWINGS

PARSONS
100 WEST WALNUT STREET
PASADENA, CALIFORNIA

LIGO
CALIFORNIA INSTITUTE OF TECHNOLOGY
MASSACHUSETTS INSTITUTE OF TECHNOLOGY

NO.	DATE	BY	CHKD	ENGR	PROJ	DESCRIPTION
2	5-21-99	AO	AA	AA		ISSUED AS REVISED AS-BUILT
1	8-7-98	DJB	AA	AA		ISSUED FOR AS-BUILT