

DUCT SILENCER SCHEDULE

Table with columns: UNIT NO, LOCATION, SERVICE (BUILDING, ROOM), CFM, DIMENSIONS W X D X L, PD IN/ WC, MANUFACTURER/ MODEL NO, REMARKS. Includes rows for Laser Area (1-5), Mechanical Room #107, General Return of LVEA, OSB Cold/Warm Air Deck, OSB Return Air, Offices Supply/Return Air, Outside Air, Toilet Exhaust, and Experiment EG.

AIR INLET & OUTLET SCHEDULE

Table with columns: UNIT NO, DESCRIPTION, FACE SIZE, NECK SIZE IN X IN, CONSTRUCTION, MANUFACTURER/ MODEL NO, REMARKS. Includes rows for HEPA filters (HF-1, HF-2), Ceiling Diffusers (CD-1, CD-2), Return Registers (RR-1, RR-2), Return Grilles (RG-1, RG-2), and Supply Register (SR-1).

(1) PROVIDE WITH HANGING TAPS, STAINLESS STEEL TRIM, 1/2" INSULATION WITH ALUMINUM FOIL  
(2) INITIAL PRESSURE DROP = 0.50" WC, REPLACEMENT PRESSURE DROP = 2.0" WC  
(3) SEE PLANS

VIBRATION ISOLATOR SCHEDULE

Table with columns: UNIT NO, NAME, LOCATION, ISOLATOR TYPE, SPRING DEFLECTION (INCH), FRAME TYPE, SEISMIC RESTRAINT, REMARKS. Lists various equipment including Vane Axial Fans, Air-Cooled Water Chillers, Chilled Water Pumps, Air Compressors, and Packaged Air Handlers.

(1) ISOLATOR HOUSING INCLUDES SEISMIC RESTRAINTS  
(2) SEE SPECIFICATIONS FOR CODE LETTER  
(3) STATIC DEFLECTION 3 HZ

NOTES:

1. FOR LEGEND, ABBREVIATIONS AND GENERAL NOTES SEE SHEETS LA-H-001 AND LA-H-002.

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way except by written consent from PARSONS to the borrower.

LIGO-D960965-01-0

Table with columns: REVISIONS (NO., DATE, BY, CHKD, ENGR, PROJ), ISSUED FOR CONSTRUCTION (DRAWN, CHECKED, ENGINEER, PROJ), and DRAWING NO. / DESCRIPTION.




Table with columns: TITLE (LASER INTERFEROMETER GRAVITATIONAL-WAVE OBSERVATORY SITE NO.2 - LIVINGSTON, LOUISIANA), SCALE, CONTRACT NUMBER (PPI50969), PROJECT NUMBER (8094), SHEET NUMBER (LA-H-006), and REVISION.