

DUCT SILENCER SCHEDULE

UNIT NO	LOCATION	SERVICE		CFM	DIMENSIONS W' X D' X L	PD IN. WC	MANUFACTURER/ MODEL NO	REMARKS
		BUILDING	ROOM					
L-CS-107-ST-01	MECH ROOM 107	LVEA	LASER AREA - 1	10,500	48 X 36 X 120	0.15	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-02	MECH ROOM 107	LVEA	LASER AREA - 2	15,000	48 X 60 X 120	0.10	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-03	MECH ROOM 107	LVEA	LASER AREA - 3	15,000	48 X 60 X 120	0.10	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-04	MECH ROOM 107	LVEA	LASER AREA - 4	10,000	48 X 36 X 120	0.15	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-05	MECH ROOM 107	LVEA	LASER AREA - 5	10,000	48 X 36 X 120	0.15	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-06	MECH ROOM 107	LVEA	MECHANICAL ROOM #107	6,000	48 X 24 X 84	0.07	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-07	MECH ROOM 107	LVEA	GENERAL RETURN OF LVEA	20,300	60 X 60 X 84	0.10	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-08	MECH ROOM 107	LVEA	GENERAL RETURN OF LVEA	20,300	60 X 60 X 84	0.10	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-09	MECH ROOM 107	LVEA	GENERAL RETURN OF LVEA	20,300	60 X 60 X 84	0.10	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-10	MECH ROOM 107	OSB	OSB COLD AIR DECK	24,000	60 X 48 X 84	0.25	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-11	MECH ROOM 107	OSB	OSB WARM AIR DECK	24,000	60 X 48 X 84	0.15	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-12	MECH ROOM 107	OSB	OSB RETURN AIR	24,000	60 X 60 X 84	0.15	INDUSTRIAL ACOUSTICS CO MS	
L-CS-160-ST-13	MECH ROOM 160	OFFICES	SUPPLY AIR	9,700	42 X 18 X 60	0.40	INDUSTRIAL ACOUSTICS CO MS	
L-CS-160-ST-14	MECH ROOM 160	OFFICES	RETURN AIR	9,000	42 X 18 X 60	0.36	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-15	MECH ROOM 107	LVEA	OUTSIDE AIR	2,600	24 X 24 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-16	MECH ROOM 107	LVEA	OUTSIDE AIR	2,600	24 X 24 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-17	MECH ROOM 107	OSB	OUTSIDE AIR	650	18 X 12 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-18	MECH ROOM 107	OSB	OUTSIDE AIR	650	18 X 12 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-19	ROOM 149	OFFICES	TOILET EXHAUST	950	14" X 36	0.05	INDUSTRIAL ACOUSTICS CO FCL	
L-CS-107-ST-20	ROOM 149	OFFICES	TOILET EXHAUST	950	14" X 36	0.05	INDUSTRIAL ACOUSTICS CO FCL	
L-CS-107-ST-21	ROOM 137	OFFICES	TOILET EXHAUST	200	12" X 36	0.02	INDUSTRIAL ACOUSTICS CO FCL	
L-CS-107-ST-22	ROOM 137	OFFICES	TOILET EXHAUST	200	12" X 36	0.02	INDUSTRIAL ACOUSTICS CO FCL	
L-CS-107-ST-23	ROOM 169	OSB	EF-04 (FUME HOOD)	800	20 X 20 X 36	0.05	INDUSTRIAL ACOUSTICS CO TSS/TXL	304 S/S PACKLESS CONSTRUCTION, 12"Ø
L-CS-107-ST-24	ROOM 169	OSB	EF-04 (FUME HOOD)	800	20 X 20 X 36	0.05	INDUSTRIAL ACOUSTICS CO TSS/TXL	304 S/S PACKLESS CONSTRUCTION, 12"Ø
L-CS-107-ST-25	ROOM 168	OSB	EF-03 (FUME HOOD)	800	20 X 20 X 36	0.05	INDUSTRIAL ACOUSTICS CO TSS/TXL	304 S/S PACKLESS CONSTRUCTION, 12"Ø
L-CS-107-ST-26	ROOM 168	OSB	EF-03 (FUME HOOD)	800	20 X 20 X 36	0.05	INDUSTRIAL ACOUSTICS CO TSS/TXL	304 S/S PACKLESS CONSTRUCTION, 12"Ø
L-EA-203-ST-01	MECH ROOM 203	ENDSTATION - A	EXPERIMENT EG.	560	12 X 24 X 84	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-02	MECH ROOM 203	ENDSTATION - A	CLEANING AREA	840	12 X 24 X 84	0.07	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-03	MECH ROOM 203	ENDSTATION - A	VEA	8,400	30 X 36 X 84	0.20	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-04	MECH ROOM 203	ENDSTATION - A	INSPECTION	560	12 X 24 X 84	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-05	MECH ROOM 203	ENDSTATION - A	MECH. RM	2,200	18 X 24 X 60	0.12	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-06	MECH ROOM 203	ENDSTATION - A	RETURN	8,400	32 X 32 X 84	0.15	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-07	MECH ROOM 203	ENDSTATION - A	RETURN	4,200	24 X 24 X 84	0.12	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-08	MECH ROOM 203	ENDSTATION - A	OUTSIDE AIR	400	18 X 12 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-09	MECH ROOM 203	ENDSTATION - A	OUTSIDE AIR	400	18 X 12 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-10	MECH ROOM 203	ENDSTATION - A	VE	1680	12 X 24 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-01	MECH ROOM 203	ENDSTATION - B	EXPERIMENT EG.	560	12 X 24 X 84	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-02	MECH ROOM 203	ENDSTATION - B	CLEANING AREA	840	12 X 24 X 84	0.07	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-03	MECH ROOM 203	ENDSTATION - B	VEA	8,400	30 X 36 X 84	0.20	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-04	MECH ROOM 203	ENDSTATION - B	INSPECTION	560	12 X 24 X 84	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-05	MECH ROOM 203	ENDSTATION - B	MECH. RM	2,200	18 X 24 X 60	0.12	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-06	MECH ROOM 203	ENDSTATION - B	RETURN	8,400	32 X 32 X 84	0.15	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-07	MECH ROOM 203	ENDSTATION - B	RETURN	4,200	24 X 24 X 84	0.12	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-08	MECH ROOM 203	ENDSTATION - B	OUTSIDE AIR	400	18 X 12 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-09	MECH ROOM 203	ENDSTATION - B	OUTSIDE AIR	400	18 X 12 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-10	MECH ROOM 203	ENDSTATION - B	VE	1680	12 X 24 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	

AIR INLET & OUTLET SCHEDULE

UNIT NO	DESCRIPTION	FACE SIZE	NECK SIZE IN X IN	CONSTRUCTION	MANUFACTURER/ MODEL NO	REMARKS
HF-1	HEPA FILTER	48 X 24	12" Ø	STEEL	FARR CPYRG	5" DEEP FILTER, (1), (2)
HF-2	HEPA FILTER	24 X 24	10" Ø	STEEL	FARR CPYRG	5" DEEP FILTER, (1), (2)
CD-1	CEILING DIFFUSER	24 X 24	(3)	ALUMINUM	KRUEGER 6604	W/OBD
CD-2	CEILING DIFFUSER	N/A	(3)	ALUMINUM	KRUEGER 6604	W/BUTTERFLY DAMPER
RR-1	RETURN REGISTER	(3)	N/A	ALUMINUM	KRUEGER 6604	W/OBB
RR-2	RETURN REGISTER	(3)	N/A	ALUMINUM	KRUEGER 5580 H OR V	W/OBB
RG-1	RETURN GRILLE	24 X 24	N/A	ALUMINUM	KRUEGER 5580 H OR V	W/OBB
RG-2	RETURN GRILLE	(3)	(3)	ALUMINUM	KRUEGER 5580 H OR V	W/OBB
SR-1	SUPPLY REGISTER	(3)	(3)	ALUMINUM	KRUEGER 6604	W/OBD

(1) PROVIDE WITH HANGING TAPS, STAINLESS STEEL TRIM, 1 1/2" INSULATION WITH ALUMINUM FOIL
 (2) INITIAL PRESSURE DROP = 0.50" WC, REPLACEMENT PRESSURE DROP = 2.0" WC
 (3) SEE PLANS

NOTES:

1. FOR LEGEND, ABBREVIATIONS AND GENERAL NOTES SEE SHEETS LA-H-001 AND LA-H-002.

VIBRATION ISOLATOR SCHEDULE - BY VIBRATION ELIMINATOR CO. INC.

UNIT NO	NAME	LOCATION	(2) ISOLATOR TYPE	(3) SPRING DEFLECTION (INCH)	(2) FRAME TYPE	(2) SEISMIC RESTRAINT	REMARKS
L-CS-107-SF-01, 02, 03, 04	VANE AXIAL FAN	CORNER STATION	B	1.0	G	SL	(TYP 4) FANS
L-CS-107-SF-05, 06	VANE AXIAL FAN	CORNER STATION	B	1.0	G	SL	(TYP 2) FANS
L-EA-203-SF-01, 02	VANE AXIAL FAN	END STATION-A	B	1.0	G	SL	(TYP 2) FANS
L-EB-203-SF-01, 02	VANE AXIAL FAN	END STATION-B	B	1.0	G	SL	(TYP 2) FANS
L-CS-190-CH-01, 02, 03	AIR-COOLED WATER CHILLER	CORNER STATION	C	1.0	-	(1)	(TYP 3) CHILLERS
L-EA-200-CH-01, 02	AIR-COOLED WATER CHILLER	END STATION-A	C	1.0	-	(1)	(TYP 2) CHILLERS
L-EB-200-CH-01, 02	AIR-COOLED WATER CHILLER	END STATION-B	C	1.0	-	(1)	(TYP 2) CHILLERS
L-CS-190-WP-01, 02, 03	CHILLED WATER PUMP	CORNER STATION	C	1.0	G	SL	(TYP 3) PUMPS
L-EA-200-WP-01, 02	CHILLED WATER PUMP	END STATION-A	C	1.0	G	SL	(TYP 2) PUMPS
L-EB-200-WP-01, 02	CHILLED WATER PUMP	END STATION-B	C	1.0	G	SL	(TYP 2) PUMPS
L-CS-107-AC-01, 02	AIR COMPRESSOR	CORNER STATION	C	1.0	G	SL	(TYP 2) COMPRESSORS
L-EA-203-AC-01, 02	AIR COMPRESSOR	END STATION-A	C	1.0	G	SL	(TYP 2) COMPRESSORS
L-EB-203-AC-01, 02	AIR COMPRESSOR	END STATION-B	C	1.0	G	SL	(TYP 2) COMPRESSORS
L-CS-160-AH-04	PACKAGED AIR HANDLER	CORNER STATION	B	1.0	G	SL	
L-CS-149-EF-01	IN-LINE EXHAUST FAN	CORNER STATION	D	1.0	-	SC	
L-CS-137-EF-02	IN-LINE EXHAUST FAN	CORNER STATION	D	1.0	-	SC	
L-CS-168-EF-03	IN-LINE EXHAUST FAN	CORNER STATION	D	1.0	-	SC	
L-CS-169-EF-04	IN-LINE EXHAUST FAN	CORNER STATION	D	1.0	-	SC	
L-EA-208-EF-01	IN-LINE EXHAUST FAN	END STATION-A	D	1.0	-	SC	
L-EB-208-EF-01	IN-LINE EXHAUST FAN	END STATION-B	D	1.0	-	SC	
L-CS-107-GP-01	GLYCOL FEED PUMP	CORNER STATION	C	1.0	G	SL	
L-EA-203-GP-01	GLYCOL FEED PUMP	END STATION-A	C	1.0	G	SL	
L-EB-203-GP-01	GLYCOL FEED PUMP	END STATION-B	C	1.0	G	SL	
L-CS-195-FP-01	FIRE PUMP	CORNER STATION	C	1.0	G	SL	
L-CS-195-FP-02	FIRE PUMP	CORNER STATION	C	1.0	G	SL	
L-CS-195-JP-03	JOCKY PUMP	CORNER STATION	C	1.0	G	SL	
L-CS-196-DP-04	DOMESTIC WATER PUMP	CORNER STATION	C	1.0	G	SL	
L-CS-196-DP-05	DOMESTIC WATER PUMP	CORNER STATION	C	1.0	G	SL	
L-CS-196-AH-05	PACKAGED AIR HANDLER	CORNER STATION	D	1.0	-	SC	

(1) ISOLATOR HOUSING INCLUDES SEISMIC RESTRAINTS
 (2) SEE SPECIFICATIONS FOR CODE LETTER
 (3) STATIC DEFLECTION 3 HZ

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

DRAWING NO.	DESCRIPTION	NO.	DATE	BY	CHKD	ENGR	PROJ	DESCRIPTION
3	5-21-99	AO	AA	AA				ISSUED AS REVISED AS-BUILT
2	8-7-98	DJB	AA	AA				ISSUED FOR AS-BUILT
1	3-20-97	WNK	AA	AA				REVISED DUCT SILENCER SCHEDULE

ISSUED FOR CONSTRUCTION
 DRAWN CLP 11-15-96
 CHECKED MN 10-25-96
 ENGINEER AA 10-23-96
 PROJ TDM 11-15-96

AS-BUILT DRAWINGS

100 WEST WALNUT STREET
PASADENA, CALIFORNIA

CALIFORNIA INSTITUTE OF TECHNOLOGY
MASSACHUSETTS INSTITUTE OF TECHNOLOGY

LIGO-D960965-03-O

LASER INTERFEROMETER
GRAVITATIONAL-WAVE OBSERVATORY
SITE NO. 2 - LIVINGSTON, LOUISIANA

HVAC EQUIPMENT SCHEDULES
SHEET 4

SCALE: NONE CONTRACT NUMBER: PPI50969 PROJECT NUMBER: 8094

SHEET NUMBER: **LA-H-006** REVISIONS: 3