

PLAN SYMBOLS

- RAYWAY EXPOSED, INCLUDING WITHIN PLENUMS, HUNG CEILING SPACES AND BELOW PLATFORMS.
- RAYWAY CONCEALED IN WALL, CEILING, BURIED IN EARTH OR EMBEDDED IN CONCRETE.
- WIRING BURIED IN EARTH OR EMBEDDED IN CONCRETE.
- VISIBLE, EXTENSION, PROJECTION, OR BACKGROUND.
- HIDDEN BACKGROUND.
- CENTER LINE.
- FLEXIBLE RAYWAY.
- BOUNDARY OR MATCH LINE.
- FLUSH GROUNDING SPOOL IN GROUND SYSTEM.
- LIGHTNING PROTECTION AIR TERMINAL.
- EXOTHERMIC WELD IN GROUND SYSTEM. BRAZING, CLAMPING, BOLTING, OR WEDGING SHALL NOT BE USED.
- GROUND ROD IN GROUND SYSTEM.
- GROUND WELL FOR PAVED AREA
- GROUND WELL FOR UNPAVED AREA
- CONDUIT CAPPED.
- BREAK IN LINE FOR DRAFTING CLARITY.
- WIRING UP, CONTINUED IN ANOTHER VIEW
- WIRING DOWN TO ENCLOSURE OR CONTINUED IN ANOTHER VIEW.
- WIRING DOWN IN SAME VIEW, CHANGING ELEV.
- CONDUIT SEALING FITTING, UL LABELED.
- JUNCTION BOX, PULL BOX, OR CONDUIT BODY, UL LABELED. FIELD SIZED PER NEC CODE. (NOTE 3)
- ENGINEERED BOX. J=JUNCTION BOX, P=PULL BOX, T=TERMINAL BOX, UL LABELED. SIZE AND FUNCTION AS SHOWN ON PLAN (H X W X D).
- CROSS MARKS INDICATE NUMBER OF #10 AWG (OR AS NOTED ON DWG) CONDUCTORS, INCLUDING NEUTRALS AND GREEN INSULATED GROUND WIRES.
- HOME RUN TO CIRCUIT BREAKER PANEL, SHOWN MULTIPLE CIRCUIT 1, 3, 5 AND SEPARATE CIRCUIT 7 OF PANEL LP01.
- WIRING RUN IDENTIFICATION SHOWN AS TWO CONDUITS EACH BEING ONE INCH O.D. CONTAINING 5 #10 AWG THIN CONDUCTORS AND 2 #10 (GREEN) GROUND WIRES
- THREE PHASE CIRCUIT WITH DEDICATED NEUTRAL AND GROUND, PANEL RP01, CIRCUITS 1, 3 AND 5
- SURFACE MOUNT PANEL BOARD AS IDENTIFIED ON SINGLE LINE DIAGRAM AND IN PANEL SCHEDULE, UL LABELED.
- RECESSED MOUNTED PANEL BOARD AS IDENTIFIED ON SINGLE LINE DIAGRAM AND IN PANEL SCHEDULE, UL LABELED
- POWER PANEL.
- CONTROL PANEL.
- SIGNAL OR COMMUNICATIONS CABINET AS IDENTIFIED ON PLAN. IP = INSTRUMENT PANEL, FP = FIRE ALARM PANEL.
- TELEPHONE TERMINAL CABINET.
- EMERGENCY BATTERY CABINET.
- SURFACE METAL RAYWAY AS IDENTIFIED ON PLAN, UL LABELED. NEMA #5-20R, 2P, 3W, 20A RECEPTACLES UNLESS OTHERWISE IDENTIFIED.
- MOTOR CONTROL CENTER OR SWITCHGEAR, SHOWN INCLUDING SPACE FOR FUTURE CUBICLE.
- CABLE TRAY, SIZE AND SHAPE IDENTIFICATION PER NEMA STANDARD VE1-1984.
- SWITCH, NEMA 1 ENCLOSED UON, HORSEPOWER RATED DISCONNECT, UL LABELED. THREE WIRE FOUR POLE SHOWN. F = FUSED A=AMPERES CONTINUOUS RATING NF= NON-FUSED W = WIRE P = POLE
- MANUAL MOTOR STARTER, NEMA 1 ENCLOSED UON, UL LABELED.
- MAGNETIC CONTACTOR, NEMA 1 ENCLOSED UON, UL LABELED.
- MAGNETIC MOTOR STARTER, FULL LOAD NON-REVERSING, NEMA 1 ENCLOSED UON, UL LABELED.
- REVERSING MAGNETIC MOTOR STARTER, NEMA 1 ENCLOSED UON, UL LABELED.

PLAN SYMBOLS

- MOTOR, SHOWING ORIENTATION OF TERMINAL BOX AND EQUIPMENT TAG NUMBER. REFER TO MOTOR CONTROL CENTER DRAWINGS.
- CENTERLINE OF SUPPORT ATTACHED TO STEEL COLUMN.
- DIMMER WITH COVER AND ENCLOSURE, MOUNTED +4'-6" UNLESS OTHERWISE NOTED. a,b,c, ETC = OUTLETS SWITCHED. 2 = TWO WAY. 3 = THREE WAY. 4 = FOUR WAY. W = WEATHERPROOF. M = MANUAL STARTER
- SWITCH, SINGLE POLE, WITH COVER AND ENCLOSURE, MOUNTED +4'-6" UNLESS OTHERWISE NOTED. 2 = TWO POLE. a,b,c, ETC = OUTLETS SWITCHED. 3 = THREE WAY. EP = EXPLOSION-PROOF. K = KEY OPERATED. WP = WEATHERPROOF. M = MANUAL STARTER
- TRACK LIGHTING FIXTURE
- WALL MOUNTING FIXTURE SEE PLAN FOR TYPE
- EMERGENCY LIGHTING UNIT. (SELF CONTAINED). TRANSFER TYPE
- FLOOD OR SPOT LIGHT, SHOWN WALL BRACKET MOUNTED, INCLUDING JUNCTION BOX WITH COVER. AP = AIMING POINT. OG = ON GRADE. AG = ABOVE GRADE. OW = ON WALL.
- METAL HALIDE LIGHT FIXTURE FOR GLOBE TYPE LAMPS AS IDENTIFIED ON PLANS OR SCHEDULES. SUBSCRIPT INDICATES CIRCUIT AND SWITCH.
- INCANDESCENT LIGHT FIXTURE, CEILING MOUNTED
- FIXTURE, RECESSED 2"x 2" SEE PLAN FOR TYPE
- LIGHT FIXTURE, SEE PLAN FOR TYPE "E" FOR EMERGENCY CIRCUIT OPERATION "M" FOR MASTER BALLAST "S" FOR SATELLITE FIXTURE SURFACE, PENDANT OR RECESSED MOUNTED (TYPICAL).
- REFERENCE TO ELECTRICAL MATERIAL SCHEDULES FOR MOUNTING HEIGHT SEE NOTES 3 & 7.
- SINGLE RECEPTACLE, UL LABELED, 3 WIRE, 2 POLE, 20 AMP. GROUNDING TYPE, NEMA #5-20R. WP = WEATHER PROOF. EP = EXPLOSION PROOF.
- DUPLEX RECEPTACLE UL LABELED, 3 WIRE, 2 POLE, 20 AMP. GROUNDING TYPE NEMA #5-20R WALL MOUNTED
- DUPLEX RECEPTACLE, UL LABELED, 3 WIRE, 2 POLE, 20 AMP. GROUNDING TYPE NEMA #5-20R. BOX INDICATES FLOOR MOUNTING, TYPICAL.
- DUAL DUPLEX, WALL-MOUNTED RECEPTACLE ISOLATED UL LABELED, 3 WIRE, 2POLE, 20AMPERE, GROUNDING TYPE NEMA 5-20R
- DUAL DUPLEX, FLOOR-MOUNTED RECEPTACLE ISOLATED UL LABELED, 3 WIRE, 2POLE, 20AMPERE, GROUNDING TYPE NEMA 5-20R
- SPECIAL PURPOSE RECEPTACLES, AS IDENTIFIED ON PLAN.
- WELDING OR OTHER SPECIAL PURPOSE RECEPTACLE AS IDENTIFIED ON PLAN.
- SPECIAL OUTLET: C = CLOCK, T=THERMOSTAT. H = HUMIDISTAT.
- EXIT LIGHT, WALL SURFACE MOUNTED WITH UNIVERSAL KNOCKOUT. DIRECTIONAL ARROWS (AS REQUIRED)
- EXIT LIGHT (SAME AS ABOVE, EXCEPT CEILING MOUNTED)
- ANNUNCIATOR. H = HORN S = SPEAKER.
- BELL.
- SMOKE DETECTOR. "PP" DENOTES PHOTO-ELECTRIC TYPE. "2" INDICATES ZONE OF SERVICE.
- BUZZER.
- PUSH BUTTON STATION (SHOWN WITH STANCHION MOUNT).
- MANUAL ALARM PULL STATION
- DEVICE AS IDENTIFIED ON PROCESS DIAGRAM
- NEW TELEPHONE OUTLET (WALL MOUNTED).
- DATA OUTLET (WALL MOUNTED).
- ELECTRICAL OR MECHANICAL EQUIPMENT AS IDENTIFIED ON PLAN.
- WARNING LIGHT, STROBE.

PLAN SYMBOLS

- ELECTRICAL DEVICE WITH BOX OR ENCLOSURE.
- Circuit Breaker, Door Switch, Emergency Light Switch, Flame Detector, Flow Recorder Controller, Flow Switch, Flow Transmitter, Heat Detector, High Level Switch, Ionization Detector, Limit Switch, Level Transmitter, Manual Pull Fire Alarm Station, Oil Fuse Cutout, Pilot or Indicating Light, Photo Electric Cell, Pressure Switch, Pressure Transmitter, Rope Switch, Switch as Indicated on Plan, High-High Level Switch, Hand-Off-Automatic Switch, Low-Low Level Switch, Manual-Off-Automatic Switch, On/Off Control Switch, Remote-Off-Automatic, Torn Belt Switch, Zero Speed Switch, Smoke Detector, Temperature Controller, Test Switch, Vibration Switch.
- EXISTING POLE WITH CONTINUING CONDUCTORS. SHOWN WITH POLE NUMBER, TYPE, HEIGHT, AND CLASS PER ANSI O5. 1-1987.
- DCFC = DOUGLAS FIR CRESSOTE TREATED.
- DPT = DOUGLAS FIR PENTA TREATED.
- WRC = WESTERN RED CEDAR UNTREATED.
- WRCC = WRC CRESSOTE TREATED.
- SP = SOUTHERN PINE UNTREATED.
- SPC = SOUTHERN PINE CRESSOTE TREATED.
- CIRCUIT IDENTIFICATION. C = CONTROL. S = SECONDARY. F = FIRE ALARM. T = TELEPHONE. I = INSTRUMENTATION. SD = SERVICE DROP. P = PRIMARY.
- EXISTING POLE WITH SIDEWALK GUY.
- NEW POLE, WITH ANCHOR.
- HEAD GUY BETWEEN NEW POLES.
- EXISTING DISTRIBUTION TYPE TRANSFORMER.
- PAD MOUNTED TRANSFORMER.
- NEW DISTRIBUTION TYPE TRANSFORMER.
- SERVICE WEATHERHEAD.
- EXISTING STEEL TOWER. IDENTIFY WITH SEQUENTIAL NUMBER (TYPICAL).
- NEW STEEL TOWER. IDENTIFY WITH SEQUENTIAL NUMBER (TYPICAL).
- ACCESS CHAMBER (AC) WITH SEQUENTIAL NUMBER. E = ELECTRICAL. C = COMMUNICATIONS. T = TELEPHONE. H = HANDHOLE. V = VAULT.
- OVERHEAD CONDUCTOR WITH SWITCH. SS = TOP ARM SECTIONALIZING SWITCH. UA = UNDER ARM SWITCH. PTD = POLE TOP DISCONNECT SWITCH. N.C. = NORMALLY CLOSED. OFC = OIL FUSE CUTOUT. N.O. = NORMALLY OPEN. PFC = PORCELAIN FUSED CUTOUT.
- POLE WITH CONDUCTOR DEADENDS AND JUMPER.
- OVERHEAD CONDUCTOR WITH POLE MOUNTED SECTIONALIZER. G = SF6 GAS. V = VACUUM.
- OVERHEAD CONDUCTOR; QUANTITY, SIZE, AND TYPE IDENTIFICATION. AAC = ALL ALUMINUM CONDUCTOR, IDENTIFIED WITH FLOWER NAME. AAAC = ALL ALUMINUM ALLOY CONDUCTOR, IDENTIFIED WITH CITY NAME. ACSR = ALUMINUM CABLE STEEL REINFORCED, IDENTIFIED WITH BIRD NAME. AN = ANNEALED. HD = HARD DRAWN. MH = MEDIUM HARD DRAWN. CU = COPPER, SOFT OR ANNEALED, UON. WP = WEATHERPROOF.
- OVERHEAD CONDUCTOR WITH POLE MOUNTED STREET LIGHT. I = INCANDESCENT. HPS = HIGH PRESSURE SODIUM. MH = METAL HALIDE.
- OVERHEAD CONDUCTOR WITH POLE MOUNTED FLOODLIGHT.
- OVERHEAD CONDUCTOR WITH FUSED SWITCH. SHOWN WITH BE FUSE.

NOTES:

- APPROPRIATE BOX AND COVER SHALL BE PROVIDED WITH ALL OUTLETS, SEE SPECIFICATIONS.
- GROUND UNDERGROUND PIPING TO MAIN GROUNDING COUNTERPOISE.
- MOUNTING HEIGHT OF EQUIPMENT, UNLESS OTHERWISE NOTED, SHALL BE ABOVE FINISHED FLOOR AS FOLLOWS:
 - LIGHTS OVER DOORS, 1'-0" ABOVE DOOR OPENINGS TO BOTTOM OF FIXTURE.
 - LOCAL SWITCHES, 4'-6" TO CENTERLINE.
 - OFFICE AND CONTROL ROOM RECEPTACLES 1'-6" TO CENTERLINE.
 - OTHER RECEPTACLES, 3'-6" TO CENTERLINE.
 - LIGHTING PANELS, 8'-0" MAXIMUM TO TOP CIRCUIT BREAKER.
- EMERGENCY LIGHTING SYSTEM BRANCH CIRCUIT RAYWAY AS WELL AS FIRE ALARM AND DETECTION RAYWAY SHALL BE INDEPENDENT OF OTHER RAYWAY SYSTEMS.
- MINIMUM CONDUCTOR SIZE FOR ALL LIGHTING AND 120V CONVENIENCE RECEPTACLE CIRCUITS SHALL BE AWG #12, 600V, TYPE THW INSULATION STRANDED COPPER WIRE, UNLESS OTHERWISE NOTED. CONNECTIONS SHALL BE MADE WITH CRIMP LUGS AND CRIMP CONNECTORS. WIRE NUTS SHALL NOT BE USED.
- FLEXIBLE CONDUIT SHALL BE USED FOR RECESSED FIXTURES FROM THE JUNCTION BOX TO THE FIXTURE NOT EXCEEDING A MAXIMUM LENGTH OF 6'-0". MINIMUM LENGTH FOR FLEXIBILITY SHALL BE 3'-0".
- MOUNTING HEIGHT OF LIGHTING FIXTURES, AS INDICATED ON THE DRAWINGS, IS FROM FINISHED FLOOR, PLATFORM, OR DECK TO BOTTOM OF FIXTURE.
- MINIMUM DISTANCE BETWEEN THE TOP OF CABLE TRAY AND BOTTOM OF THE STRUCTURAL STEEL DIRECTLY ABOVE IT SHALL BE 6". WHERE TWO TRAYS CROSS EACH OTHER, THE TOP OF THE LOWER TRAY TO THE BOTTOM OF THE TRAY ABOVE SHALL BE 6" MINIMUM.
- THE CONSTRUCTOR SHALL PROVIDE CONDUIT BODIES, FITTINGS, AND SUPPORTS NOT SHOWN ON THE DRAWINGS BUT REQUIRED BY JOB CONFIGURATION OR THE NEC.

POLELINE AND DUCTBANK PLAN SYMBOLS


- EXISTING POLE WITH CONTINUING CONDUCTORS. SHOWN WITH POLE NUMBER, TYPE, HEIGHT, AND CLASS PER ANSI O5. 1-1987.
- DCFC = DOUGLAS FIR CRESSOTE TREATED.
- DPT = DOUGLAS FIR PENTA TREATED.
- WRC = WESTERN RED CEDAR UNTREATED.
- WRCC = WRC CRESSOTE TREATED.
- SP = SOUTHERN PINE UNTREATED.
- SPC = SOUTHERN PINE CRESSOTE TREATED.
- CIRCUIT IDENTIFICATION. C = CONTROL. S = SECONDARY. F = FIRE ALARM. T = TELEPHONE. I = INSTRUMENTATION. SD = SERVICE DROP. P = PRIMARY.
- EXISTING POLE WITH SIDEWALK GUY.
- NEW POLE, WITH ANCHOR.
- HEAD GUY BETWEEN NEW POLES.
- EXISTING DISTRIBUTION TYPE TRANSFORMER.
- PAD MOUNTED TRANSFORMER.
- NEW DISTRIBUTION TYPE TRANSFORMER.
- SERVICE WEATHERHEAD.
- EXISTING STEEL TOWER. IDENTIFY WITH SEQUENTIAL NUMBER (TYPICAL).
- NEW STEEL TOWER. IDENTIFY WITH SEQUENTIAL NUMBER (TYPICAL).
- ACCESS CHAMBER (AC) WITH SEQUENTIAL NUMBER. E = ELECTRICAL. C = COMMUNICATIONS. T = TELEPHONE. H = HANDHOLE. V = VAULT.
- OVERHEAD CONDUCTOR WITH SWITCH. SS = TOP ARM SECTIONALIZING SWITCH. UA = UNDER ARM SWITCH. PTD = POLE TOP DISCONNECT SWITCH. N.C. = NORMALLY CLOSED. OFC = OIL FUSE CUTOUT. N.O. = NORMALLY OPEN. PFC = PORCELAIN FUSED CUTOUT.
- POLE WITH CONDUCTOR DEADENDS AND JUMPER.
- OVERHEAD CONDUCTOR WITH POLE MOUNTED SECTIONALIZER. G = SF6 GAS. V = VACUUM.
- OVERHEAD CONDUCTOR; QUANTITY, SIZE, AND TYPE IDENTIFICATION. AAC = ALL ALUMINUM CONDUCTOR, IDENTIFIED WITH FLOWER NAME. AAAC = ALL ALUMINUM ALLOY CONDUCTOR, IDENTIFIED WITH CITY NAME. ACSR = ALUMINUM CABLE STEEL REINFORCED, IDENTIFIED WITH BIRD NAME. AN = ANNEALED. HD = HARD DRAWN. MH = MEDIUM HARD DRAWN. CU = COPPER, SOFT OR ANNEALED, UON. WP = WEATHERPROOF.
- OVERHEAD CONDUCTOR WITH POLE MOUNTED STREET LIGHT. I = INCANDESCENT. HPS = HIGH PRESSURE SODIUM. MH = METAL HALIDE.
- OVERHEAD CONDUCTOR WITH POLE MOUNTED FLOODLIGHT.
- OVERHEAD CONDUCTOR WITH FUSED SWITCH. SHOWN WITH BE FUSE.

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

REFERENCES	DESCRIPTION	NO.	DATE	BY	CHKD	ENGR	PROJ	DESCRIPTION
LA-E-001	ABBREVIATIONS & ACRONYMS							
LA-E-003	SCHEMATIC & WIRING DIAGRAM SYMBOLS							
LA-E-004	ONE & THREE LINE DIAGRAM SYMBOLS							

ISSUED FOR CONSTRUCTION			
DRAWN	M. M.	11-15-96	
CHECKED	JCL	7-24-96	
ENGINEER	LSA	10-28-96	
PROJ	SP/A	11/1/96	



PARSONS

100 WEST WALNUT STREET
PASADENA, CALIFORNIA

LIGO

CALIFORNIA INSTITUTE OF TECHNOLOGY
MASSACHUSETTS INSTITUTE OF TECHNOLOGY

LASER INTERFEROMETER GRAVITATIONAL-WAVE OBSERVATORY SITE NO. 2 - LIVINGSTON, LOUISIANA			
TITLE	SCALE	CONTRACT NUMBER	PROJECT NUMBER
ELECTRICAL STANDARD PLAN SYMBOLS	NONE	PP150969	8094