

| PANEL 144LP.1 | | LOCATION ROOM 144 | | | | | | | | | | VOLTS 480Y/277V | | | | |
|-----------------------------|------------------------|-------------------|--------|-----------|-----|-----------|-----------------|-------|-------|-----------|-----|-----------------|-------|--------------------------------|-------------|-----|
| FED FROM | CKT # | MOUNTING Recessed | | | | | | | | | | MAIN | | | | |
| | | PHASE 3 | WIRE 4 | FEEDER | | BUS 225 | | | | | | | | | | |
| CKT | LOAD SERVED | SLOT | POLES | WIRE SIZE | BKR | VOLT AMPS | PHASE LOAD (VA) | | | VOLT AMPS | BKR | WIRE SIZE | POLES | SLOT | LOAD SERVED | CKT |
| | | | | | | | A | B | C | | | | | | | |
| 1 | LTG RM 147 | 1 | 1 | 15 | | 855 | 855 | 0 | 0 | 2542 | 15 | 1 | 2 | LTG RM 128,130,131,138,139,152 | 2 | |
| 3 | LTG RM 122 | 3 | 1 | 20 | | 1872 | 0 | 1872 | 0 | 332 | 15 | 1 | 4 | LTG RM 148,149 | 4 | |
| 5 | CORRIDOR 146 | 5 | 1 | 15 | | 216 | 0 | 0 | 0 | 216 | 15 | 1 | 6 | LTG RM 144,145 | 6 | |
| 7 | LTG RM 136,137,151 | 7 | 1 | 15 | | 352 | 352 | 0 | 0 | 150 | 15 | 1 | 8 | EMERGENCY LIGHTING | 8 | |
| 9 | EXIT | 9 | 1 | 15 | | 10 | 0 | 10 | 0 | 1140 | 15 | 1 | 10 | LTG 140,141,142,143,125 | 10 | |
| 11 | LTG RM 123,124,126,127 | 11 | 1 | 15 | | 1045 | 0 | 0 | 0 | 1330 | 15 | 1 | 12 | LTG RM 129-135 | 12 | |
| 13 | PARKING LOT LIGHTING | 13 | 1 | 20 | | 720 | 720 | 0 | 0 | 8000 | 15 | 3 | 14 | L-CS-136-WH-02 | 14 | |
| 15 | SPARE | 15 | 1 | 20 | | 0 | 0 | 0 | 0 | 0 | | 1 | 16 | | | |
| 17 | SPARE | 17 | 1 | 20 | | 0 | 0 | 0 | 0 | 2666 | | 1 | 18 | | | |
| 19 | L-CS-138-SV-2B | 19 | 3 | 20 | | 13000 | 4333 | 4333 | 4333 | 13000 | 20 | 3 | 20 | L-CS-132-SV-04 | 20 | |
| 21 | | 21 | | | | 0 | 0 | 0 | 0 | 0 | | 1 | 22 | | | |
| 23 | | 23 | | | | 0 | 0 | 0 | 0 | 4333 | | 1 | 24 | | | |
| 25 | L-CS-129-SV-06 | 25 | 3 | 20 | | 13000 | 4333 | 4333 | 4333 | 13000 | 20 | 3 | 26 | L-CS-127-SV-08 | 26 | |
| 27 | | 27 | | | | 0 | 0 | 0 | 0 | 0 | | 1 | 28 | | | |
| 29 | | 29 | | | | 0 | 0 | 0 | 0 | 4333 | | 1 | 30 | | | |
| 31 | L-CS-146-SV-16A | 31 | 3 | 20 | | 13000 | 4333 | 4333 | 4333 | 13000 | 20 | 3 | 32 | L-CS-146-SV-16B | 32 | |
| 33 | | 33 | | | | 0 | 0 | 0 | 0 | 0 | | 1 | 34 | | | |
| 35 | | 35 | | | | 0 | 0 | 0 | 0 | 4333 | | 1 | 36 | | | |
| 37 | L-CS-147-SV-15 | 37 | 3 | 20 | | 13000 | 4333 | 1000 | 0 | 3000 | 15 | 3 | 38 | L-CS-149-WH-01 | 38 | |
| 39 | | 39 | | | | 0 | 0 | 0 | 0 | 0 | | 1 | 40 | | | |
| 41 | | 41 | | | | 0 | 0 | 0 | 0 | 720 | | 1 | 42 | | | |
| TOTAL | | | | | | | 38616 | 37256 | 36968 | | | | | | | |
| TOTAL CONNECTED LOAD (VA) | | | | | | | 112840 | | | | | | | | | |
| TOTAL CONNECTED LOAD (AMPS) | | | | | | | | | | | | | | | | |

| PANEL 163LP.1 | | LOCATION ROOM 163 | | | | | | | | | | VOLTS 480Y/277V | | | | |
|-----------------------------|--------------------|-------------------|--------|-----------|-----|-----------|-----------------|-------|-------|-----------|-----|-----------------|-------|----------------|-------------|-----|
| FED FROM | CKT # | MOUNTING Square D | | | | | | | | | | MAIN | | | | |
| | | PHASE 3 | WIRE 4 | FEEDER | | BUS 225 | | | | | | | | | | |
| CKT | LOAD SERVED | SLOT | POLES | WIRE SIZE | BKR | VOLT AMPS | PHASE LOAD (VA) | | | VOLT AMPS | BKR | WIRE SIZE | POLES | SLOT | LOAD SERVED | CKT |
| | | | | | | | A | B | C | | | | | | | |
| 1 | LTG RM 166 | 1 | 1 | 15 | | 1824 | 1824 | 0 | 0 | 3135 | 15 | 1 | 2 | LTG RM 167 | 2 | |
| 3 | RM 160,161,163 | 3 | 1 | 15 | | 1238 | 0 | 1238 | 0 | 1482 | 15 | 1 | 4 | LTG RM 174 | 4 | |
| 5 | LTG RM 175 | 5 | 1 | 15 | | 2736 | 0 | 0 | 0 | 884 | 15 | 1 | 6 | LTG RM 171,172 | 6 | |
| 7 | LTG RM 162 | 7 | 1 | 15 | | 1425 | 1425 | 0 | 0 | 864 | 15 | 1 | 8 | HALL | 8 | |
| 9 | LTG RM 173 | 9 | 1 | 15 | | 2700 | 0 | 2700 | 0 | 760 | 15 | 1 | 10 | LTG RM 169 | 10 | |
| 11 | LTG RM 170 | 11 | 1 | 15 | | 2400 | 0 | 0 | 0 | 2400 | 15 | 1 | 12 | LTG RM 168 | 12 | |
| 13 | L-CS-135-SV-01 | 13 | 3 | 20 | | 13000 | 4333 | 4333 | 4333 | 19000 | 30 | 3 | 14 | L-CS-138-SV-2A | 14 | |
| 15 | | 15 | | | | 0 | 0 | 0 | 0 | 0 | | 1 | 16 | | | |
| 17 | | 17 | | | | 0 | 0 | 0 | 0 | 4333 | | 1 | 18 | | | |
| 19 | LTG RM 165 | 19 | 1 | 15 | | 950 | 950 | 0 | 0 | 0 | 30 | 1 | 20 | SPARE | 20 | |
| 21 | SPARE | 21 | 1 | 15 | | 0 | 0 | 0 | 0 | 0 | | 1 | 22 | | | |
| 23 | EMERGENCY LIGHTING | 23 | 1 | 15 | | 240 | 0 | 0 | 0 | 240 | | 1 | 24 | | | |
| 25 | SPARE | 25 | 3 | 20 | | 0 | 0 | 0 | 0 | 0 | 20 | 1 | 26 | SPARE | 26 | |
| 27 | | 27 | | | | 0 | 0 | 0 | 0 | 0 | 20 | 1 | 28 | SPARE | 28 | |
| 29 | | 29 | | | | 0 | 0 | 0 | 0 | 0 | 20 | 1 | 30 | SPARE | 30 | |
| 31 | SPARE | 31 | 1 | 20 | | 0 | 0 | 0 | 0 | 0 | 15 | 1 | 32 | SPARE | 32 | |
| 33 | SPARE | 33 | 1 | 20 | | 0 | 0 | 0 | 0 | 0 | 15 | 1 | 34 | SPARE | 34 | |
| 35 | SPARE | 35 | 1 | 20 | | 0 | 0 | 0 | 0 | 0 | 15 | 1 | 36 | SPARE | 36 | |
| 37 | SPARE | 37 | 1 | 15 | | 0 | 0 | 0 | 0 | 0 | 15 | 1 | 38 | SPARE | 38 | |
| 39 | SPARE | 39 | 1 | 15 | | 0 | 0 | 0 | 0 | 0 | 15 | 1 | 40 | SPARE | 40 | |
| 41 | SPARE | 41 | 1 | 15 | | 0 | 0 | 0 | 0 | 0 | 15 | 1 | 42 | SPARE | 42 | |
| TOTAL | | | | | | | 18864 | 16846 | 17286 | | | | | | | |
| TOTAL CONNECTED LOAD (VA) | | | | | | | 52996 | | | | | | | | | |
| TOTAL CONNECTED LOAD (AMPS) | | | | | | | | | | | | | | | | |

| PANEL 172RP.1 | | LOCATION ROOM 172 | | | | | | | | | | VOLTS 208Y/120V | | | | |
|-----------------------------|----------------------|-------------------|--------|-----------|-----|-----------|-----------------|-------|-------|-----------|-----|-----------------|-------|------------------|-------------|-----|
| FED FROM | CKT # | MOUNTING Recessed | | | | | | | | | | MAIN | | | | |
| | | PHASE 3 | WIRE 4 | FEEDER | | BUS 225 | | | | | | | | | | |
| CKT | LOAD SERVED | SLOT | POLES | WIRE SIZE | BKR | VOLT AMPS | PHASE LOAD (VA) | | | VOLT AMPS | BKR | WIRE SIZE | POLES | SLOT | LOAD SERVED | CKT |
| | | | | | | | A | B | C | | | | | | | |
| 1 | RCPT RM 175 | 1 | 3 | 30 | | 8646 | 2882 | 2882 | 2882 | 8646 | 30 | 3 | 2 | RCPT RM 175 | 2 | |
| 3 | | 3 | | | | 0 | 0 | 0 | 0 | 0 | | 1 | 4 | | | |
| 5 | | 5 | | | | 0 | 0 | 0 | 0 | 0 | | 1 | 6 | | | |
| 7 | RCPT RM 174 | 7 | 3 | 30 | | 8646 | 2882 | 0 | 0 | 900 | 20 | 1 | 8 | RCPT RM 173 GFCI | 8 | |
| 9 | | 9 | | | | 0 | 0 | 0 | 0 | 900 | 20 | 1 | 10 | RCPT RM 172 | 10 | |
| 11 | | 11 | | | | 0 | 0 | 0 | 0 | 1080 | 20 | 1 | 12 | RCPT RM 175 | 12 | |
| 13 | RCPT RM 170 GFCI | 13 | 1 | 20 | | 900 | 900 | 0 | 0 | 720 | 20 | 1 | 14 | RCPT RM 174 | 14 | |
| 15 | RCPT RM 171 | 15 | 1 | 20 | | 900 | 0 | 900 | 0 | 1080 | 20 | 1 | 16 | RCPT RM 175 | 16 | |
| 17 | RCPT RM 174,175 GFCI | 17 | 1 | 20 | | 360 | 0 | 0 | 0 | 900 | 20 | 1 | 18 | RCPT RM 175 | 18 | |
| 19 | RCPT RM 175 | 19 | 1 | 20 | | 900 | 0 | 0 | 0 | 8646 | 30 | 3 | 20 | RCPT RM 167 | 20 | |
| 21 | SPARE | 21 | 1 | 20 | | 0 | 0 | 0 | 0 | 0 | | 1 | 22 | | | |
| 23 | RCPT RM 174 | 23 | 1 | 20 | | 900 | 0 | 0 | 0 | 900 | 20 | 1 | 24 | | | |
| 25 | RCPT RM 167 | 25 | 3 | 30 | | 8646 | 2882 | 0 | 0 | 0 | 20 | 1 | 26 | SPARE | 26 | |
| 27 | | 27 | | | | 0 | 0 | 0 | 0 | 0 | 20 | 1 | 28 | SPARE | 28 | |
| 29 | | 29 | | | | 0 | 0 | 0 | 0 | 0 | 20 | 1 | 30 | SPARE | 30 | |
| 31 | SPARE | 31 | 1 | 20 | | 0 | 0 | 0 | 0 | 0 | 30 | 3 | 32 | SPARE | 32 | |
| 33 | SPARE | 33 | 1 | 20 | | 0 | 0 | 0 | 0 | 0 | | 1 | 34 | | | |
| 35 | SPARE | 35 | 1 | 20 | | 0 | 0 | 0 | 0 | 0 | | 1 | 36 | | | |
| 37 | SPARE | 37 | 1 | 20 | | 0 | 0 | 0 | 0 | 0 | 20 | 1 | 38 | SPARE | 38 | |
| 39 | SPARE | 39 | 1 | 20 | | 0 | 0 | 0 | 0 | 0 | 20 | 1 | 40 | SPARE | 40 | |
| 41 | SPARE | 41 | 1 | 20 | | 0 | 0 | 0 | 0 | 0 | 20 | 1 | 42 | SPARE | 42 | |
| TOTAL | | | | | | | 17830 | 17290 | 17650 | | | | | | | |
| TOTAL CONNECTED LOAD (VA) | | | | | | | 52770 | | | | | | | | | |
| TOTAL CONNECTED LOAD (AMPS) | | | | | | | | | | | | | | | | |

| PANEL 168RP.1 | | LOCATION ROOM 168 | | | | | | | | | | VOLTS 208Y/120V | | | | |
|-----------------------------|------------------|-------------------|--------|-----------|-----|-----------|-----------------|-------|-------|-----------|-----|-----------------|-------|--------------------------------|-------------|-----|
| FED FROM | CKT # | MOUNTING Recessed | | | | | | | | | | MAIN | | | | |
| | | PHASE 3 | WIRE 4 | FEEDER | | BUS 225 | | | | | | | | | | |
| CKT | LOAD SERVED | SLOT | POLES | WIRE SIZE | BKR | VOLT AMPS | PHASE LOAD (VA) | | | VOLT AMPS | BKR | WIRE SIZE | POLES | SLOT | LOAD SERVED | CKT |
| | | | | | | | A | B | C | | | | | | | |
| 1 | RCPT RM 169 | 1 | 3 | 30 | | 8646 | 2882 | 2882 | 2882 | 8646 | 30 | 3 | 2 | RCPT RM 169 | 2 | |
| 3 | | 3 | | | | 0 | 0 | 0 | 0 | 0 | | 1 | 4 | | | |
| 5 | | 5 | | | | 0 | 0 | 0 | 0 | 0 | | 1 | 6 | | | |
| 7 | RCPT RM 169 | 7 | 3 | 20 | | 4992 | 1664 | 1701 | 0 | 5104 | 20 | 3 | 8 | RCPT RM 169 | 8 | |
| 9 | | 9 | | | | 0 | 0 | 0 | 0 | 0 | | 1 | 10 | | | |
| 11 | | 11 | | | | 0 | 0 | 0 | 0 | 1664 | | 1 | 12 | | | |
| 13 | RCPT RM 166 | 13 | 1 | 20 | | 360 | 360 | 0 | 0 | 540 | 20 | 1 | 14 | RCPT RM 166 | 14 | |
| 15 | RCPT RM 169 GFCI | 15 | 1 | 20 | | 720 | 0 | 720 | 0 | 360 | 20 | 1 | 16 | RCPT RM 168 GFCI | 16 | |
| 17 | RCPT RM 167 GFCI | 17 | 1 | 20 | | 540 | 0 | 0 | 0 | 180 | 20 | 1 | 18 | RCPT RM 166 | 18 | |
| 19 | RCPT RM 166 | 19 | 1 | 20 | | 180 | 180 | 0 | 0 | 720 | 20 | 1 | 20 | RCPT RM 167 | 20 | |
| 21 | RCPT RM 169 GFCI | 21 | 1 | 20 | | 720 | 0 | 720 | 0 | 720 | 20 | 1 | 22 | RCPT RM 167 | 22 | |
| 23 | RCPT RM 167 | 23 | 1 | 20 | | 540 | 0 | 0 | 0 | 305 | 20 | 1 | 24 | LTG,STAIR 176,ROOF WALK/PLATF. | 24 | |
| 25 | RCPT RM 166 | 25 | 1 | 20 | | 180 | 180 | 0 | 0 | 720 | 20 | 1 | 26 | RCPT ROOF PLATFORM | 26 | |
| 27 | SPARE | 27 | 1 | 20 | | 0 | 0 | 0 | 0 | 180 | 15 | 1 | 28 | RCPT RM 166 | 28 | |
| 29 | SPARE | 29 | 1 | 20 | | 0 | 0 | 0 | 0 | 180 | 15 | 1 | 30 | RCPT RM 166 | 30 | |
| 31 | SPARE | 31 | 3 | 30 | | 0 | 0 | 0 | 0 | 0 | 20 | 3 | 32 | SPARE | 32 | |
| 33 | | 33 | | | | 0 | 0 | 0 | 0 | 0 | | 1 | 34 | | | |
| 35 | | 35 | | | | 0 | 0 | 0 | 0 | 0 | | 1 | 36 | | | |
| 37 | SPARE | 37 | 1 | 20 | | 0 | 0 | 0 | 0 | 0 | 20 | 1 | 38 | SPARE | 38 | |
| 39 | SPARE | 39 | 1 | 20 | | 0 | 0 | 0 | 0 | 0 | 20 | 1 | 40 | SPARE | 40 | |
| 41 | SPARE | 41 | 1 | 20 | | 0 | 0 | 0 | 0 | 0 | 20 | 1 | 42 | SPARE | 42 | |
| TOTAL | | | | | | | 11829 | 11829 | 10874 | | | | | | | |
| TOTAL CONNECTED LOAD (VA) | | | | | | | 34532 | | | | | | | | | |
| TOTAL CONNECTED LOAD (AMPS) | | | | | | | | | | | | | | | | |

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

LIGO-D961017-01-0

| | | | | | |
|-------------------------|----------|----------|------|------|------|
| ISSUED FOR CONSTRUCTION | DATE | BY | CHKD | ENGR | PROJ |
| DRAWN | M. M. | 11-15-96 | | | |
| CHECKED | J. C. L. | 7-24-96 | | | |
| ENGINEER | K. C. R. | 10-25-96 | | | |
| PROJ | T. D. M. | 11-15-96 | | | |

STATE OF LOUISIANA
 PROFESSIONAL ENGINEER
 K. C. R.
 No. 4477
 Exp. 11/2/98

