

not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will

PANEL 163RP.1		LOCATION ROOM 163						VOLTS 208Y/120V								
FED FROM		MOUNTING Recessed		MAIN				BUS 225								
		PHASE 3		WIRE 4		FEEDER										
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	BKR	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	BKR	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	RCPT RM 165	1	3		30	8646	2982	720	0	720	20		1	2	RCPT RM 162	2
		3					0	2882	720	720	20		1	4	RCPT RM 162	4
		5					0	0	2882	540	20		1	6	RCPT RM 165	6
7	RCPT RM 162	7	1		20	540	540	360	0	360	20		1	8	RCPT RM 165	8
9	RCPT RM 165	9	1		20	360	0	360	0	360	20		1	10	RCPT RM 161	10
11	RCPT RM 163	11	1		20	360	0	0	360	360	20		1	12	RCPT RM 163	12
13	RCPT RM 162	13	1		20	540	540	0	0	540	20		1	14	RCPT RM 161	14
15	RCPT RM 165	15	1		20	540	540	0	0	360	20		1	16	RCPT RM 163	16
17	CORR 177,178 & 179	17	1		20	900	0	0	0	900	20		1	18	SPARE	18
19	LTG RM 162	19	1		20	540	540	0	0	300	20		1	20	FACP RM 161	20
21	RCPT RM 163	21	1		20	360	0	360	0	500	20		1	22	EXHAUST RM 137	22
23	SPARE	23	1		20		0	0	3750	7500	50		2	24	L-CS-139-SV-03	24
25	MICROWAVE RM 145	25	1		20	1350	1350	0	0		20			26		26
27	JB REMOTE FIRE PNL	27	1		20	1920	0	1920	0	4000	30		2	28	L-CS-140-SV-05	28
29	J BOX RM 121	29	1		20		0	0	2000					30		30
31	COOK TOP RM 145	31	3		30	7300	2433	2000	0	4000	30		2	32	L-CS-141-SV-07	32
		33					0	2433	2000					34		34
		35					0	0	2433	4000	30		2	36	L-CS-142-SV-09	36
37	RCPT RM 160	37	1		20	720	720	0	0					38		38
39	L-CS-160-SV-18	39	2		30	4000	0	2000	2000	4000	30		2	40	L-CS-143-SV-10	40
		41					0	0	2000					42		42
TOTAL							19035	18975	19225							
TOTAL CONNECTED LOAD (VA)							57235									
(AMPS)																

PANEL 163RP.2		LOCATION ROOM 163						VOLTS 208Y/120V								
FED FROM		MOUNTING Recessed		MAIN				BUS 225								
		PHASE 3		WIRE 4		FEEDER										
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	BKR	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	BKR	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	DUAL DUPLEX RCPT RM 162	1	1		20	1920	1920	0	0	1920	20		1	2	DUAL DUPLEX RCPT RM 165	2
3	DUAL DUPLEX RCPT RM 162	3	1		20	1920	0	1920	0	1920	20		1	4	DUAL DUPLEX RCPT RM 165	4
5	DUAL DUPLEX RCPT RM 162	5	1		20	1920	0	0	1920	1920	20		1	6	DUAL DUPLEX RCPT RM 165	6
7	DUAL DUPLEX RCPT RM 162	7	1		20	1920	1920	0	0	1920	20		1	8	DUAL DUPLEX RCPT RM 165	8
9	DUAL DUPLEX RCPT RM 162	9	1		20	1920	0	1920	0	1920	20		1	10	DUAL DUPLEX RCPT RM 165	10
11	DUAL DUPLEX RCPT RM 162	11	1		20	1920	0	0	1920	1920	20		1	12	DUAL DUPLEX RCPT RM 165	12
13	DUAL DUPLEX RCPT RM 162	13	1		20	1920	1920	0	0	1920	20		1	14	DUAL DUPLEX RCPT RM 161	14
15	DUAL DUPLEX RCPT RM 162	15	1		20	1920	0	1920	0	1920	20		1	16	DUAL DUPLEX RCPT RM 161	16
17	DUAL DUPLEX RCPT RM 162	17	1		20	1920	0	0	1920	1920	20		1	18	DUAL DUPLEX RCPT RM 161	18
19	DUAL DUPLEX RCPT RM 161	19	1		20	1920	1920	0	0	1920	20		1	20	DUAL DUPLEX RCPT RM 161	20
21	DUAL DUPLEX RCPT RM 161	21	1		20	1920	0	1920	0					22	SPARE	22
23	DUAL DUPLEX RCPT RM 163	23	1		20	1920	0	0	1920					24	SPARE	24
25	SPARE	25	1		20		0	0	0					26	SPARE	26
27	SPARE	27	1		20		0	0	0					28	SPARE	28
29	SPARE	29	1		20		0	0	0					30	SPARE	30
31	SPARE	31	1		20		0	0	0					32	SPARE	32
33	SPARE	33	1		20		0	0	0					34	SPARE	34
35	SPARE	35	1		20		0	0	0					36	SPARE	36
37	SPARE	37	1		20		0	0	0					38	SPARE	38
39	SPARE	39	1		20		0	0	0					40	SPARE	40
41	SPARE	41	1		20		0	0	0					42	SPARE	42
TOTAL							15360	13440	13440							
TOTAL CONNECTED LOAD (VA)							42240									
(AMPS)																

PANEL 172PP.1		LOCATION ROOM 172						VOLTS 480Y/277V								
FED FROM		MOUNTING Recessed		MAIN				BUS 225								
		PHASE 3		WIRE 4		FEEDER										
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	BKR	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	BKR	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	JB RM 167	1	3		60	39905	13302	13302	0	39905	60		3	2	JB ROOM 167	2
		3					0	13302	13302					4		4
		5					0	0	13302					6		6
7	RM 166	7	3		60	39905	13302	277	0	831	15		3	8	DOOR MOTOR 170	8
		9					0	13302	277					10		10
		11					0	13302	277					12		12
13	DOOR MOTOR 173	13	3		15	1496	499	277	0	831	15		3	14	DOOR MOTOR 170	14
		15					0	499	277					16		16
		17					0	0	499	15				18		18
19	J BOX RM 174	19	3		60	39905	13302	0	0		15		3	20	SPARE	20
		21					0	13302	0					22		22
		23					0	0	13302					24		24
25	JB RM 167	25	3		60	39905	13302	13302	0	39905	60		3	26	JB FUME HOOD 169	26
		27					0	13302	13302					28		28
		29					0	13302	13302					30		30
31	JB BAKE OVEN 169	31	3		60	39905	13302	0	0		20		3	32	SPARE	32
		33					0	13302	0					34		34
		35					0	0	13302					36		36
37	SPARE	37	3		60		0	0	0		30		3	38	SPARE	38
		39					0	0	0					40		40
		41					0	0	0					42		42
TOTAL							94164	94164	94164							
TOTAL CONNECTED LOAD (VA)							282492									
(AMPS)																

PANEL 144RP.1		LOCATION ROOM 144						VOLTS 208Y/120V								
FED FROM		MOUNTING Recessed		MAIN				BUS 225								
		PHASE 3		WIRE 4		FEEDER										
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	BKR	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	BKR	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	RCPT XEROX RM 144	1	3		30	960	960	1200	0	1200	20		1	2	RCPT RMS 121,122,147 & 148	2
		3					0	960	960	960	20		1	4	RCPT RMS 122,146,147 & 149	4
		5					0	0	960	720	20		1	6	RCPT RMS 122,123,146 & 147	6
7	DISHWASHER RM 145	7	1		20	1000	1000	0	0	720	20		1	8	REFRIGERATOR RM 145	8
9	RECEPTACLE RM 147	9	1		20	240	0	240	0	1080	20		1	10	RECEPTACLE RMS 123 TO 129	10
11	RCPT RMS 125,139,144,150	11	1		20	720	0	0	720	120	20		1	12	RECEPTACLE RM 144	12
13	SPACE	13	1		20		0	0	0	1200	20		1	14	RCPT RMS 125,141,142,143,144 & 145	14
15	RECEPTACLE GFI	15	1		20	840	0	840	0	480	20		1	16	RECEPTACLE RMS 132 TO 135	16
17	RECEPTACLE EWC	17	1		20	1000	0	0	1000	840	20		1	18	RECEPTACLE RMS 128,130,136,138,151	18
19	RECEPT RMS 130,131,137,138,140	19	1		20	960	960	0	0	600	20		1	20	RECEPTACLE RMS 123 TO 129	20
21	RECEPT RMS 123,124,126 TO 129	21	1		20	720	0	720	0	600	20		1	22	RCPT RMS 140,141,142 & 145	22
23	DISPOSAL RM 145	23	1		20											