

"A" ARM END STATION

Panel EA DP.02, LOCATION ROOM 203, VOLTAGE 480Y/277V. Table with columns: CKT, LOAD SERVED, SLOT, POLES, WIRE SIZE, BKR, VOLT AMPS, PHASE LOAD (VA) (A, B, C), VOLT AMPS, BKR, WIRE SIZE, POLES, SLOT, LOAD SERVED, CKT. Includes total connected load: 67255 VA (80.9 AMPS).

Panel VEAC.01B, LOCATION ROOM 203, VOLTAGE 480Y/277V. Table with columns: CKT, LOAD SERVED, SLOT, POLES, WIRE SIZE, BKR, VOLT AMPS, PHASE LOAD (VA) (A, B, C), VOLT AMPS, BKR, WIRE SIZE, POLES, SLOT, LOAD SERVED, CKT. Includes total connected load: 51001 VA (61.5 AMPS).

NOTE: 1. PANELS DP.01, DP.02, VEAC.01B AND VEAC.02B ARE TYPICAL FOR END STATIONS A AND B.

"A" ARM END STATION

Panel EA RP.01, LOCATION ROOM 203, VOLTAGE 208Y/120V. Table with columns: CKT, LOAD SERVED, SLOT, POLES, WIRE SIZE, BKR, VOLT AMPS, PHASE LOAD (VA) (A, B, C), VOLT AMPS, BKR, WIRE SIZE, POLES, SLOT, LOAD SERVED, CKT. Includes total connected load: 8140 VA (22.1 AMPS).

"B" ARM END STATION

Panel EB DP.02, LOCATION ROOM 203, VOLTAGE 480Y/277V. Table with columns: CKT, LOAD SERVED, SLOT, POLES, WIRE SIZE, BKR, VOLT AMPS, PHASE LOAD (VA) (A, B, C), VOLT AMPS, BKR, WIRE SIZE, POLES, SLOT, LOAD SERVED, CKT. Includes total connected load: 67255 VA (80.9 AMPS).

"B" ARM END STATION

Panel EB RP.01, LOCATION ROOM 203, VOLTAGE 208Y/120V. Table with columns: CKT, LOAD SERVED, SLOT, POLES, WIRE SIZE, BKR, VOLT AMPS, PHASE LOAD (VA) (A, B, C), VOLT AMPS, BKR, WIRE SIZE, POLES, SLOT, LOAD SERVED, CKT. Includes total connected load: 8140 VA (22.1 AMPS).

not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

Table with columns: NO., DATE, BY, CHKD, ENGR, PROJ, DESCRIPTION. Includes revision history and drawing information.

ISSUED FOR CONSTRUCTION
DRAWN M. M. 11-15-96
CHECKED J. C. L. 7-24-96
ENGINEER K. C. R. 10-25-96
PROJ T. D. M. 11-15-96
AS-BUILT DRAWINGS

PARSONS
100 WEST WALNUT STREET
PASADENA, CALIFORNIA

LIGO
CALIFORNIA INSTITUTE OF TECHNOLOGY
MASSACHUSETTS INSTITUTE OF TECHNOLOGY

LIGO-D961029-03-0
LASER INTERFEROMETER
GRAVITATIONAL-WAVE OBSERVATORY
SITE NO.2 - LIVINGSTON, LOUISIANA
ELECTRICAL END A AND B STATIONS PANEL SCHEDULES