

PANEL 175RP_1		LOCATION RM 175		VOLTS 208Y/120V												
FED FROM	CKT #	MOUNTING RECESSED	MAIN													
		PHASE 3	WIRE 4	FEEDER	BUS 100											
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	TRIP	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	TRIP	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	MISC RM 175	1	3			7203	2401			1920			1	2	MISC RM 175	2
3		3					1920			1920			1	4	MISC RM 175	4
5		5					2401			1920			1	6	MISC RM 175	6
7	MISC RM 175	7	3			7203	2401			1920			1	8	MISC RM 175	8
9		9					1920			1920			1	10	MISC RM 175	10
11		11					2401			1920			1	12	MISC RM 175	12
13	MISC RM 175	13	1			1920	1920							14	SPACE	14
15	MISC RM 175	15	1			1920		1920						16	SPACE	16
17	MISC RM 175	17	1			1920			1920					18	SPACE	18
19	SPACE	19												20	SPACE	20
21	SPACE	21												22	SPACE	22
23	SPACE	23												24	SPACE	24
25	SPACE	25												26	SPACE	26
27	SPACE	27												28	SPACE	28
29	SPACE	29												30	SPACE	30
TOTAL							8161	8161	8161							
TOTAL CONNECTED LOAD (VA)							24483									
(AMPS)							67.95									


PANEL 175RP_2		LOCATION RM 175		VOLTS 208Y/120V												
FED FROM	CKT #	MOUNTING RECESSED	MAIN													
		PHASE 3	WIRE 4	FEEDER	BUS 100											
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	TRIP	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	TRIP	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	MISC RM 175	1	3			7203	2401			1920			1	2	MISC RM 175	2
3		3					1920			1920			1	4	MISC RM 175	4
5		5					2401			1920			1	6	MISC RM 175	6
7	MISC RM 175	7	3			7203	2401			1920			1	8	MISC RM 175	8
9		9					1920			1920			1	10	MISC RM 175	10
11		11					2401			1920			1	12	MISC RM 175	12
13	MISC RM 175	13	1			1920	1920							14	SPACE	14
15	MISC RM 175	15	1			1920		1920						16	SPACE	16
17	MISC RM 175	17	1			1920			1920					18	SPACE	18
19	SPACE	19												20	SPACE	20
21	SPACE	21												22	SPACE	22
23	SPACE	23												24	SPACE	24
25	SPACE	25												26	SPACE	26
27	SPACE	27												28	SPACE	28
29	SPACE	29												30	SPACE	30
TOTAL							8161	8161	8161							
TOTAL CONNECTED LOAD (VA)							24483									
(AMPS)							67.95									

not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will

NO.	DATE	BY	CHKD	ENGR	PROJ	DESCRIPTION

ISSUED FOR CONSTRUCTION
 DRAWN M.M. 6-25-96
 CHECKED [Signature] 7-3-96
 ENGINEER [Signature] 7-3-96
 PROJ [Signature] 7-3-96



PARSONS
 100 WEST WALNUT STREET
 PASADENA, CALIFORNIA

LIGO
 CALIFORNIA INSTITUTE OF TECHNOLOGY
 MASSACHUSETTS INSTITUTE OF TECHNOLOGY

LASER INTERFEROMETER
 GRAVITATIONAL-WAVE OBSERVATORY
 SITE NO. 1 - HANFORD, WASHINGTON
 ELECTRICAL CORNER STATION
 OSB
 PANEL SCHEDULES
 NONE PPI50969 8094
WA-E-122