

# *Preliminary Design Report*

## *Presentation*

November 9, 1995

**LIGO**  
**Laser Interferometer Gravitational-Wave Observatory**  
**California Institute of Technology**  
**The Ralph M. Parsons Company**  
**Contract Number: PP150969**


**LIGO Document** C951726-00-

**CDRL Number** **22**

**DRD Number** **09**



Laser Interferometer Gravitational-Wave Observatory



# *Preliminary Design Report*

## *Presentation*

November 9, 1995

**LIGO**  
**Laser Interferometer Gravitational-Wave Observatory**  
**California Institute of Technology**  
**The Ralph M. Parsons Company**  
**Contract Number: PP150969**


**LIGO Document** \_\_\_\_\_

**CDRL Number**           **22**

**DRD Number**           **09**

**Parsons-LIGO**

Laser Interferometer Gravitational-Wave Observatory




---

# LIGO Facilities

## Mel Weingart


### Preliminary Design Review Presentation



# Purpose and Objective

---


- Purpose -- Present LIGO Design Team's evaluation of the project and the 30% design that has developed to meet project requirements.
- Objective -- Reach a consensus baseline facility design that will develop into the final design and construction bid packages.



# Design Timeline

---

- Project Start: January, 1995
- 30% Concept Review: February, 1995
  - Presented 6 Interferometer Arrangements
- 60% Concept Review: March, 1995




# Parsons Timeline (Continued)

---

- 90% Concept Review: April, 1995
  - Presented Construction Cost Estimate
  - Estimate for 6 Interferometers Exceeded Budget Constraint
- Project Directed Trade Studies: May, 1995
  - Design Team Directed to Proceed with Final Concept (3 Interferometers)






# Parsons Timeline (Continued)

---


---

- Descoping Exercise, July, 1995
- Preliminary Design Review: Nov. 9, 1995
- Authorization to proceed: Nov. 15, 1995




# Agenda

Topic	Presenter	Time
Introduction	M. Weingart	9:00 am - 9:10 am
Requirements	J. Hermann	9:10 am - 9:25 am
Design		
- Overview	T. Melott	9:25 am - 10:00 am
- 3D Model	R. Carbone	
- Civil	J. Blasius	10:00 am - 10:25 am
- Architecture	S. Ford	10:25 am - 10:50 am
Break		10:50 am - 11:00am



# Agenda (con't)

Structural	F. Dickens	10:45 am - 11:15 am
Material Handling	T. Melott	11:15am - 11:30 am
Mechanical	A. Atia	11:30 am - 12:00 am
Lunch		12:00pm -12:30 pm
Electrical	K. Ramsing	12:30 am -1:00 pm
Technology Studies		
- Acoustics	M. Long	1:00 pm - 1:20 pm
- Vibrations	P. MacCalden	1:20 pm - 2:00 pm



# Agenda (con't)

---


---

Construction Cost Estimate      W. Messzik    2:00 pm - 2:30 pm

- Basis of Estimate
- Hanford Summary
- Livingston Summary

Review Committee Mtg.      M Coles            2:30 pm - Closing






# Technical Presentation Format

---

---

- Each technical discipline will present the following information:
  - Requirements
  - Proposed Approach
  - Outstanding Issues and Resolutions




# Design Review Approach

---

- Each discipline will make a presentation
- Questions will be entertained at any time during the presentation
- For any comments or issue arises that need dispensation, fill out a comment form and pass it to the Review Board Secretary






# Design Review Approach (Continued)


---

- At the conclusion of the presentations, the comment forms will be screened.
- Comments which require resolution will be read, and individuals responsible for action identified.
- All resolutions will be agreed to by the commentor and the respondent.



# Design Requirements

Jeff Hermann




# Major DCCD Updates

---

---


- Two Interferometers
- Revised Vibration Control Criteria
  - Less Than 4 Times the LIGO Standard PSD
  - Peak Amplitudes Defined
- Removed Cleanrooms
- Change in Lasers: Argon-Ion to Nd:YAG






# Major TDMs Received

## ► Relocation of Chiller Plants






# Preliminary ICD Information -- Received

---

- Preliminary Information on LVEA Layout
- Telephone Requirements
- Preliminary Clean Work Benches
- BTE/Facility Interfacing Dimensions
- Plumbing in LVEA and VEAs
- Layout of LVEA Power Distribution






# Preliminary ICD Information -- Received (Continued)

---

---

- Cooling Water Systems for the LVEA
- Fume Hood in the Optics Lab




# Preliminary ICD Information -- Upcoming

---

---

- OSB Room Layouts
- Grounding and Shielding Requirements in LVEA/VEAs
- Cryogenic Piping and Storage Dewars




---

# Design Overview

## 3D CAD Model

Tim Melott and  
Randy Carbone




# Design Considerations

---

---

- Meeting the Technical and Operational Criteria
- Design to Cost
- Expandability




## Major Design Features -- General

---

- Hanford Facility will Accommodate One Full Length and One Half Length Interferometer Housed within a Corner Station with Mid and End Stations Along Each Arm
- Livingston Facility will Accommodate Two Full Length Interferometers Housed within a Corner Station and End Stations Along Each Arm






# Major Design Features -- LVEA/VEAs

---

---

- Houses the Lasers and Vacuum Equipment
- 68-inch Technical Foundation Separated from the Superstructure Foundation with a 2-Inch Air Gap
- Finishes Consistent with Cleanrooms
- HEPA Filtered Air Supply
- Mechanical Room adjacent to the LVEA
- 5-Ton Crane System






## Major Design Features -- OSB

---


- Houses Control/Computer Rooms, Labs, Shipping/Receiving/Inspection, Change Room, Cleaning Area, Offices, Kitchen, Restrooms, and Visitor Support Functions
- Has a Multi-Use Space for Visitor Displays and for Conferences with up to 50 People



# Major Design Features -- Maintenance Building Area

- Support Services Set 300 Feet from the Corner Station
- Maintenance Building Housing Support Shop Functions, Fire Pumps, and Electrical Systems for the Chillers
- Chiller Yard
- Fire Water Storage Tank
- Potable Water System






## Major Design Features -- Mid and End Stations

---

---

- In addition to a VEA, the Station Houses a Mechanical Room, Shipping/Receiving/Inspection Areas, Change Room, Air Lock, Lab Space, and Restroom Facility




# Items not Included in PDR Design Package

---


- Chiller Plant Relocation at Mid/End Stations
- Grading around Mid/End Stations
- Site Power Distribution
- OSB Detailed Arrangement
- Power Interfaces in the LVEA






# Civil Review

John Blasius



# Civil Site Work


- Grading
- Drainage
- Roads / Paving
- Parking
- Access
- Layout Features
- Landscaping
- Solid Waste
- Potable Water
- Firewater Distribution
- Chilled Water Alignment
- Sewage System
- Irrigation



# Sitework Requirements

---

- Minimize settlement
- Laser level site along beam arms
- 200 foot traffic exclusion
- 300 foot vibration exclusion
- Interferometer alignment/mount
- Bridge to “backside” for fire protection
- Minimize cost, stay functional




# Corner Station - Hanford Approach

---

---

- Civil Sitework Description
- Grading/Drainage (Rough & Final)
  - Overexcavation & Compaction
- Exclusion Zones
- Roads / Parking / Paving
- Bridge Over Beam Tube
- Utilities






# Mid and End Stations - Hanford Approach

---

- Civil Sitework Description
- At Lower Grade Than Beam Tube
- Chiller Move to 300 Feet Away
- Access to Nitrogen Tank(s)
- Utilities
  - Potable Water
  - Sewage
  - Chilled Water Alignment






# Livingston Sitework Approach


---

- Generally the same look as Hanford
- Rough Grading & Drainage
  - 500 Year Flood / Freeboard
  - Proper Compaction to Minimize Settlement
  - Minimize Fill
  - Laser Level Site
  - Property Boundaries
- Sewage Treatment



# LIGO Architecture

Sandra L. Ford




# LVEA -- Requirements

---

- Design to Cost Goal
- Interior Clean Environment
- Minimum Disturbance from Acoustical Noise, Ground Vibrations, and Electromagnetic Interference
- Low Risk, Ease of Maintenance, and Operability
- Building Code Requirements






# LVEA -- Proposed Approach

---

- Architectural Philosophy
- Exterior Building Facade
- Roof System
- Interior Clean Environment Materials and Finishes
- Building Code Interpretation
- Expediency of Construction




# OSB -- Requirements

---

---


- Design to Cost Goal
- Low Risk, Ease of Maintenance, and Operability
- Quality Environment for Personnel
- Facility Monitoring and Control
- Accessibility to the Disabled
- Building Code Requirements



# OSB -- Proposed Approach

---

- Architectural Philosophy
- Exterior Building Facade
- Roof System
- Entry Facade
- Multi-Use Visitors Center
- Comfortable & Quality Work Environment
- Building Code Interpretation
- Expediency of Construction




# Mid and End Stations -- Requirements

---

- Design to Cost Goal
- Interior Clean Environment
- Minimum Disturbance from Acoustical Noise, Ground Vibrations, and Electromagnetic Interference
- Low Risk and, Ease of Maintenance and Operability
- Building Code Requirements






# Mid and End Stations -- Proposed Approach

---


- Architectural Philosophy
- Exterior Building Facade
- Interior Clean Environment Materials & Finishes
- Building Code Interpretation
- Expediency of Construction



# Issues and Resolutions

---

- LVEA
  - Detailed Information for the Final Design
- OSB
  - Detailed Information for Final Design
  - Functional Requirements for Office Floor Plan
  - Computer Locations
  - Facility Control Room Requirements
  - Computer Users Requirements




# Issues and Resolutions

---

---

- Mid and End Stations
  - Detailed Information for Final Design
  - Computer Locations
  - Work Stations






---

# Structural Review

## Freddy Dickens




# Corner, Mid and End Stations -- Design Requirements

---

---

- Structural Design Meets UBC/SBC
- Isolate Building Foundation From LVEA and VEA Foundations
- 5-Ton Under-Hung Cranes






# Corner, Mid and End Stations -- Proposed Design Approach

---

- Metal Decking Welded to Roof Beams
- Horizontal Roof Bracing Transfers Lateral Loads to Vertical Bracing
- Vertical Wall Bracing Transfers Lateral Load to Foundations
- Isolated and Combined Footings for Superstructure






# Corner, Mid and End Stations -- Proposed Design Approach

---


---

- Standard Framed Connections
- OSB Main Entrance and Multi-Use Area
- Roof is Made of Open Web Steel Joists




# Issues/Resolutions

- LVEA and VEA Air Gap Location Between Technical and Superstructure Foundations
- LVEA and VEA Technical Foundation Thickness



# Material Handling Review


Tim Melott



# Requirements

- 5 Ton Capacity System (Large Item)
- 26 Foot 6 Inch Hook Height for Cranes
- Allow Crane Coverage over LVEA and VEA Areas
- Semi-Clean System
- Variable Speed Drive
- Small Item Handling System (1 Metric Ton)






# Proposed Approach

---

---

- Multi-Bridge System with Laydown Areas Required in the LVEA and VEAs
- Monorail Crane within the Large Item Access Airlock
- Ground Transfer System (by Others) for transfer between the LVEA and the Large Item Access Airlock and for Small Items to and from the OSB






# Proposed Approach


---

- Possible future addition of up to a 5-ton monorail system within the Shipping/Receiving/Inspection and Cleaning Areas of the OSB and Mid/End Stations



# Mechanical Systems Review

Atia Y. Atia, P.E.




# HVAC Systems -- Requirements

---

- Energy Efficient Systems and Equipment
- Stable Space Temperature (72 +/- 3.5 °F)
- Facility Monitoring and Control
- Humidity Control
- Meet UMC and State Energy Code for Washington Site
- Meet Standard Mechanical Code for Louisiana Site






# HVAC Systems -- Requirements

---

---


- Vibration Mitigation to LVEA and VEA
- Noise Mitigation to LVEA and VEA
- High System Reliability (24 Hr. Operation)
- Low Capital Cost
- Clean Environment





# Outdoor and Indoor Conditions


Condition	Washington	Louisiana
Outdoor DB (Summer)	99 F	95 F
Outdoor WB (Summer)	68 F	77 F
Outdoor DB (Winter)	5 F	25 F
Indoor DB	72 +/- 3.5 F	72 +/- 3.5 F
Indoor RH	30% Min. 70% Max.	30% Min. 70% Max.



# Vibration Mitigation -- Proposed Approaches

---

- Eliminate Return Fans
- Vane Axial Fans
- Rotating Equipment, No Reciprocating
- High Deflection Spring Vibration Isolators
- Locate Chillers & Pumps 300' from Bldgs.
- All Rotating Equipment will Run at 20 Hz  
or Higher
- Synchronizing Fans at Corner Station




# Noise Mitigation -- Proposed Approach

---

- Double Wall Perforated Ducts for LVEA and VEA
- Low Air Duct Velocity
- Sound Attenuators on Supply and Return Air
- Vibration Isolators On Ducts and Pipes






# System Reliability Proposed Approaches

---


---

- Standby Chillers and Pumps for All Buildings
- Standby Fans for Mid and End Stations
- Multiple Fans for LVEA
- Multiple Fans for OSB (Technical Area)



# System Reliability Proposed Approaches (Cont'd)


- Industrial Grade Equipment
- Continuous Monitoring
- Scheduled Preventive Maintenance
- Eliminate Return Air Fans



# Stable Space Temperature -- Proposed Approaches

---

- Return Plenum In Walls and Ceilings
- Individually Controlled Thermal Zones
- Thermal Insulation On Walls and Roofs
- Isolated Foundation Perimeter




# Humidity Control -- Proposed Approach

---

- Washington
  - Dehumidifying by Chilled Water Coil
  - Steam Humidifiers (Electric), On Site Potable Water for Corner Station Facilities
  - Steam Humidifiers (Electric), Off-Site Reverse Osmosis Water for Mid and End Stations






# Humidity Control -- Proposed Approach

---

- Louisiana
  - Dehumidifying by Chilled Water Coil
  - Steam Humidifiers (Electric), On-Site Potable Water for Corner Station Facilities
  - Steam Humidifiers (Electric), Off Site Reverse Osmosis Water for End Stations
  - 25% Min. Air Flow Through Cooling Coil For Humidity Control During Moderate Ambient




# Air Handling System -- Proposed Approaches

---

---

- Concrete AHUs Enclosure for LVEA, OSB,  
Mid and End Stations
- Vane Axial Fans (Two Stage)
- Supply Fans Only (No Return Air Fans)
- Direct Drive Fans
- Ducted Supply and Plenum Return




# Clean Environment -- Proposed Approaches

---

---

- HEPA Filters at Supply Air Outlets for LVEA, OSB, Mid and End Stations
- 90% Efficiency In AHUs
- Return Air Registers Located Near Floor
- Air Locks
- Pressurized Building






# HVAC System Application -- Proposed Approaches

- Constant Volume, (Face and Bypass) for LVEA with Duct Heaters
- Constant Volume, (Face and Bypass) for Mid and End Station with Duct Heaters
- Constant Volume, (Double Duct) for OSB
- VAV with Terminal Heating for Offices
- Electric Heating






# Energy Conservation -- Proposed Approaches

---

- Energy Efficient HVAC Systems (CVVT) for LVEA, MID and End Stations
- Minimizing Outside Air
- No Reheat Except For Humidity Control
- High Efficiency Motors and Chillers
- Insulated Ducts and Pipes
- Insulated Walls and Roof
- Air Tight Construction




# Facility Monitoring & Control -- Proposed Approaches

---

---

- Direct Digital Controls (DDC) for Controls, Monitoring, Diagnostics, and Scheduled Maintenance
- DDC for Security Systems, Fire Alarm, and Enunciation
- Pneumatic Drives for High Reliability




## Issues

---

---

- Expensive DDC Control and Monitoring
  - \$600,000 for DDC Control and Monitoring
  - \$400,000 for DDC Control Only
  - \$300,000 for Pneumatic Control Only




# Water Supply and Sewage -- Requirements

---

---

- No Potable Water at Mid and End Stations
- No Sewage Drain at Mid and End Stations
- Meet Uniform Plumbing Code for Washington Site
- Meet Standard Plumbing Code for Louisiana Site






# Water Supply and Sewage -- Proposed Approaches

---

- Potable Water Supply for Corner Station
- Waste Drainage System for Corner Station
- Pressurized Storage Water Tanks for Mid and End Stations
- Holding Tanks at Mid & End Stations
- Point of Use Electric Water Heaters






# Fire Protection -- Requirements

---

---


- Meet Uniform Fire Code and NFPA Standards for Washington Site
- Meet Standard Fire Prevention Code and NFPA Standards for Louisiana Site



# Fire Protection -- Proposed Approaches


- No Sprinkler System
- On-Site Water Storage, Corner Station
- Two Electric Fire Pumps 1,000 GPM Each  
for Corner Station Fire-Hydrant Loop
- One 1,000-GPM Trailerable Propane-  
Powered Fire Pump Provided (by Others) to  
Local Fire Department






## Fire Protection -- Proposed Approaches (Cont'd)

- Fire Hose Cabinet for OSB
- Clean Agent (FM 2000) Gas for Critical  
Rooms of OSB
- Portable Fire Extinguishers for All Facilities



# Electrical Systems Overview


Kai Ramsing, P.E.



# Electrical Requirements


- Mitigate Vibration
- Electromagnetic Coupling, Noise and Grounding
- System Reliability
- Energy Conservation
- Site Vector Inputs





# Mitigate Vibration -- Proposed Approach

- Minimize Vibrating Equipment (i.e., Switchgear, Transformers, etc.) within Exclusion Zones
- Flexible Couplings between Superstructure and Technical Foundation
- Locate all High-Bay Ballasts in the Mechanical Equipment Room




# Mitigate Electromagnetic Coupling -- Proposed Approach

---

---

- Highest Possible Distribution Voltage
- Separate Grounding for Utility and Facility
- 4-Wire Wye Isolation
- Triplex Direct Burial Cable Geometry
- Distance Sources from Victim Systems
- Routing of Electrical Circuits
- Ferrous Conduit to Provide Shielding




# Electromagnetic Coupling, Noise and Grounding (Continued)

---

- Technical Power Isolation Transformers
- Tree Topology Grounding
- Single-Point Ground for Technical Systems
- Grounding Counterpoise for Buildings
- Equipotential Screen Under Computer Rooms (Signal Reference Grid)
- Delta-Wye Transformations to Mitigate Power Frequency Harmonic Conduction






# Electromagnetic Coupling, Noise and Grounding (Continued)

---


- Specify Low Harmonic Distortion Equip.
- Tuned Circuits at the Motor Terminal Boxes  
Control Voltage Spikes
- RFI Lenses on Fluorescent and Metal-Halide Fixtures
- Transient Voltage Surge Suppressors



# System Reliability -- Proposed Approach

- Single Utility Company Owns and Operates the Distribution System
- Medium Voltage, Simple Radial System Architecture
- Similar and Simplified Systems for Each Building
- Conventional Manufacturing and Limited Custom Components






# Energy Conservation -- Proposed Approach

---


---

- Energy Efficient Motors
- Energy Efficient Lighting
- Electronic Ballasts
- Occupancy Sensor Switches
- Phase-controlled Electric Heating
- Facilities Monitoring and Control System



# Site Vector Inputs -- Proposed Approach

- Current Sensors in Electrical Equipment
- CDS Collects Sensor Data
- CDS Processes and Interprets the Data
- CDS Real-Time Clock Synchronized




## Issues

---


---

- Facilities Monitoring and Control System
- Telecommunications
- Laser Equipment Power
- Beam Tube Lightning Protection
- Cost/Benefit of Variable-Speed State-Vector Controlled Motor-Drives



# Acoustics Review

Marshall Long




# LVEA/VEA Acoustics -- Requirements

## ► Sound Pressure Level

Frequency	SPL
$f > 63 \text{ Hz}$	PNC-50
$f = 63 \text{ Hz}$	66 dB
$f = 31.5 \text{ Hz}$	64 dB
$f = 16 \text{ Hz}$	61 dB
$f = 8 \text{ Hz}$	57 dB
$f = 4 \text{ Hz}$	55 dB






# LVEA/VEA Acoustics -- Considerations

---


---

- HVAC Systems
  - Duct-Borne Noise
  - Flow Velocities
  - Duct Rumble
- Exterior Noise
  - Exterior Source -- Trucks
  - Rain and Wind



# LVEA/VEA Acoustics -- Projected Results

- HVAC
- Reverberation Time
- Exterior to Interior




# LVEA/VEA Acoustics -- Proposed Approach

---

---

- HVAC
  - Vane Axial Fans -- High Frequency Noise Components
  - Synchronous Motors with Phase Control
  - Duct Silencers
  - Concrete Block Wall Enclosures to Reduce Well Vibrations



# LVEA/VEA Acoustics -- Proposed Approach (Cont'd)


---

---

- HVAC

- Round Duct to Reduce Tin-Canning and Increase Transmission Loss
- Double Walled Lined Duct
- Low Flow Velocities
- Vibration Isolation






# LVEA/VEA Acoustics -- Proposed Approach

- Interior Acoustics
  - Acoustical Tile on Ceiling NRC = 0.6
  - Additional Wall Panels
- Exterior to Interior Acoustics
  - Double Wall Construction with Absorption Between
  - High Transmission Loss Acoustical Tile
  - Large Air Space Between Interior and Exterior Walls






# LVEA/VEA Acoustics -- Issues and Resolutions


---

- Low Frequency Data -- HVAC  
Very Little Information Below 63 Hz
- Modeling at Low Frequency Limited
- Rain and Wind Noise not Controlled  
Depending on 5% Criteria



# Vibration Review

Paul MacCalden




# Foundation Analyses

---

- Vibration Criteria
- Foundation Configurations
- Acoustically Induced Vibrations
- Thermally Induced Distortions
- Ambient PSD Induced Vibrations
- HVAC Equipment Vibrations
- Chiller Equipment Vibrations
- Wind Induced Vibrations
- Foundation Thickness Trade Study






# Vibration Criteria


---

---

- Broad-Band Vibrations
- LIGO Standard Power Spectral Density (LSPSD)
  - Acoustic Induced Vibrations Less Than the LSPSD
  - Ambient Ground Excited Vibrations Less Than Four Times the LSPSD

# LIGO ACCELERATION PSD CRITERIA






# Vibration Criteria - 2 nd

## ► Narrow-Band Vibration Requirements

Narrow-Band Vibration Range	RSS of Three Axes Shall Be Less Than
<b>From 0.1 Hz to 1.0 Hz</b>	<b><math>2.4 \times 10^{-7}</math> m/sec<sup>2</sup></b>
<b>From 1.0 Hz to 50 Hz</b>	<b><math>5.0 \times 10^{-4}</math> m/sec<sup>2</sup></b>
<b>Above 50Hz</b>	<b><math>3.0 \times 10^{-25} \{F/1\text{ Hz}\}^9</math> m</b>




# Vibration Criteria - 3 rd

---

---

- Acoustic Requirements - SPL
  - Marshall Long's Presentation Slides
- Environmental Effects
  - Acoustic and Vibration Levels Must Not Be Exceeded More Than 5% of the Time
  - Includes Wind, Rain, and Other Local Environmental Effects







# Foundation Configuration

- LVEA Foundation
  - 68 Inch Thick -- Solid Reinforced Concrete
- Plan View X-Shaped
  - 277 Feet By 300 Feet -- Overall Plan Dimension
  - 37.5 Feet and 57.5 Feet -- Typical Floor Widths
  - 2 Inch Air Gap Around Perimeter of Floor

8/29/95






# Foundation Configuration -- 2nd


---

---

- Mid-Station -- VEA
  - 68 Inch Thick -- Solid Reinforced Concrete
  - Plan View Rectangular
  - 35 Feet By 77 Feet
  - 2 Inch Air Gap Around Perimeter of Floor

8/29/95







# Foundation Configuration -- 3rd

- End-Station -- VEA
  - 68 Inch Thick - Solid Reinforced Concrete
  - Plan View -- Rectangular
  - 35 Feet By 57 Feet
  - 2 Inch Air Gap Around Perimeter of Floor

8/29/95

ar° waafsp 41.0pz







# Acoustically Induced Vibrations

---


- Inputs
  - LIGO Acoustic Criteria = L-SPL
  - Marshall Long's Predicted SPL = ML-SPL
- LVEA Responses
  - 1/7 th of Criteria at L-SPL
  - 1/50 th of Criteria at ML-SPL
- Mid-Station Responses
  - 1/5 th of Criteria at L-SPL
  - 1/50 th of Criteria at ML-SPL




# 68" LVEA FOUNDATION - ACOUSTIC PSD



# 68" MID-STATION FOUNDATION - ACOUSTIC PSD






# Thermally Induced Distortions

---


- Input: 2 °F Air Temperature Change in 1 Hour
- Thermal Response of Floor in 10 Minutes
  - 0.28 °F at Surface, 0.00 °F at 3 inch Depth
  - Goal = 50 Nano-Radians Over 2 Meters




2 F TEMPERATURE CHANGE PER HOUR  
10 MINUTE DIFFERENTIAL CHANGE




# 10 MINUTE THERMAL FOUNDATION DEFORMATIONS



# 10 MINUTE THERMAL FOUNDATION ROTATIONS






## Thermal Distortions - 2 nd Response Over 2 Meter Distance

---

---

- 12 Meter Floor Span
  - Exceeds Goal at 1 Meter From Center
- 45 Meter Floor Span
  - Exceeds Goal at 14 Meters From Center
- 95 Meter Floor Span
  - Exceeds Goal at 37 Meters From Center



# Ambient PSD Induced Vibrations

---

---

- Criteria = 4 x LIGO Standard PSD
- LVEA, Mid and End Station
- All Foundations Satisfy Criteria
- Significant High Frequency Reductions

Node 792 X3  
LUEA-PB1 PSD RUN - 68 INCH (MODAL STRAIN ENERGY DAMP

N  
O.  
D.  
A.  
L.  
  
P  
S  
D  
  
9  
A  
C  
C  
E  
L  
  
P  
S  
D

2.00E-13


1.00E-13

1.00E-14

1.00E-15

1.00E-16

1.00E-17




FREQUENCY (HZ)

PLOT NO =

9

68° MID-PBI RESPONSE TO GROUND PSD SPECTRUM (STRAIN ENER)




FREQUENCY (HZ)

PLOT NO =

3


**68 END-PB1 RESPONSE TO GROUND PSD (V DAMP 0.02) NODE 150**



FREQUENCY (HZ)

PLOT NO =

3




# HVAC Equipment Vibrations

---

---

- Isolated Concrete Fan Room
- Minimum 5 Hz Fan Isolation Skids
- LVEA = Six Fans Operating Continuously
- Mid and End Stations = One Fan Operates
- 0.1g Unbalanced Fan Vibration Source
- 1800 rpm Fan Speed




## HVAC Equipment Vibrations -- 2 nd

---

---

- Proposed Spike Criteria =  $1.4 \times 10^{-8}$  m at 30 Hz
- LVEA Expected Displacement
  - $2.5 \times 10^{-8}$  m
- Mid & End Station Expected Displacement
  - $5.7 \times 10^{-8}$  m




# Chiller Equipment Vibrations

---

---


- Chillers at 300 Feet From LVEA/VEA
- Minimum 5 Hz Rotating Equipment Skid
- 0.1g Unbalanced Vibration Source
- 3600 rpm Rotational Speed
- Proposed Spike Criteria at 60 Hz
  - $3.0 \times 10^{-9}$  m
- Expected Displacement {LVEA and VEA}
  - $5.6 \times 10^{-9}$  m





# Wind Induced Vibrations

---

- Wind Exceeds 20 mph less than 5% of Time
- Side-Sway Building Frequency 2.54 Hz
- Side-Sway Vibration at Roof = 0.003 Inches  
at 20 mph
- LVEA Foundation Vibration =  $2.3 \times 10^{-6}$  m
- Spike Amplitude Criteria =  $2.0 \times 10^{-6}$  m
- Moses Lake Wind Measurements
- Internal Pressure Fluctuations - TBD







# Foundation Thickness Study


---

---


- 68 Inch Thick Foundation Meets Criteria
  - With a Substantial Factor of Safety
- 36 Inch Thick Foundation Meets Criteria
  - With No Factor of Safety
- 18 Inch Thick Foundation Exceeds Criteria




# 68" LVEA FOUNDATION - ACOUSTIC PSD




# 36" LVEA FOUNDATION - ACOUSTIC PSD




# 18" LVEA FOUNDATION - ACOUSTIC PSD




# 68" MID-STATION FOUNDATION - ACOUSTIC PSD




# 36" MID-STATION FOUNDATION - ACOUSTIC PSD




# 18" MID-STATION FOUNDATION - ACOUSTIC PSD




# 10 MINUTE THERMAL FOUNDATION DEFORMATIONS




# 10 MINUTE THERMAL FOUNDATION DEFORMATIONS




# 10 MINUTE THERMAL FOUNDATION DEFORMATIONS



# 10 MINUTE THERMAL FOUNDATION ROTATIONS



# 10 MINUTE THERMAL FOUNDATION ROTATIONS



# 10 MINUTE THERMAL FOUNDATION ROTATIONS

