

VOLUME II ATTACHMENTS

ATTACHMENT 1 *Part II* LIGO-C960964-01-V

1. STRUCTURAL CALCULATIONS

TITLE	DOCUMENT NO.	REVISION
I. LIGO Vacuum Equipment Structural Design Criteria	V049-1-066	0
II. Beam Splitter Chamber		
Finite Element Analysis of Upper Section	V049-1-014	0
ASME Code Calculations for Upper Section	V049-1-015	0
FE Analysis of 1 in. Thick Flange for Bolt Preload	V049-1-016	0
FE Analysis of 1 in. Thick Flange for Bolt Preload & Pos. Pressure	V049-1-017	0
FE Analysis of 3/4 in Thick Flange	V049-1-018	0
Flange Design for Internal Pressure	V049-1-019	0
Design of Removable Work Floor	V049-1-020	0
Design of Flange Welds	V049-1-021	1
Finite Element Analysis of Lower Section	V049-1-022	0
Design of 60 in Access Covers	V049-1-023	0
Design of Support Legs & Base Plates	V049-1-024	0
Temporary Cover for 60 in Nozzle	V049-1-025	0
Nozzle to Shell Welds	V049-1-026	0
Lifting Lugs	V049-1-027	0
Shipping Loads	V049-1-028	0
BSC Deflections	V049-1-029	1
NASTRAN Buckling Analysis	V049-1-040	0
BSC Support Clevis	V049-1-069	0
Nozzle D Analysis For 200 kg Force	V049-1-104	0
BSC Point Loads	V049-1-111	0

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

CHECK GEOMETRY

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Pr. No.	Bending Stress				Recovery Distances		Ctors	Shear Stress Fact.			
	Cy-	/	Cy+	/	Cz-	/		Cz+	SSFy	/	SSFz
1	4.11E+00		4.11E+00		4.38E+00		4.38E+00	8.10E-01	4.36E+00		1.92E+00
2	2.00E+00		2.00E+00		2.00E+00		2.00E+00	1.92E+00	2.31E+00		2.31E+00
3	1.00E+00		1.00E+00		1.00E+00		1.00E+00	1.00E+00	1.00E+00		1.00E+00
4	2.00E+00		2.00E+00		4.00E+00		4.00E+00	2.44E+00	1.89E+00		3.43E+00
5	4.00E+00		4.00E+00		4.00E+00		4.00E+00	3.79E+00	2.33E+00		2.33E+00

NODE COORDINATES

Node	X-Coord.	Y-Coord.	Z-Coord.
1	0.00000E+00	0.00000E+00	0.00000E+00
2	0.00000E+00	1.80000E+01	0.00000E+00
3	0.00000E+00	4.40000E+01	0.00000E+00
4	8.40000E+01	0.00000E+00	0.00000E+00
5	8.40000E+01	1.80000E+01	0.00000E+00
6	8.40000E+01	4.40000E+01	0.00000E+00
7	8.40000E+01	0.00000E+00	-8.40000E+01
8	8.40000E+01	1.80000E+01	-8.40000E+01
9	8.40000E+01	4.40000E+01	-8.40000E+01
10	0.00000E+00	0.00000E+00	-8.40000E+01
11	0.00000E+00	1.80000E+01	-8.40000E+01
12	0.00000E+00	4.40000E+01	-8.40000E+01
13	-4.20000E+01	0.00000E+00	-4.20000E+01
14	1.26000E+02	0.00000E+00	-4.20000E+01
15	4.20000E+01	7.00000E+01	-4.20000E+01
16	0.00000E+00	9.00000E+00	0.00000E+00
17	8.40000E+01	9.00000E+00	0.00000E+00
18	8.40000E+01	9.00000E+00	-8.40000E+01
19	0.00000E+00	9.00000E+00	-8.40000E+01
20	0.00000E+00	0.00000E+00	0.00000E+00
21	3.61250E+01	7.00000E+01	-4.20000E+01

*** WARNING - *** Nodes 1 & 20 are <=0.0001 apart in all 3 dirs. ***

BEAM CONNECTIVITY

Beam No	Nodes			Prop No	Mat No	Pincodes		Rigid End Offset		Length	Beam Type
	From/	To /	Ref			I	J	I	J		

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

CHECK GEOMETRY

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Beam No	Nodes			Prop No	Mat No	Pincodes		Rigid End Offset		Length	Beam Type
	From/	To /	Ref			I /	J	I	J		
1	16	2	13	5	1			0.00E+00	0.00E+00	9.0000E+00	Beam
2	2	3	13	5	1	45		0.00E+00	0.00E+00	2.6000E+01	Beam
3	17	5	14	5	1			0.00E+00	0.00E+00	9.0000E+00	Beam
4	5	6	14	5	1	45		0.00E+00	0.00E+00	2.6000E+01	Beam
5	18	8	14	5	1			0.00E+00	0.00E+00	9.0000E+00	Beam
6	8	9	14	5	1	45		0.00E+00	0.00E+00	2.6000E+01	Beam
7	19	11	13	5	1			0.00E+00	0.00E+00	9.0000E+00	Beam
8	11	12	13	5	1	45		0.00E+00	0.00E+00	2.6000E+01	Beam
9	2	5	1	4	2			0.00E+00	0.00E+00	8.4000E+01	Beam
10	5	8	4	4	2			0.00E+00	0.00E+00	8.4000E+01	Beam
11	8	11	7	4	2			0.00E+00	0.00E+00	8.4000E+01	Beam
12	11	2	10	4	2			0.00E+00	0.00E+00	8.4000E+01	Beam
13	3	15	0	3	3			0.00E+00	0.00E+00	6.4838E+01	Beam
14	6	15	0	3	3			0.00E+00	0.00E+00	6.4838E+01	Beam
15	9	15	0	3	3			0.00E+00	0.00E+00	6.4838E+01	Beam
16	12	15	0	3	3			0.00E+00	0.00E+00	6.4838E+01	Beam
17	1	16	13	5	1			0.00E+00	0.00E+00	9.0000E+00	Beam
18	4	17	14	5	1			0.00E+00	0.00E+00	9.0000E+00	Beam
19	7	18	14	5	1			0.00E+00	0.00E+00	9.0000E+00	Beam
20	10	19	13	5	1			0.00E+00	0.00E+00	9.0000E+00	Beam
21	15	21	0	3	3			0.00E+00	0.00E+00	5.8750E+00	Beam

RESTRAINTS

Node No	Global/Local	Restraint Directions
1	GLOBAL	X Y Z - - -
4	GLOBAL	X Y Z - - -
7	GLOBAL	X Y Z - - -
10	GLOBAL	X Y Z - - -

NODAL CONNECTIVITY

*** WARNING - Node 13 not connected to any element ***

```

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

```

CHECK GEOMETRY

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

*** WARNING - Node 14 not connected to any element ***

*** WARNING - Node 20 not connected to any element ***

*EXTRA NODE
(NOT REQ'D)*

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

RENUMBER NODES

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

NODE RENUMBERING CROSS REFERENCE LIST

Was	Is	Was	Is	Was	Is	Was	Is	Was	Is
1	18	2	16	3	15	4	4	5	14
6	11	7	1	8	7	9	5	10	3
11	13	12	10	13	19	14	20	15	12
16	17	17	9	18	2	19	8	20	21
21	6								

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

ASSEMBLE STIFFNESS MATRIX Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

STIFFNESS ASSEMBLY SUMMARY

Number of Node Points.....	21
Number of Truss and Beam Elements.....	21
Number of Plate Elements.....	0
Number of Spring Elements.....	0
Number of Solid Elements.....	0
Number of Axisymmetric Elements.....	0
Number of Nodes with Restraints.....	4
Number of Equations to be Solved.....	96
Number of Blocks in the Matrix.....	1

B L O C K I N F O R M A T I O N

BLCK NO	SIZE (Byte)	BLCK NO	SIZE (Byte)	BLCK NO	SIZE (Byte)	BLCK NO	SIZE (Byte)
----	-----	----	-----	----	-----	----	-----
1	14208						

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

ASSEMBLE STIFFNESS MATRIX Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

E Q U A T I O N N U M B E R L I S T

NODE		TRANSLATION			ROTATION		
WAS	IS	X	Y	Z	X	Y	Z
1	18	0	0	0	94	95	96
2	16	82	83	84	85	86	87
3	15	76	77	78	79	80	81
4	4	0	0	0	13	14	15
5	14	70	71	72	73	74	75
6	11	52	53	54	55	56	57
7	1	0	0	0	1	2	3
8	7	28	29	30	31	32	33
9	5	16	17	18	19	20	21
10	3	0	0	0	10	11	12
11	13	64	65	66	67	68	69
12	10	46	47	48	49	50	51
13	19	0	0	0	0	0	0
14	20	0	0	0	0	0	0
15	12	58	59	60	61	62	63
16	17	88	89	90	91	92	93
17	9	40	41	42	43	44	45
18	2	4	5	6	7	8	9
19	8	34	35	36	37	38	39
20	21	0	0	0	0	0	0
21	6	22	23	24	25	26	27

STIFFNESS SUMMARY IN 1 BLOCKS

Minimum Diagonal Stiffness..... .1541D+08
Eq No of Minimum Diagonal..... 28
Maximum Diagonal Stiffness..... .2597D+11
Eq No of Maximum Diagonal..... 62

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

SOLVE DISPLACEMENTS

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

L O A D C A S E 1

MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

GRAVITY LOADING

X	Y	Z
.0000E+00	.0000E+00	.0000E+00

CONCENTRATED LOADS

Node	Fx	Fy	Fz	Mx	My	Mz
15	.4625E+05	-.1400E+05	.0000E+00	.0000E+00	.0000E+00	.0000E+00
21	.0000E+00	.0000E+00	.2944E+05	.0000E+00	.0000E+00	.0000E+00

REFERENCE TEMPERATURE = .0000E+00

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

SOLVE DISPLACEMENTS

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

L O A D C A S E 1

MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)
APPLIED LOAD VECTOR

Node	Fx	Fy	Fz	Mx	My	Mz
15	.4625E+05	-.1400E+05	.0000E+00	.0000E+00	.0000E+00	.0000E+00
21	.0000E+00	.0000E+00	.2944E+05	.0000E+00	.0000E+00	.0000E+00

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

SOLVE DISPLACEMENTS

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

L O A D C A S E 1

MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

DISPLACEMENTS

Node	T r a n s l a t i o n s			/	R o t a t i o n s		
	X	Y	Z		X	Y	Z
1	.0000E+00	.0000E+00	.0000E+00	/	.1942E-02	-.4443E-05	-.3025E-02
2	.5339E-01	.1250E-03	.3407E-01	/	.1377E-02	-.4443E-05	-.2353E-02
3	.1134E+00	.1363E-03	.6336E-01	/	.1090E-02	-.5882E-03	-.1319E-02
4	.0000E+00	.0000E+00	.0000E+00	/	.1870E-02	.2820E-04	-.3112E-02
5	.5569E-01	-.1250E-02	.3381E-01	/	.1964E-02	.2820E-04	-.2902E-02
6	.1485E+00	-.2293E-02	.1040E+00	/	-.5761E-03	-.6703E-04	-.2981E-04
7	.0000E+00	.0000E+00	.0000E+00	/	.1745E-02	.7949E-04	-.2866E-02
8	.5069E-01	-.3747E-03	.3047E-01	/	.1151E-02	.7949E-04	-.2298E-02
9	.1116E+00	-.7467E-03	.5170E-01	/	.1286E-02	.7517E-03	-.9411E-03
10	.0000E+00	.0000E+00	.0000E+00	/	.2029E-02	.4685E-04	-.2914E-02
11	.5208E-01	.1000E-02	.3651E-01	/	.2019E-02	.4685E-04	-.2676E-02
12	.1368E+00	.1683E-02	.1058E+00	/	-.1979E-03	.2306E-03	-.2257E-03
13	.0000E+00	.0000E+00	.0000E+00	/	.0000E+00	.0000E+00	.0000E+00
14	.0000E+00	.0000E+00	.0000E+00	/	.0000E+00	.0000E+00	.0000E+00
15	.1524E+00	-.8364E-02	.9703E-01	/	.2621E-03	.1263E-03	-.4118E-03
16	.2821E-01	.6250E-04	.1831E-01	/	.1801E-02	-.4443E-05	-.2857E-02
17	.2832E-01	-.6249E-03	.1669E-01	/	.1894E-02	.2820E-04	-.3060E-02
18	.2662E-01	-.1874E-03	.1657E-01	/	.1596E-02	.7949E-04	-.2724E-02
19	.2658E-01	.5001E-03	.1828E-01	/	.2027E-02	.4685E-04	-.2855E-02
20	.0000E+00	.0000E+00	.0000E+00	/	.0000E+00	.0000E+00	.0000E+00
21	.1524E+00	-.5944E-02	.9785E-01	/	.2621E-03	.1438E-03	-.4118E-03

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

SOLVE BEAM LOADS/STRESSES

Version 3.0

12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

GLoads Node	Fx	Fy	Fz	Mx	My	Mz
LLoads Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
Stress Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
	Corner1	Corner2	Corner3	Corner4	Maximum	Minimum
BEAM NO. 5						
GLoads 18	-.1555E+05	.1050E+05	-.1626E+05	.1464E+06	-.1348E-11	-.1400E+06
GLoads 8	.1555E+05	-.1050E+05	.1626E+05	-.2928E+06	.1348E-11	.2800E+06
LLoads 18	.1050E+05	-.2250E+05	.5027E+03	-.1348E-11	.4524E+04	.2025E+06
LLoads 8	-.1050E+05	.2250E+05	-.5027E+03	.1348E-11	-.9049E+04	-.4050E+06
Stress 18	-.6037E+03	-.3007E+04	.6718E+02	.1983E-13	.1183E+03	-.5294E+04
	.4808E+04	-.5779E+04	-.6016E+04	.4572E+04	.4808E+04	-.6016E+04
Stress 8	-.6037E+03	-.3007E+04	.6718E+02	.1983E-13	.2366E+03	-.1059E+05
	.1022E+05	-.1095E+05	-.1143E+05	.9747E+04	.1022E+05	-.1143E+05
BEAM NO. 6						
GLoads 8	-.1056E+05	.7220E+04	-.4245E+04	.9017E+05	.0000E+00	.7412E+05
GLoads 9	.1056E+05	-.7220E+04	.4245E+04	-.2005E+06	.0000E+00	.2005E+06
LLoads 8	.7220E+04	-.1047E+05	-.4468E+04	.0000E+00	.1162E+06	.1135E+05
LLoads 9	-.7220E+04	.1047E+05	.4468E+04	.0000E+00	.0000E+00	-.2836E+06
Stress 8	-.4149E+03	-.1399E+04	-.5971E+03	.0000E+00	.3037E+04	-.2966E+03
	.2919E+04	.2326E+04	-.3749E+04	-.3156E+04	.2919E+04	-.3749E+04
Stress 9	-.4149E+03	-.1399E+04	-.5971E+03	.0000E+00	.0000E+00	-.7415E+04
	.7000E+04	-.7830E+04	-.7830E+04	.7000E+04	.7000E+04	-.7830E+04
BEAM NO. 7						
GLoads 19	-.6542E+04	-.2804E+05	-.2763E+03	.2486E+04	.9042E-12	-.5888E+05
GLoads 11	.6542E+04	.2804E+05	.2763E+03	-.4973E+04	-.9042E-12	.1178E+06
LLoads 19	-.2804E+05	.4430E+04	-.4821E+04	.9042E-12	-.4339E+05	-.3987E+05
LLoads 11	.2804E+05	-.4430E+04	.4821E+04	-.9042E-12	.8678E+05	.7975E+05
Stress 19	.1611E+04	.5920E+03	-.6442E+03	-.1330E-13	-.1134E+04	.1042E+04
	-.5655E+03	.1519E+04	.3788E+04	.1703E+04	.3788E+04	-.5655E+03
Stress 11	.1611E+04	.5920E+03	-.6442E+03	-.1330E-13	-.2269E+04	.2085E+04
	-.2742E+04	.1427E+04	.5965E+04	.1795E+04	.5965E+04	-.2742E+04
BEAM NO. 8						
GLoads 11	-.1153E+05	-.1325E+05	-.9043E+04	-.2712E+06	.0000E+00	.2638E+06
GLoads 12	.1153E+05	.1325E+05	.9043E+04	.3603E+05	.0000E+00	.3603E+05
LLoads 11	-.1325E+05	.1759E+04	-.1455E+05	.0000E+00	.3783E+06	-.5216E+04
LLoads 12	.1325E+05	-.1759E+04	.1455E+05	.0000E+00	.0000E+00	.5096E+05
Stress 11	.7614E+03	.2351E+03	-.1944E+04	.0000E+00	.9889E+04	.1364E+03
	.1051E+05	.1079E+05	-.8991E+04	-.9264E+04	.1079E+05	-.9264E+04
Stress 12	.7614E+03	.2351E+03	-.1944E+04	.0000E+00	.0000E+00	.1332E+04
	-.5708E+03	.2094E+04	.2094E+04	-.5708E+03	.2094E+04	-.5708E+03
BEAM NO. 9						
GLoads 2	-.8235E+04	-.9287E+04	-.1037E+02	-.4993E+04	.1583E+03	-.3758E+06

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

SOLVE BEAM LOADS/STRESSES

Version 3.0

12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

GLoads Node	Fx	Fy	Fz	Mx	My	Mz
LLoads Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
Stress Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
	Corner1	Corner2	Corner3	Corner4	Maximum	Minimum
GLoads 5	.8235E+04	.9287E+04	.1037E+02	.4993E+04	.7129E+03	-.4043E+06
LLoads 2	-.8235E+04	.9287E+04	.1037E+02	-.4993E+04	-.1583E+03	.3758E+06
LLoads 5	.8235E+04	-.9287E+04	-.1037E+02	.4993E+04	-.7129E+03	.4043E+06
Stress 2	.7919E+03	.1685E+04	.3425E+01	.1902E+03	-.1287E+02	-.2002E+05
	.2080E+05	-.1924E+05	-.1921E+05	.2082E+05	.2082E+05	-.1924E+05
Stress 5	.7919E+03	.1685E+04	.3425E+01	.1902E+03	.5796E+02	.2153E+05
	-.2068E+05	.2238E+05	.2227E+05	-.2080E+05	.2238E+05	-.2080E+05
BEAM NO. 10						
GLoads 5	.6602E+01	.5502E+04	.1201E+05	.2522E+06	-.7129E+03	-.5140E+04
GLoads 8	-.6602E+01	-.5502E+04	-.1201E+05	.2100E+06	.1583E+03	.5140E+04
LLoads 5	-.1201E+05	-.5502E+04	-.6602E+01	.5140E+04	.7129E+03	-.2522E+06
LLoads 8	.1201E+05	.5502E+04	.6602E+01	-.5140E+04	-.1583E+03	-.2100E+06
Stress 5	.1155E+04	-.9981E+03	-.2180E+01	-.1958E+03	.5796E+02	.1343E+05
	-.1222E+05	.1464E+05	.1453E+05	-.1233E+05	.1464E+05	-.1233E+05
Stress 8	.1155E+04	-.9981E+03	-.2180E+01	-.1958E+03	.1287E+02	-.1118E+05
	.1235E+05	-.1002E+05	-.1004E+05	.1233E+05	.1235E+05	-.1004E+05
BEAM NO. 11						
GLoads 8	-.4983E+04	.8786E+04	-.1037E+02	-.7390E+04	-.1583E+03	-.3592E+06
GLoads 11	.4983E+04	-.8786E+04	.1037E+02	.7390E+04	-.7129E+03	-.3788E+06
LLoads 8	.4983E+04	-.8786E+04	-.1037E+02	.7390E+04	.1583E+03	-.3592E+06
LLoads 11	-.4983E+04	.8786E+04	.1037E+02	-.7390E+04	.7129E+03	-.3788E+06
Stress 8	-.4791E+03	-.1594E+04	-.3425E+01	-.2815E+03	.1287E+02	.1913E+05
	-.1960E+05	.1867E+05	.1864E+05	-.1963E+05	.1867E+05	-.1963E+05
Stress 11	-.4791E+03	-.1594E+04	-.3425E+01	-.2815E+03	-.5796E+02	-.2018E+05
	.1964E+05	-.2071E+05	-.2060E+05	.1975E+05	.1975E+05	-.2071E+05
BEAM NO. 12						
GLoads 11	.6602E+01	-.6002E+04	.8756E+04	.2687E+06	.7129E+03	-.2743E+04
GLoads 2	-.6602E+01	.6002E+04	-.8756E+04	.2355E+06	-.1583E+03	.2743E+04
LLoads 11	.8756E+04	.6002E+04	.6602E+01	-.2743E+04	-.7129E+03	.2687E+06
LLoads 2	-.8756E+04	-.6002E+04	-.6602E+01	.2743E+04	.1583E+03	.2355E+06
Stress 11	-.8420E+03	.1089E+04	.2180E+01	.1045E+03	-.5796E+02	-.1431E+05
	.1341E+05	-.1521E+05	-.1510E+05	.1353E+05	.1353E+05	-.1521E+05
Stress 2	-.8420E+03	.1089E+04	.2180E+01	.1045E+03	-.1287E+02	.1254E+05
	-.1340E+05	.1169E+05	.1171E+05	-.1337E+05	.1171E+05	-.1340E+05
BEAM NO. 13						
GLoads 3	-.1016E+05	-.2198E+03	-.6706E+04	.2224E+06	-.1574E-09	-.2224E+06
GLoads 15	.1016E+05	.2198E+03	.6706E+04	-.4060E+06	.7085E+06	.4774E+06
LLoads 3	-.2327E+04	.7785E+03	-.1193E+05	.2881E+06	-.1261E+06	.8643E-09

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

SOLVE BEAM LOADS/STRESSES

Version 3.0

12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

GLoads Node	Fx	Fy	Fz	Mx	My	Mz
LLoads Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
Stress Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
	Corner1	Corner2	Corner3	Corner4	Maximum	Minimum
LLoads 15	.2327E+04	-.7785E+03	.1193E+05	-.2881E+06	.8995E+06	.5048E+05
Stress 3	.2327E+02	.7785E+01	-.1193E+03	-.1441E+03	-.1261E+03	-.8643E-12
	-.1029E+03	-.1029E+03	.1494E+03	.1494E+03	.1494E+03	-.1029E+03
Stress 15	.2327E+02	.7785E+01	-.1193E+03	-.1441E+03	-.8995E+03	.5048E+02
	-.9267E+03	-.8258E+03	.9732E+03	.8723E+03	.9732E+03	-.9267E+03
BEAM NO. 14						
GLoads 6	-.1399E+05	.2025E+05	-.9445E+04	-.5790E+05	.6670E-09	-.5790E+05
GLoads 15	.1399E+05	-.2025E+05	.9445E+04	.6628E+06	.1910E+06	-.4288E+06
LLoads 6	.2330E+05	.1190E+05	-.3215E+04	.7501E+05	-.3284E+05	-.2778E-09
LLoads 15	-.2330E+05	-.1190E+05	.3215E+04	-.7501E+05	.2413E+06	.7718E+06
Stress 6	-.2330E+03	.1190E+03	-.3215E+02	-.3751E+02	-.3284E+02	.2778E-12
	-.2659E+03	-.2659E+03	-.2002E+03	-.2002E+03	-.2002E+03	-.2659E+03
Stress 15	-.2330E+03	.1190E+03	-.3215E+02	-.3751E+02	-.2413E+03	.7718E+03
	-.1246E+04	.2975E+03	.7801E+03	-.7635E+03	.7801E+03	-.1246E+04
BEAM NO. 15						
GLoads 9	-.1056E+05	.7220E+04	-.4245E+04	.2005E+06	-.4327E-09	-.2005E+06
GLoads 15	.1056E+05	-.7220E+04	.4245E+04	-.6142E+06	-.6220E+06	.1720E+06
LLoads 9	.6988E+04	.4822E+04	.1047E+05	-.2598E+06	.1137E+06	.4116E-09
LLoads 15	-.6988E+04	-.4822E+04	-.1047E+05	.2598E+06	-.7927E+06	.3127E+06
Stress 9	-.6988E+02	.4822E+02	.1047E+03	.1299E+03	.1137E+03	-.4116E-12
	.4384E+02	.4384E+02	-.1836E+03	-.1836E+03	.4384E+02	-.1836E+03
Stress 15	-.6988E+02	.4822E+02	.1047E+03	.1299E+03	.7927E+03	.3127E+03
	.4102E+03	.1035E+04	-.5499E+03	-.1175E+04	.1035E+04	-.1175E+04
BEAM NO. 16						
GLoads 12	-.1153E+05	-.1325E+05	-.9043E+04	-.3603E+05	-.1841E-08	-.3603E+05
GLoads 15	.1153E+05	.1325E+05	.9043E+04	.3574E+06	-.1045E+06	-.2206E+06
LLoads 12	-.1864E+05	-.6303E+04	.1759E+04	-.4668E+05	.2043E+05	.4527E-09
LLoads 15	.1864E+05	.6303E+04	-.1759E+04	.4668E+05	-.1345E+06	-.4087E+06
Stress 12	.1864E+03	-.6303E+02	.1759E+02	.2334E+02	.2043E+02	-.4527E-12
	.2068E+03	.2068E+03	.1660E+03	.1660E+03	.2068E+03	.1660E+03
Stress 15	.1864E+03	-.6303E+02	.1759E+02	.2334E+02	.1345E+03	-.4087E+03
	.7296E+03	-.8779E+02	-.3568E+03	.4606E+03	.7296E+03	-.3568E+03
BEAM NO. 17						
GLoads 1	-.1840E+05	-.3504E+04	-.1547E+05	-.3289E-09	-.9815E-12	-.3440E-10
GLoads 16	.1840E+05	.3504E+04	.1547E+05	-.1393E+06	.9815E-12	.1656E+06
LLoads 1	-.3504E+04	.2395E+05	.2072E+04	-.9815E-12	.2569E-09	.2082E-09
LLoads 16	.3504E+04	-.2395E+05	-.2072E+04	.9815E-12	-.1865E+05	.2156E+06
Stress 1	.2014E+03	.3201E+04	.2769E+03	.1444E-13	.6715E-11	-.5444E-11
	.2014E+03	.2014E+03	.2014E+03	.2014E+03	.2014E+03	.2014E+03

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

SOLVE BEAM LOADS/STRESSES Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

GLoads Node	Fx	Fy	Fz	Mx	My	Mz
LLoads Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
Stress Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
	Corner1	Corner2	Corner3	Corner4	Maximum	Minimum
Stress 16	.2014E+03	.3201E+04	.2769E+03	.1444E-13	.4876E+03	.5636E+04
	-.4947E+04	.6325E+04	.5350E+04	-.5923E+04	.6325E+04	-.5923E+04
BEAM NO. 18						
GLoads 4	-.5751E+04	.3504E+05	.2574E+04	.1465E-10	.9770E-13	.1489E-10
GLoads 17	.5751E+04	-.3504E+05	-.2574E+04	.2317E+05	-.9770E-13	.5176E+05
LLoads 4	.3504E+05	-.5886E+04	.2246E+04	.9770E-13	-.1705E-12	-.2089E-10
LLoads 17	-.3504E+05	.5886E+04	-.2246E+04	-.9770E-13	-.2022E+05	-.5298E+05
Stress 4	-.2014E+04	-.7866E+03	.3002E+03	-.1437E-14	-.4458E-14	.5461E-12
	-.2014E+04	-.2014E+04	-.2014E+04	-.2014E+04	-.2014E+04	-.2014E+04
Stress 17	-.2014E+04	-.7866E+03	.3002E+03	-.1437E-14	.5285E+03	-.1385E+04
	-.1001E+03	-.2870E+04	-.3927E+04	-.1157E+04	-.1001E+03	-.3927E+04
BEAM NO. 19						
GLoads 7	-.1555E+05	.1050E+05	-.1626E+05	-.8290E-10	-.1348E-11	.4106E-10
GLoads 18	.1555E+05	-.1050E+05	.1626E+05	-.1464E+06	.1348E-11	.1400E+06
LLoads 7	.1050E+05	-.2250E+05	.5027E+03	-.1348E-11	-.2959E-10	-.8765E-10
LLoads 18	-.1050E+05	.2250E+05	-.5027E+03	.1348E-11	-.4524E+04	-.2025E+06
Stress 7	-.6037E+03	-.3007E+04	.6718E+02	.1983E-13	-.7735E-12	.2292E-11
	-.6037E+03	-.6037E+03	-.6037E+03	-.6037E+03	-.6037E+03	-.6037E+03
Stress 18	-.6037E+03	-.3007E+04	.6718E+02	.1983E-13	.1183E+03	-.5294E+04
	.4808E+04	-.5779E+04	-.6016E+04	.4572E+04	.4808E+04	-.6016E+04
BEAM NO. 20						
GLoads 10	-.6542E+04	-.2804E+05	-.2763E+03	-.2741E-10	.9042E-12	.3778E-11
GLoads 19	.6542E+04	.2804E+05	.2763E+03	-.2486E+04	-.9042E-12	.5888E+05
LLoads 10	-.2804E+05	.4430E+04	-.4821E+04	.9042E-12	.2206E-10	-.1671E-10
LLoads 19	.2804E+05	-.4430E+04	.4821E+04	-.9042E-12	.4339E+05	.3987E+05
Stress 10	.1611E+04	.5920E+03	-.6442E+03	-.1330E-13	.5766E-12	.4369E-12
	.1611E+04	.1611E+04	.1611E+04	.1611E+04	.1611E+04	.1611E+04
Stress 19	.1611E+04	.5920E+03	-.6442E+03	-.1330E-13	-.1134E+04	.1042E+04
	-.5655E+03	.1519E+04	.3788E+04	.1703E+04	.3788E+04	-.5655E+03
BEAM NO. 21						
GLoads 15	-.5457E-08	-.1210E-08	-.2944E+05	-.3399E-10	-.1730E+06	-.6029E-08
GLoads 21	.5457E-08	.1210E-08	.2944E+05	.3399E-10	-.6762E-08	.4820E-10
LLoads 15	.5457E-08	-.1210E-08	.2944E+05	.3399E-10	-.1730E+06	.6029E-08
LLoads 21	-.5457E-08	.1210E-08	-.2944E+05	-.3399E-10	-.6762E-08	-.4820E-10
Stress 15	-.5457E-10	-.1210E-10	.2944E+03	-.1700E-13	-.1730E+03	-.6029E-11
	-.1730E+03	-.1730E+03	.1730E+03	.1730E+03	.1730E+03	-.1730E+03
Stress 21	-.5457E-10	-.1210E-10	.2944E+03	-.1700E-13	.6762E-11	-.4820E-13
	-.4776E-10	-.4786E-10	-.6138E-10	-.6128E-10	-.4776E-10	-.6138E-10

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

SOLVE BEAM LOADS/STRESSES

Version 3.0

12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

GLoads Node	Fx	Fy	Fz	Mx	My	Mz
LLoads Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
Stress Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
	Corner1	Corner2	Corner3	Corner4	Maximum	Minimum

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

SOLVE BEAM LOADS/STRESSES

Version 3.0

12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

MAXIMUM STRESS SUMMARY FOR BEAMS/TRUSSES
 WITHIN SPECIFIED RANGE 1- 21

Element	Type	Stress Type	Value
-----	-----	-----	-----
7	BEAM	Axial Tension	.1611E+04
3	BEAM	Axial Compression	-.2014E+04
1	BEAM	Transv. Shear	.3201E+04
15	BEAM	Torsion Shear	.1299E+03
9	BEAM	Bending Stress	.2153E+05
9	BEAM	Max. Comb. Normal	.2238E+05
9	BEAM	Min. Comb. Normal	-.2080E+05

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

SOLVE REACTIONS

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

REACTIONS

Node	Fx	Fy	Fz	Mx	My	Mz
1	-.1840E+05	-.3504E+04	-.1547E+05	.0000E+00	.0000E+00	.0000E+00
4	-.5751E+04	.3504E+05	.2574E+04	.0000E+00	.0000E+00	.0000E+00
7	-.1555E+05	.1050E+05	-.1626E+05	.0000E+00	.0000E+00	.0000E+00
10	-.6542E+04	-.2804E+05	-.2763E+03	.0000E+00	.0000E+00	.0000E+00
Total	-.4625E+05	.1400E+05	-.2944E+05	.0000E+00	.0000E+00	.0000E+00

MEMBER STABILITY EVALUATION

FROM THE IMAGES OUTPUT, EL 9, THE 8x4x1/2 WIDE FLANGE MEMBER, HAS THE HIGHEST STRESS. THIS IS DUE TO BENDING AT THE COLUMN (8x8x5/8 TS SUPPORT LEG)

THIS MEMBER WILL BE AISC GRA B WITH A MIN YIELD STRESS OF 46 KSI

FROM AISC - F3, THE ALLOWABLE UNBRACED LENGTH IS

$$L_c = \left(1950 + \frac{1200 M_1}{M_2} \right) \frac{b}{F_y}$$

$$b = 4 \text{ IN}$$

$$M_1 = 375 \text{ IN-K (NODE 2)}$$

$$M_2 = 404 \text{ IN-K (NODE 5)}$$

$$F_y = 46$$

$$L_c = \left(1950 + 1200 \times \frac{375}{404} \right) \frac{4}{46} = 266 \text{ IN}$$

$$\gg L = 84 \text{ IN OK}$$

$$\frac{b}{t} = \frac{4}{.50} = 8 < \frac{190}{\sqrt{F_y}} = 28 \text{ OK}$$

\(\therefore\) SECTION IS COMPACT - AISC TABLE D5.1

$$\Rightarrow F_b = .66 F_y = .66 (46) = 30.4 \text{ KSI}$$

FROM THE IMAGES OUTPUT -

$$f_b = 22.4 \text{ KSI} < F_b = 30.4 \text{ KSI OK}$$

50 SHEETS
100 SHEETS
200 SHEETS

MAX DEFLECTION (NODE 15)

$\Delta_y = .152$

$\Delta_z = .097$

$\Delta = (\Delta_y^2 + \Delta_z^2)^{1/2}$
 $= .180 \text{ IN}$

BASE PLATE / ANCHOR REACTIONS

NODE	1	4	7	10	
F_y	18.4	5.8	15.6	6.5	
F_z	-3.5	35.0	10.5	-28.0	$\left\{ \begin{array}{l} + = \text{COMP} \\ - = \text{TEN} \end{array} \right.$
F_x	15.5	2.6	16.3	.3	
TEN = 1.25 F_y	4.4	—	—	3.5	PRYING
$V = (F_y^2 + F_z^2)^{1/2}$	24.0	6.4	22.6	6.5	
$T = \text{TEN}/4$	1.1	—	—	4.75	← MAX BOLT TENSION
TALL	10.96	—	—	10.96	*
T/VALL	.10	—	—	.80	
$V/4$	6.0	1.6	5.7	1.6	
VALL	7.63	7.63	7.63	7.63	*
$V/VALL$.79	.21	.75	.21	
$T/VALL + V/VALL$.89	.21	.75	1.01	≈ 1.0 OK

* SEE FOLLOWING SHEETS

BEARING FOR COMPRESSIVE FORCES

A-2 WOOD W $F_y = 35.0 \text{ K}$

FOR 14 X 14 BASE PLATE

$$f_p = \frac{35}{14 \times 14} = .18 \text{ ksi } \approx$$

$\ll f'_c = 3000 \text{ psi}$
FOR CONCRETE

HILTI HVA ADHESIVE ANCHORS WILL BE
USED - 4 PER BASE PLATE

USE 1 IN ANCHORS W/ 4 "1/4" EMBEDMENT

$T_{HI} = 10.9 \text{ K}$ (BOND IN 3000 PSI CON.)


$T_{AL} = 12.12 \text{ K}$ (A307 STEEL ROD)

$V_{ALL} = 7.63$

ALLOWABLES ARE FROM HILTI CATALOG

(HAS-Anchor Rod)

$P_{T_{MAX}} = 2 \frac{1}{2} \text{ IN}$ FOR
STANDARD ROD





USE CUSTOM ROD
FOR LARGE GROUT
PAD

TENSILE CAPACITY OF 4-BOLT CLUSTER DUE TO CONCRETE CONE FAILURE. CONSIDER OVERLAPPING CONES

ANCHOR SPACING

$$S = 11 \text{ IN} > AS = 8 \frac{1}{4} \text{ PER MULTI CATALOG}$$

SURFACE AREA OF INTERSECTING CONES



$$E = \text{EMBEDMENT} = 8.25 \text{ IN}$$

$$r = E$$

$$2r = 16.5 > S = 11$$

$$\theta = \cos^{-1} \left(\frac{S/2}{r} \right) = \cos^{-1} \left(\frac{5.5}{8.25} \right) = .841 \text{ RAD} = 48.2^\circ$$

$$h = r \sin \theta = 8.25 \sin (.841 \text{ RAD}) = 6.15 \text{ IN}$$

$$A_{RT} = S/2 (h/2) = \frac{1}{2} (6.15) = 16.91 \text{ IN}^2$$

$$A_{2\theta} = \pi r^2 \left(\frac{2\theta}{2\pi} \right) = r^2 \theta = (8.25)^2 (.841) = 57.25 \text{ IN}^2$$

$$A_{OL} = A_{2\theta} - 2A_{RT} = 57.25 - 2(16.91) = 23.43 \text{ IN}^2$$

$$\text{FOR EA CONE: } A_{\text{CONE}} = \pi r^2 - 2A_{OL} = \pi (8.25)^2 - 2(23.43) = 167 \text{ IN}^2$$

TOTAL CONE AREA

$$A_T = 4 A_{\text{CONE}} = 4(167) = 668 \text{ IN}^2$$

Revision No. 0

Doc. No. V049-1-024

Page 30 of 35

CONCRETE STRENGTH FOR THE 4 BOLT ANCHORAGE

$$T_u = 4 \phi_c \sqrt{f'_c} A_T$$

$$f'_c = 3000 \text{ psi}$$

$$\phi_c = .65$$

$$T_u = 4(.65)(3000)^{\frac{1}{2}}(662) \\ = 95113 \text{ LB}$$

MAXIMUM TENSILE FORCE IN COL

$$F_y = 28.0 \text{ K}$$

PER AISC CODE, (PART 9), LOAD FACTOR = 1.7

$$1.7F_y = 47.6 < T_u = 95.1 \text{ K OK}$$

ALLOWABLE LOAD PER ANCHOR BASED ON
CONCRETE CONE FAILURE

$$T_{all} = \frac{T_u}{4(1.7)} = \frac{95.1}{4(1.7)}$$

$$= 14.0 \text{ K}$$


$$> 10.96 \text{ K (BASED ON 3000 PSI CONC)}$$

$$> 12.12 \text{ K (A307 STEEL ROD CAPACITY)}$$

∴ BOND GOVERNS ANCHOR FOR $8\frac{1}{4}$ " EMBEDMENT.



BASE PLATE BENDING DUE TO ANCHOR TENSION



$$b = 2a$$

$$a = \left(\left(\frac{11 - 8}{2} \right)^2 \times 2 \right)^{\frac{1}{2}}$$

$$a = 2.12$$

$$b = 2(2.12) = 4.24$$

MOMENT

$$M = T a = 8.75 (2.12) = 18.6 \text{ IN-K}$$

STRESS

$$f_b = \frac{6M}{b t^2}$$

$$= \frac{6(18.6)}{4(1)^2}$$

$$= 27.8 \text{ KSI} \approx .75 F_y = .75(36) = 27 \text{ KSI}$$

SAY OK

TUBESTEEL TO BASE PLATE WELD

$$T = 28.0 \text{ K} = F_y \text{ MAX TENSION}$$

TRY 5/16 FILLET,

$$L = 4(1) = 32$$

$$R_w = .707 \left(\frac{5}{16} \right) (32) \\ = 7.07 \text{ IN}^2$$

WELD STRESS DUE TO SHEAR LOADS

$$V = 24.0 \text{ K} \text{ MAX SHEAR ON ANOTHER BASE PLATE}$$

$$f_v = \frac{T}{R_w} + \frac{V}{R_w} = \\ = \frac{28.0}{7.07} + \frac{24.0}{7.07} \\ = 4.0 + 3.4 = \\ = 7.4 \text{ KSI} \quad \text{OK}$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS




LEG TO VESSEL CONNECTION

PAD WELD - DESIGN FOR RESULTANT FORCE AND IN PLANE MOMENT AT TOP OF SUPPORT LEG

$$\begin{aligned}
 F &= (F_x^2 + F_y^2 + F_z^2)^{\frac{1}{2}} \\
 &= (20.3^2 + 3.2^2 + 16.6^2)^{\frac{1}{2}} \quad (\text{BEAM 4, NODE 6}) \\
 &= 26.4 \text{ K MAX FORCE}
 \end{aligned}$$

$$\begin{aligned}
 M_z &= 315 \text{ IN-K, MAX AT BEAM 2, NODE 3} \\
 (M_x = M_y = 0 \text{ DUE TO PIN RELEASE})
 \end{aligned}$$

ASSUME WELD IS 3/8 IN THICK ALL AROUND ON 10 X 12 PAD



$$A = \frac{3}{8} (1.707) (10 + 12) (2) = 11.67 \text{ IN}^2$$

$$\begin{aligned}
 I_y &= \frac{3}{8} \left(2 \times \frac{12^3}{12} + 2 \times 10 \times 6^2 \right) \\
 &= \frac{3}{8} (1008) = 378 \text{ IN}^4
 \end{aligned}$$

$$\begin{aligned}
 I_x &= \frac{3}{8} \left(2 \times \frac{10^3}{12} + 2 \times 12 \times 5^2 \right) \\
 &= \frac{3}{8} (767) = 288 \text{ IN}^4
 \end{aligned}$$

$$J = I_x + I_y = 666 \text{ IN}^4$$

$$P = (6^2 + 5^2)^{\frac{1}{2}} = 7.81 \text{ IN}$$


WELD SHEAR STRESS

$$\begin{aligned}
 f_v &= \frac{F}{A_w} + \frac{M_z P}{J} \\
 &= \frac{26.4}{11.67} + \frac{315 (7.81)}{666} \\
 &= 2.26 + 3.69 = 5.96 \text{ KSI OK}
 \end{aligned}$$

ACTUAL STRESS < 5.96 KSI SINCE MAX MOMENT & MAX FORCE OCCUR AT DIFFERENT JOINTS

WELDED CONNECTION BETWEEN SUPPORT LEG
($8 \times 8 \times 5/8$ TS) AND CROSS MEMBER ($7 \times 4 \times 3/4$ TS)

SINCE THE BENDING STRESS IN THE
CROSS MEMBER IS HIGH AT THE SUPPORT
LEG, THIS CONNECTION WILL BE A
FP BUTT WELD



* FULL THROAT REQUIRED FOR
 $3/8$ " THICK MEMBER


NOTE: SEE CALCULATION V049-1-069
FOR DESIGN OF CLEVIS CONNECTION
BETWEEN SUPPORT LEG AND WELD
PAD AT SHELL.

22-141 50 SHEETS
22-142 100 SHEETS
22-143 200 SHEETS



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-025 PAGE 1 OF 5
REV.	DEO #	DATE	BY:	CHECK	TITLE: Design of Temporary Covers	
0	0128	4/17/96	RDC	WDB		
					BY: R. D. Ciatto	DEPT.: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> Design temporary shipping and test covers for 60.5 in nozzles in accordance with the requirements of ASME Section VIII, Div. 1.						
<u>METHOD:</u> Hand calculation to determine membrane and shear stresses.						
<u>ASSUMPTIONS:</u>						
<u>INPUTS:</u> 1. Atmospheric pressure = 14.7 psi. 2. Temperature = 70°F (SHIPPING). 3. TEMP = 400°F DURING BAKEOUT						
<u>REFERENCES:</u> 1. ASME Boiler & Pressure Vessel Code, Section VIII, Div. 1, Pressure Vessels 2. Doc. No. V049-1-026, LIGO VACUUM EQUIP., STRUCT. DESIGN CRITERIA,						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> The requirements of the ASME Code are met.						
<u>NOTES:</u>						

TEMPORARY 60.5 IN COVER



C = FLANGE WIDTH FOR 60.5 IN
FLANGE

THICKNESS = 1/16 IN

MATERIAL SA 210 304L (CMTR REQD)

BOLT PATTERN & SIZE IS SAME AS
FLANGE BOLT PATTERN & SIZE

REV D
DCL. NO V049-1-025
P. 2 OF 5


22-141 50 SHEETS
22-142 100 SHEETS
22-143 200 SHEETS



TEMPORARY COVER FOR 60 IN FOR-

COVER WILL BE 1/16 IN SHEET 304L.
COLD FORM COVER USING 30 PSID APPROX.
PLATE

TO FORM THE COVER, THE SHEET WILL
BE CLAMPED BETWEEN 2 CIRCULAR PLATES.
PRESSURE WILL BE APPLIED ON ONE
SIDE. A PLASTIC HINGE WILL FORM
AT THE EDGE OF THE SHEET



MEMBRANE STRESS IN SPHERE

$$\sigma = \frac{pR}{2t}$$

YIELD STRESS AT ROOM TEMP

$$\sigma = S_y = 25 \text{ KSI FOR 304L}$$


$$p = 30$$

$$t = 1/16 = .0625$$

$$25,000 = \frac{30 R}{2(.0625)}$$

$$R = 104.2 \text{ IN}$$

REV D
DOC. No V049-1-025
P. 3 OF 5



$$a = (104.2^2 - 30.25^2)^{\frac{1}{2}}$$

$$= 99.7$$

$$b = 104.2 - a$$

$$= 104.2 - 99.7$$

$$= 5.0 \text{ IN}$$

USING YIELD STRESS FROM CHTR
 DETERMINE PRESSURE REQUIRED
 TO OBTAIN $b = 5 \text{ IN}$

$$P = \frac{2 S_y t}{R}$$

$$= \frac{2 (.0625) S_y}{104.2}$$

$$= 1.20 (10)^{-3} S_y$$

P, S_y IN PSI, S_y @ ROOM TEMP

REQUIRED THICKNESS FROM ASME VIII, (1), APP-1

$$t = \frac{p R_0}{2 S E T . 8 P} \quad \text{FOR SPHERICAL SHELL}$$

$$P = 14.7$$

$$R_0 = 104.2 + .06$$

$$= 104.3$$

REV D
 Doc. No. V049-1-025
 P. 4 OF 5

VESSELS WILL BE BAKED @ 400° F WHILE
TEMP COVER ARE IN PLACE

$$S = 14.7 \text{ @ } 70^{\circ} \text{F ASME II TABLE 1A} \\ \text{FOR SA 240 304L}$$

$E =$ JOINT EFFICIENCY

$$= 1.0 \text{ (NO WELD)}$$

$$t = \frac{14.7(104.3)}{2(14,700)(1) + .8(14.7)}$$

$$= .052 < .0625 = 1/16$$

$$\text{OR}$$

OR

SHEAR STRESS AT EDGE

$$\tau = \frac{\pi \left(\frac{60.5}{2}\right)^2 (14.7)}{\pi (60.5) (.0625)}$$

$$= 3600 \text{ psi OR}$$

$$= 3600 \text{ psi OR}$$

REV 0
Doc. No. V047-1-025
P. 5 OF 5


50 SHEETS
100 SHEETS
200 SHEETS

22-141
22-142
22-144



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-026 PAGE 1 OF 3
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber - Evaluation of Nozzle to Shell Welds	
0	0024	12/6/95	RAC	AGR		
					BY: <i>J.D. Cirillo</i>	DEPT.: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> To evaluate nozzle to shell fillet welds.						
<u>METHOD:</u> Hand calculation using standard principles of mechanics.						
<u>ASSUMPTIONS:</u>						
<u>INPUTS:</u> LIGO project sketches and drawings.						
<u>REFERENCES:</u> ASME Boiler & Pressure Vessel Code, Section VIII, Division 1. <i>Doc. No. V049-1-066, LIGO VACUUM EQUIP. STRUCTURAL DESIGN CRITERIA.</i>						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> Nozzle welds are acceptable.						
<u>NOTES:</u>						

NOZZLE TO SHELL WELDS



MAX NOZZLE DIAMETER THAT USES THIS WELD IS 14" O.D. THE THICKNESS OF THE NOZZLES THAT RANGE FROM 8" TO 14" O.D. IS .125 IN. THE WELD FOR THE 14" NOZZLE HAS THE MAX STRESS.

EVALUATE FULL FILLET FOR END CAP LOAD ONLY. DISCONTINUITY BENDING & SHEAR WILL BE NEGLECTED SINCE THEY ARE SECONDARY, BUT THE STRENGTH ADDED BY THE STITCH WELD WILL BE IGNORED.

END CAP FORCE DUE TO VACUUM

$$\begin{aligned}
 F &= \pi r^2 (14.7) \\
 &= \pi \left(\frac{14}{2}\right)^2 (14.7) = 2263 \text{ LB}
 \end{aligned}$$

14" NOZZLE HAS MAX END CAP LOAD





WELD THROAT AREA

$$A_w = \pi 14 \times .707 (.125) \\ = 3.89 \text{ IN}^2$$

WELD SHEAR STRESS

$$f_v = \frac{F}{A_w} \\ = \frac{2263}{3.89} \\ = 582 \text{ psi} \quad \text{OK}$$

THE 60 IN NOZZLES ARE WELDED TO THE SHEET USING FULL PENETRATION WELDS, NO FURTHER ANALYSIS OF THESE WELDS IS REQUIRED.

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-027 PAGE 1 OF 6
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber - Vessel Lifting Devices	
0	0024	12/6/95	RDC	WDB		
					BY: R. D. CATTO	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
<p>PURPOSE: To design lifting lugs and evaluate leg stresses when BSC is lifted and rotated to & from a horizontal position.</p>						
<p>METHOD: Hand calculation using standard stress analysis method.</p>						
<p>ASSUMPTIONS:</p>						
<p>INPUTS: 1. LIGO project skteches and drawings. 2. Vertical shock acceleration = 1g. 3. DDC. No. V049-1-066, LIGO VACUUM EQUIP., STRUCTURAL DESIGN CRITERIA.</p>						
<p>REFERENCES:</p>						
<p>CALCULATIONS: (SEE ATTACHED)</p>						
<p>CONCLUSIONS: Lug & weld stresses are acceptable. Stresses in support legs and shell are acceptable.</p>						
<p>NOTES: A spreader beam should be used for the lift.</p>						

LIFTING LUGS

MAXIMUM ESTIMATED WEIGHT OF BSC

$$W = 15000 \text{ LB}$$

INCLUDES SHROUDS & REMOVABLE FLOOR.

SHIPPING ACCELERATIONS FOR AIR-RIDE TRUCK.

VERT $a_v = 1.0 g$



HORIZ. $a_H = \sqrt{2} g$

ASSUME THAT THESE ACCELERATIONS ALSO APPLY TO LIFTING IN SHED

∴ VERTICAL LOAD = DL + SHIPPING LOAD

$$= F_v = W + W = 2W = 30000 \text{ LB}$$

SINCE THERE WILL BE 2 LIFTING LUGS THE LIFTING LOAD IN EA LUG (FOR DESIGN PURPOSES) IS 15000 LB. WHEN VESSEL IS IN HORIZ POSITION AND BEING RAISED TO VERTICAL WITH THE LUGS THE LATERAL LOAD IS $F_H/2 = 7500 \text{ LB}$ ON LUG





THE FE ANAL OF THE BSC UPPER SECTION SHOWED THAT THE MAX SHELL STRESS FOR THE VERTICAL LIFT IS 1590 PSI FOR A LUG LOAD OF 6250 LB. ∴ THE MAX STRESS FOR THIS CASE IS

$$SI = \frac{15000}{6250} \times 1590$$


$$= 3800 \text{ psi OK}$$

FOR THE HOIST CASE THE MAX SHELL STRESS FROM THE FE ANALYSIS IS 2630 PSI FOR A LOAD OF 3125 LB. ∴ THE MAX STRESS INTENSITY FOR THIS CASE IS

$$SI = \frac{7500}{3125} \times 2630$$

$$= 6300 \text{ psi OK}$$

LUG GEOMETRY




TENSILE STRESS AT PIN HOLE

$$A_{net} = (6 - 1.5)(.5) = 2.25 \text{ in}^2$$

$$f_t = \frac{15}{2.25} = 6.67 \text{ ksi OK}$$

FOR $t = .5$


SHEAR STRESS



$$A_v = 2 \left(\frac{6 - 1.5}{2} \right) (.5) = 4.5 \text{ in}^2$$

$$f_v = \frac{15}{4.5} = 3.33 \text{ ksi}$$

BENDING STRESS



$$M = 13.5 (7.5) = 101.25 \text{ in}^2$$

$$f_b = \frac{6M}{t b^2} = \frac{6(101.25)}{1(9)^2} = 15.0 \text{ ksi OK}$$

WELD - 704 1/4 IN FILLET WELD

$$A_w = .707(.75) (12 + 12 + 9) = 5.8 \text{ in}^2$$


(NOTE: DWG V049-4-001 SH 5 SHOWS A WELD PAD BETWEEN LUG & VESSEL W/ 3/16 WELD ALL AROUND TO VESSEL)

$$A_w = 3/16 (.707) (2 \times 12 + 2 \times 13.5) = 6.4 \text{ in}^2 > 5.8 \text{ OK}$$

FOR VERTICAL LOAD, WELD STRESS IS

$$f_v = \frac{15}{A_w} = \frac{15}{5.8} = 2.6 \text{ ksi OR}$$

TORSIONAL SHEAR STRESS DUE TO LIFT FROM HORIZONTAL POSITION



$$C = \frac{12 \times 9 + 2 \times 12 \times 6}{2 \times 12 + 9}$$

$$= 7.64 \text{ in}$$

$$F_L = 7.5 \text{ k}$$

$$T = 7.5 (13.5 + 7.64) = 158.6 \text{ in k}$$

$$I_x = \left[\frac{9^3}{12} + 2(12)(4.5)^2 \right] (.75)(.707)$$

$$= 386.6 (.25) = 96.6 \text{ in}^4$$

$$I_y = \left[9(12-7.64)^2 + 2 \times \frac{12^3}{12} + 2 \times 12 \times 6.64^2 \right] (.707)(.25)$$

$$= 370.2 (.25) = 92.6 \text{ in}^4$$

$$J = I_x + I_y = 96.6 + 92.6 = 189.2 \text{ in}^4$$

$$P_{max} = (7.64^2 + 4.5^2)^{\frac{1}{2}} = 8.90 \text{ in}$$


WELD SHEAR STRESS

$$\tau = \frac{F_L}{A_w} + \frac{T P_{max}}{J}$$

$$= \frac{7.5}{5.8} + \frac{158.6(8.90)}{189.2}$$

$$= 1.3 + 7.43 = 8.7 \text{ ksi OR}$$

LIFTING FORCE ON LEG WHEN BSC
IS IN HORIZONTAL POSITION



$$F_{LEG} \approx 7.5 \text{ K} \quad \text{EA. LEG}$$

THIS FORCE IS BOUNDED BY THE
MAX SHEAR FORCE IN THE BASE PLATE
IMPOSED BY THE UNBALANCED VACUUM
LOAD. FROM SUPPORT CALC

$$V = 14.5 \text{ K}$$

∴ STRESSES IN SUPPORT STRUCTURE AND
BSC SHELL DUE TO LIFT ARE ACCEPTABLE

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



STRESS IN OUTER WELD FOR PAD TO SHELL CONNECTION (3/16 KILLT ALL AROUND)

FOR VERT LOAD


$$T = 15 \text{ K}$$

$$A_w = .707 \times \frac{3}{16} (2 \times 12 + 2 \times 13.5) \\ = 6.76 \text{ IN}^2$$

$$f_t = \frac{15}{6.76} = 2.21 \text{ KSI OR}$$

FOR HORIZ CASE

$$7.5 \text{ K}$$

$$T = 7.5 (25.5 + 1.5 - \frac{13.5}{2}) \\ = 151.9$$

$$I_y = \frac{3}{16} (.707) \left[2 \times \frac{12^3}{12} + 2 \times 13.5 \times 6^2 \right] \\ = \frac{3}{16} (891) = 167 \text{ IN}^4$$

$$I_x = \frac{3}{16} (.707) \left[2 \times \frac{13.5^3}{12} + 2 \times 12 \times \left(\frac{13.5}{2}\right)^2 \right] \\ = \frac{3}{16} (1063) = 199$$

$$J = I_x + I_y = 366 \text{ IN}^4$$

$$r = \left[6^2 + \left(\frac{13.5}{2}\right)^2 \right]^{\frac{1}{2}} = 9.03 \text{ IN}$$

WELD SHEAR STRESS:

$$\tau = \frac{7.5}{6.76} + \frac{151.9(9.03)}{366}$$

$$= 1.1 + 3.74$$

$$= 4.8 \text{ KSI OR}$$

REV D
Doc No 1049-1-027


P. 6A OF 6

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-028 PAGE 1 OF 8
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber - Shipping Loads	
0	0136	4/20/96	RDC	WDB		
					BY: R. D. Ciatto	DEPT: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> To evaluate the BSC shell for loads imposed during shipping.						
<u>METHOD:</u> The IMAGES finite element computer program is used to analyze shell stresses.						
<u>ASSUMPTIONS:</u> It is assumed that the BSC will be shipped with its long axis in a horizontal position. Also, it is assumed that the vessel will be supported by 2 wood saddles during shipping.						
<u>INPUTS:</u> Vert shock accel = 1g Horizontal shock accel. = .5g Internal Vacuum Pressure = -14.7 psi						
<u>REFERENCES:</u> 1. IMAGES 3D, Version 3.0, R.L. Cloud & Associates 2. Doc. No. V049-1-066, LIGO Vacuum Equipment, Structural Design Criteria						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> Shell stresses that result from shipping loads are low. The vessel can withstand a shock of 5Gs or more without damage to the shell.						
<u>NOTES:</u> The computer file name is BSC-SHIP.						

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-028 PAGE 1 OF 7
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber - Shipping Loads	
0	0128	12/6/95	RDC	WFB		
					BY: R.D. CURTIS	DEPT.: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> To evaluate the BSC shell for loads imposed during shipping.						
<u>METHOD:</u> The IMAGES finite element computer program is used to analyze shell stresses.						
<u>ASSUMPTIONS:</u> It is assumed that the BSC will be shipped with its long axis in a horizontal position. Also, it is assumed that the vessel will be supported by 2 wood saddles during shipping.						
<u>INPUTS:</u> Vert shock accel = 1g Horizontal shock accel. = .5g						
<u>REFERENCES:</u> IMAGES 3D, Version 3.0, R.L. Cloud & Associates						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> Shell stresses that result from shipping loads are low. <i>THE VESSEL COULD SUSTAIN A SHOCK ACCELERATION OF SEVERAL GS.</i>						
<u>NOTES:</u> The computer file name is BSC-SHIP. *						

BSC SHIPPING LOADS

IT IS EXPECTED THAT THE BSC WILL BE SHIPPED IN A HORIZONTAL POSITION WHILE SUPPORTED BY 2 WOOD SADDLES AND STAPPED TO A WOOD SKID



CRITICAL LOCATIONS ARE IN THE SHELL AT THE SADDLES. SINCE THE THINNEST SHELL IS THE $1/4$ IN UPPER SECTION, IT IS EVALUATED.

BECAUSE THE VERTICAL ACCEL (1G) WHEN COMBINED WITH GRAVITY (1G) IS HIGHER THAN THE HORIZONTAL ACCEL (.5G), ONLY THE VERTICAL LOAD WILL BE ANALYZED. THESE ACCELERATIONS ARE THE MAXIMUM FOR AN AIR-RIDE TRUCK.

MAX GST WT

$$W = 15000 \text{ LB}$$

DL + SHOCK LOAD (VERTICAL)

$$F_1 = W + W = 2W \\ = 30000 \text{ LB}$$

SADDLE LOAD

$$F_2 = \frac{F_1}{2} = 15000 \text{ LB}$$

THE HALF MODEL USED FOR THE UPPER SECTION ANALYSIS (BSC00PSA) IS USED TO EVALUATE THE SHELL. THE FILE WAS COPIED TO

FILE: BSC-1M1A

AND A SADDLE WAS ADDED. SINCE THIS IS A HALF MODEL, A 7500 LB LOAD IS APPLIED TO THE SADDLE IN THE X DIRECTION. NODAL LOADS ARE

$$F_{7564} = F_{7565} = 7500 \text{ LB}$$

$$F_{7565...568} = 1500 \text{ LB}$$

THE WOOD SADDLE IS 1 IN THICK. IT IS INPUT IN MESH 4 AND PLATE LAYER NO. 6.

PLOTS ON THE FOLLOWING SHEETS SHOW THAT THE MAX STRESS INTENSITY IN THE 1/4 IN SHELL IS ONLY 2070 PSI AND THE MAX DEFLECTION IS .01 IN

WHEN COMBINED WITH VACUUM (LOAD CASE 3) THE SHIPPING LOAD STRESS IN THE SHELL IS ONLY 2600 PSI (SEE PLOT ON P. 7. THIS SHOWS THAT THE VERTICAL SHOCK COULD BE 5 G'S OR MORE WITHOUT DAMAGING THE 1/4 IN SHELL

(LOAD CASE 2 IS VACUUM ALONE.)


22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



```


?#,130,140
Next Node 573
?D
Next Node 572
?-58.14,24,34
  572)   -58.14      24      34
Next Node 573
?-61.625,24,23.45
  573)   -61.625    24      23.45
Next Node 574
?-63.545,24,12.05
  574)   -63.545    24      12.05
Next Node 575
?-64.25,24,0
  575)   -64.25     24      0
Next Node 576
?#,130,140
Next Node 576
?#,564,575
Next Node 576
?█

```





↑ SADDLE

Auto	Blwup	Chge	Del
Exit	Gen	Help	List
Mult	Prnt	Rot	SCrn
Select	Undel	#	



IMAGES-3D
Ver. 3.0





Revision 0
Doc. No. V049-1-028
Page 5 of 8

Load Case
1

Wireframe Plot

11/30/95
11:29: 2

IMAGES-3D
Version 3.0




Revision 0
Doc. No. V049-1-028
Page 6 of 9

Load Case
1

Stress Contour Plot
Surf: Bottom
Stress Intensity

11/30/95
11:25: 6

IMAGES-3D
Version 3.0




Revision 0
Doc. No. V049-1-028
Page 7 of 8

Load Case
1

Displacement Contour Plot
DX

11/30/95
11:27:37

IMAGES-3D
Version 3.0




Load Case
3

Stress Contour Plot
Surf: Top
Stress Intensity



4/20/96
9:21:40

REV 0
Doc. No. V049-1-028
P. 8 of 8

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-029 PAGE 1 OF 5
REV.	DEO #	DATE	BY:	CHECK	TITLE: Beam Splitter Chamber - Deflections	
0	0024	12/6/95	RDC			
1	0237	8/2/96	RDC	WDB		
					BY: R. D. Ciatto	DEPT: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
PURPOSE: Compute estimated deflections at Beam Splitter 60.5 in Nozzles for vacuum loads.						
METHOD: Combine shell deflections with support deflections to obtain maximum estimated deflections at ports.						
ASSUMPTIONS: Bellows deflects with negligible force.						
INPUTS: LIGO project drawing V049-4-001 - Beam Splitter Chamber. LIGO project drawing V049-5-001 - Equipment Arrangement - Corner Station - Washington Calc. No. V049-1-066, Structural Design Criteria Calc. No. V049-1-022, BSC, FE Analysis of Lower Section Calc. No. V049-1-024, BSC, Design of Support Legs and Base Plates						
REFERENCES: See INPUTS						
CALCULATIONS: (SEE ATTACHED)						
CONCLUSIONS:						
NOTES: The basis for the Rev. 1 deflections is the final support structure.						



CORNER STATION KEY PLAN



ref. dwg.
V049-5-001

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



OPERATING CONDITIONS

1. ALL VACUUM
2. VERTEX SECTION VENTED
3. DIAGONAL SECTION VENTED

DEFLECTIONS RESULT FROM

- SHELL DISPLACEMENT MAX $\delta \approx .125$
rel. calc. V049-1-022

- SUPPORT DISPLACEMENT

$$\delta_{max} = \delta_x = .1524" \approx .15"$$

rel. calc. V049-1-024 pg. 18 of 35

DEFLECTIONS ARE IN INCHES



BSC No.	OP. COND. NO.	Port a		Port b		Port c		Port d	
		Δy	Δz	Δy	Δz	Δy	Δz	Δy	Δz
1	1	.125			.125	-.125			-.125
	2								
	3	.125			.125	-.125			-.125
2	1	.125			.125	-.125			-.125
	2								
	3	.125			.125	-.125			-.125
3	1	.125			.125	-.125			-.125
	2								
	3	.125			.125	-.125			-.125
4	1	.125			.125	-.125			-.125
	2	.125			.125	-.125			-.125
	3								



BSC No.	OP. COND. No.	Port a		Port b		Port c		Port d	
		Δy	Δz	Δy	Δz	Δy	Δz	Δy	Δz
7	1	.125	-.15		-.025	-.125	-.15		-.275
	2	.275	-.15	.15	-.025	.025	-.15	.15	-.275
	3	.125	-.15		-.025	-.125	-.15		-.275
8	1	.275		.15	.125	.025		.15	-.125
	2	.275	-.15	.15	-.025	.025	-.15	.15	-.275
	3	.275		.15	.125	.025		.15	-.125

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-040 PAGE 1 OF 7
REV.	DEO #	DATE	BY:	CHECK	TITLE: Buckling Analysis of Beam Splitter Chamber	
0	0128	1/29/94	AM	RDC		
					BY: Kyle Martini	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
<u>PURPOSE:</u> Evaluate the beam splitter chamber (BSC) for buckling modes.						
<u>METHOD:</u> Finite element method and hand calculation.						
<u>ASSUMPTIONS:</u> See attached.						
<u>INPUTS:</u> LIGO project drawings and sketches.						
<u>REFERENCES:</u> NASTRAN Finite Element Program Doc. No. V049-1-066, LIGO VACUUM EQUIP STRUCT. DES. CRITERIA						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> The minimum factor of safety against elastic buckling for vacuum loading is 5.9.						
<u>NOTES:</u> COMPUTER FILE: BMSPLY*.INP						

1.0 Hand Analysis


Assumption - (1) Extra material at nozzles replaces stiffness of vessel material removed

(2) pressure uniform over cylinder

(3) stiffeners are ignored

(4) cylinder length is from bottom head to connection between lower & upper beamsplitter $l = 91''$

From Roark 5th ed Table 35 case 19 b



Short tube of length l
ends held circular but otherwise
not constrained, no end loads

$$P_{cr} = 0.807 \frac{Et^2}{lr} \sqrt[4]{\left(\frac{1}{1-\nu^2}\right)^3 \frac{t^2}{r^2}}$$

$$t = 0.15''$$

$$l = 91''$$

$$\nu = 0.3$$

$$r = 52.75''$$

$$E = 29(10^6) \text{ psi}$$

$$P_{cr} = 127.4 \text{ psi}$$

$$F_r S = \frac{P_{cr}}{14.7} = \underline{\underline{8.67}}$$

REV 0
Doc. No. V049-1-040
P. 2 of 7

2.0 COMPUTER ANALYSIS

- a. The same length shell is analyzed using NASTRAN'S buckling program.
- b. The shell is $\frac{1}{2}$ " thick with the openings or holes for the 60" diameter tubes.
- c. The smaller nozzles are not modeled. It is assumed the stiffness of the nozzle replaces the stiffness removed by the hole.
- d. The stiffness of the tube nozzles are modeled as beams. Assuming the nozzles extend 3" and are $\frac{1}{2}$ " thick.
- e. The vessel junction with the bottom head and the junction with the top portion of the vessel are modeled as reinforcement beams $3" \times \frac{1}{2}"$.
- f. An external pressure of 14.7 psi is applied to all plate elements.
- g. An ^(vertical) axial ring load is applied to the bottom of the vessel and the top equal to $-PA$ where A is inside Area of vessel and $P = 14.7$ PSI

h. The vessel is restrained at its connection with the support legs.

i. Four configurations are analyzed, a four bellows model where no load is applied to the tube nozzle, a three bellows model where one nozzle is loaded, a two bellows model where two opposite nozzles are loaded, and two adjacent bellows loaded.

j. Except as describe above all other stiffeners are ignored.


k. The model is a 180°

3.0 Computer Results

<u>Model</u>	<u>Factor of Safety</u>
4 - bellows (Fig 1)	7.0
3 - bellows (Fig 2)	6.5
2 op bellows (Fig 3)	6.1
2 - adjacent bellows	5.9

5 1/29/96 MAX-DEF. = 1.0000000

5



REV 0
 DOC. NO. Y049-1-BV0
 P. 5 OF 7

HAM 1/1 SYMM MODEL


BUCKLING SOLUTION
 MODAL DEFOR. SUBCASE 2 MODE 5 EIGENV. 7.049044 MASS MODEL

Fig 1 - 4 Bellows Buckling Shape

5/7

6 1/29/76 MAX-DEF. = 1.00000000

5



HAM 1/1 SYMM MODEL

BUCKLING SOLUTION


MODAL DEFOR. SUBCASE 2 MODE 6 EIGENV. 6.476190 MASS MODEL

*REV D
DOC. NO. V0Y9.1-D10
P. 6 OF 7*

Fig 2 3 Bellows Buckling Diagram

617

6 1/29/96 MAX-DEF. = 1.00000000 6



HAM 1/1 SYMM MODEL

BUCKLING SOLUTION

MODAL DEFOR. SUBCASE 2 MODE 6 EIGENV. 6.128821 MASS MODEL

Rev 0
Doc. No. 1049-1-040
P. 7 of 7

Fig 3 2 Bellows Bottom View

1/16

PROCESS SYSTEMS INTERNATIONAL, INC.
WESTBOROUGH, MA

ENGINEERING
CALCULATIONS

NO: V049-1-069

PAGE 1 OF 9

REV.	DEO #	DATE	BY:	CHECK
1	0131	3-8-96	AGR	RDC

TITLE:
BEAM SPUTTER SUPPORT CLEVIS

By: AGT ROUSSOPOULOS | DEPT.: 744

PROJECT: LIGO

PROJECT NO: V59049

PURPOSE: DETERMINE THE STRUCTURAL INTEGRITY
OF THE BSC CLEVIS SUPPORT ASSEMBLY

METHOD: CLASSICAL STRESS ANALYSIS - MAX SHEAR STRESS THEORY

SUMPTIONS: SEE CALCS

INPUTS: V049-1-024

REFERENCES: DWGS: V049-4-023 + V049-4-001 DOC. NO.
ASME VIII, DIV 2, 1989 ED.
AISC, SCM - 9TH. ED.
V049-1-026, LIGO VAC. EQUIP. STRUCT. DESIGN CRITERIA

CALCULATIONS: (SEE ATTACHED)

CONCLUSIONS: STRUCTURAL SUPPORT OF CLEVIS ATTACHMENT + WELDS
ARE DESIGNED TO ASME VIII REQUIREMENTS

NOTES:

TABLE OF CONTENTS


	<u>PAGE</u>
1.- BSC SUPPORT DESIGN SKETCH.	3
2.- ALLOWABLE WELD STRESSES	4
3.- SUPPORT WELD ANALYSIS	6
3.1 • CLEVIS / LUG TO VESSEL WELD	6
3.2 • 8X8 STEEL TUBE LEG TO CLEVIS/LUG	8

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



1.0

BSC SUPPORT DESIGN SKETCH



22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



2. - ALLOWABLE WELD STRESSES

- ALLOWABLE WELD STRESS FOR BASE MATERIAL EVALUATIONS SHALL BE BASED ON SA 240 TYPE 304 AND IS ACCEPTABLE DUE TO DUAL CERTIFICATION OF 304/304L MATERIAL. I.C. 304 L SHALL, VIA CMTR'S, MEET THE MINIMUM YIELD AND TENSILE STRESS AND ALL OTHER SA MATERIAL REQUIREMENTS FOR 304.

- ALLOWABLE WELD STRESS IS BASED ON THE REQUIREMENTS OF ASME VIII, DIV 2, SECTION AD-920 "STRESS VALUES FOR WELD MATERIAL"

- DESIGN STRESS INTENSITY, S_m , FOR SA 240 TYPE 304 FROM PART AM, TABLE AHA-1:

$$S_m = 18,700 \text{ PSI AT } 400^\circ\text{F}$$

- STRESS INTENSITY REDUCTION FACTOR PER AD-920: = .5 FOR FILLET WELDS $\leq 1/2"$

2.1 - ALLOWABLE WELD STRESS INTENSITY:

$$S_{m, \text{allow}} = .5 (18,700) = 9,350 \text{ PSI}$$

2.2 - ALLOWABLE SHEAR STRESS:

- SHALL BE THE LESSEER OF THE FOLLOWING:

- PER AD-132.2 "PERIPHERY OF SECTION IN TORSION"

$$\tau \leq .8 S_{m, \text{allow}} = .8 (.5 S_m) = .4 S_m$$

$$\therefore \tau \leq .4 S_m = .4 (18,700) = 7,480 \text{ PSI}$$

OR

$$\tau \leq .6 S_{m, \text{allow}} = .6 (.5 S_m) = .3 S_m$$

$$\tau \leq .3 S_m = .3 (18,700) = 5,610 \text{ PSI FOR}$$

PURE SHEAR

REV 0
DOC. NO. V049-1-069
P. 4 OF 9



- PER AISC, TABLE J2.5, P. 5-70:

$\tau \leq .30 \times$ NOMINAL TENSILE STRENGTH OF WELD METAL. THIS VALUE WILL BE MULTIPLIED BY THE RATIO OF TENSILE STRESS OF THE BASE MATERIAL AT DESIGN TEMP. TO THE TENSILE OF THE BASE MATERIAL AT ROOM TEMP FOR REPRESENTATIVE DESIGN CONDITIONS.

$$\tau \leq .30 \times 75000 \left(\frac{S_{EHT}}{S_{ECOW}} \right)$$

$$\tau \leq .30 \times 75000 \left(\frac{63450}{82800} \right) = 17,242 \text{ PSI}$$

- CONCLUSION:

- $\tau_{\text{TORSION}} \leq .8 S_m = 7,480 \text{ PSI}$

- $\tau_{\text{PURE}} \leq .6 S_m = 5,610 \text{ PSI}$

2.3 - SUMMARY:

- TORSIONAL SHEAR: $\tau \leq 7,480 \text{ PSI} = .8 S_m$ (ALLOWED)

- PURE SHEAR: $\tau \leq 5,610 \text{ PSI} = .6 S_m$ (ALLOWED)

- LOCAL PRIMARY MEMBRANE STRESS: $P_L \leq 1.5 S_m$
(REF: AD 140 (c))

$$P_L \leq 1.5 (.5 S_m) = 1.5 (.5) (18,700) = 14,025 \text{ PSI}$$

- PRIMARY BENDING STRESS: $P_b \leq 1.5 S_m$
(REF: AD 140 (d))

$$P_b \leq 14,025 \text{ PSI}$$

- $P_L + P_b \leq 1.5 S_m = 14,025 \text{ PSI}$



3 - SUPPORT WELD ANALYSIS


REF: BSC SUPPORT DESIGN SKETCH
PSI DWG. V049-4-043
" " V049-4-001

• THE FOLLOWING ARE THE WORSE CASE LOADS FOR BEAM #2, NODE 3 AS CALCULATED IN REF. DOC. NO. V049-1-024, P.19

$$F_x = 220\# ; F_y = 11,930\# ; F_z = 2444\#$$

$$M_z = 314,500\text{ IN}\cdot\#$$

3.1 - CLEVIS / LUG TO VESSEL WELD



$$\rho = [8^2 + 8^2]^{1/2} = 5.65"$$

$$I_{xrot} = \frac{4bh^3}{12} = \frac{4(1.707)(.5)(8)^3}{12} = 60.3 \text{ IN}^4$$

$$I_{yrot} = 2 \left\{ \frac{8[2(1.707)(.5)]^3}{12} + (2)(1.707)(.5)(8)^2 \right\} = 181.5 \text{ IN}^4$$

$$J = I_{xrot} + I_{yrot} = 60.3 + 181.5 = 241.8 \text{ IN}^4$$

• TORSION:

$$T = M_z = 314,500 \text{ IN}\cdot\#$$

$$\tau = \frac{T\rho}{J} = \frac{314,500(5.65)}{241.8} = 7,349 \text{ PSI} < .8S_m = 7,480 \text{ PSI} \therefore \text{OK}$$

• SHEAR: $A_s = 4 \times (8)(1.707)(.5) = 11.31 \text{ IN}^2$

$$\tau_{sx} = F_x / A_s = (220) / 11.31 = 20 \text{ PSI} < .6S_m = 5,610 \text{ PSI} \therefore \text{OK}$$

$$\tau_{sy} = F_y / A_s = (11,930) / 11.31 = 1,055 \text{ PSI} < .6S_m = 5,610 \text{ PSI} \therefore \text{OK}$$

• TOTAL COMBINED SHEAR STRESS:

$$\tau_{STOT} = \sqrt{(\tau + \tau_{sx})^2 + \tau_{sy}^2}$$

$$\tau_{STOT} = \sqrt{(7,349 + 20)^2 + (1,055)^2} = 7,444 \text{ PSI}$$

$$< .8 S_m = 7,480 \text{ PSI} \therefore \text{OK}$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



3.1 CONT

- TENSILE / COMPRESSIVE NORMAL STRESS:

$$\sigma_{TC} = \frac{F_z}{A_g} = \frac{2449}{11.31} = 216 \text{ PSI}$$

- COMBINED STRESS:

$$\tau = \sqrt{216^2 + 7444^2} = 7447 \text{ PSI} < S_m = 7400 \text{ PSI}$$

∴ OK

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



REV 0
Doc. No. V049-1-069
P. 7 OF 9



3.2 - 8x8 STEEL TUBE LEG TO CLEVIS/LUG

• SHEAR: $F_3 = \sqrt{F_1^2 + F_2^2} = \sqrt{(11930)^2 + (2449)^2} = 12,170 \#$

$$\tau_s = \frac{F_3}{A_s} = \frac{12,170}{2[.707(4.375)(8 + 2 \times 5.25)]} = 1,064 \text{ PSI}$$

$< .6 S_m = 5,610 \text{ PSI} \therefore \text{OK}$

• BENDING:



APPLIED MOMENT M PER WELD LINE $M_z/2 = (314,500/2) = 157,250 \text{ IN-}\#$

$$\tau_b = \frac{M_z}{I/c} = \frac{M_z c}{I} = \frac{157,250(4)}{58.5} = 10,746 \text{ PSI}$$

$< 1.5 S_m = 14,025 \text{ PSI}$
 $\therefore \text{OK}$

WHERE:

$$I = \frac{bd^3 - h^3(b-t)}{12} \quad \text{REF: MACHINERY HDBK; 17ED; P.364}$$

$$I = [(5.25)(8)^3 - (7.38)^3(5.25 - .31)]/12 = 58.5 \text{ IN}^4$$

$$b = 5.25"; \quad d = 8"; \quad t = .707(4.375) = .31"$$

$$h = 8 - 2 \times (.707)(4.375) = 7.38"$$

$$c = 4"$$

• TENSILE / COMPRESSIVE

$$\sigma_{T/C} = \frac{F_x}{A_s} = \frac{220}{11.44} = 19 \text{ PSI}$$

• COMBINED STRESS:

$$\sigma = \frac{(10,746 + 19)}{2} \pm \sqrt{\left(\frac{10,746 + 19}{2}\right)^2 + (1064)^2}$$

$$\sigma_{1,2} = 5383 \pm 5487$$

$$\sigma_1 = 10,870 \text{ PSI} ; \sigma_2 = -104 \text{ PSI} ; \sigma_3 = 0$$

• MAX. STRESS INTENSITY:

$$S_{\text{MAX}} = 10,780 - (-104) = 10,884 \text{ PSI}$$

$$< 1.5 S_m = 14,025 \text{ PSI} \therefore \text{OK}$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



REV 0
DOC. NO. V049-1-069
P. 9 OF 9

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-104 PAGE 1 OF 9
REV.	DEO #	DATE	BY:	CHECK	TITLE: Beam Splitter Chamber - Nozzle D Analysis for 200 kg Force	
0	0293	7/2/96	ROC	WDB		
					BY: R. D. Ciatto	DEPT: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
<u>PURPOSE:</u> Evaluate nozzle D of the BSC for 200 kg load specified by the LIGO project.						
<u>METHOD:</u> Hand calculations for overall stress analysis of nozzle and FE analysis to determine detailed stresses.						
<u>ASSUMPTIONS:</u> 1. Force is transverse to nozzle centerline. 2. Force is applied uniformly about circumference at end of nozzle.						
<u>INPUTS:</u> LIGO project drawing V049-4-001 - Beam Splitter Chamber. Calc. No. V049-1-066, Structural Design Criteria						
<u>REFERENCES:</u> See INPUTS						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> The resulting stresses from the imposed nozzle D forces are low and the structural integrity of the nozzle and shell are not affected by this load.						
<u>NOTES:</u> See load cases 4 and 5 of computer file BMSPLI12.* for the Images FE model results.						

ANALYSIS OF 200 KG FORCE ON NOZZLE
D RESULTING FROM LIGD BELLOWS

ASSUMPTIONS

FORCE IS TRANSVERSE TO NOZZLE &

FORCE IS APPLIED UNIFORMLY

SHEAR FORCE

$$\begin{aligned}V &= 200 \text{ Kg} \\ &= 2.205(200) = 441 \text{ LB}\end{aligned}$$

NOZZLE D CROSS SECTION AREA

$$A = \pi D t$$

$$D = \text{MEAN DIAH}$$

$$= 14" - t$$

$$t = .125$$

$$D = 13.875$$

$$A = \pi (13.875)(.125)$$

$$= 5.45 \text{ IN}^2$$



AVERAGE SHEAR STRESS


$$T = \frac{V}{A} = \frac{441}{5.45}$$

= 81 PSI - NEGLIGIBLE

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



BENDING MOMENT AT NOZZLE TO SHELL WELD



REF DWG V049-4-001 FOR DIMENSIONS

$$r = 52 \text{ IN}$$

$$y^2 + 40^2 = 52^2$$
$$y = 33.2$$

$$s = 48.5 - 33.2$$
$$= 15.3" = \text{MAX MOMENT ARM AT SHELL}$$

$$M = 441(15.3) = 6747 \text{ IN-LB}$$



$$I = \pi R^3 t$$

$$R = \frac{13.875}{2} = 6.94 \text{ IN}$$

$$I = \pi (6.94)^3 (.125) = 131 \text{ IN}^4$$

BENDING STRESS IN NOZZLE

$$f_b = \frac{MR}{I} = \frac{6747 (6.94)}{131}$$

$\approx 360 \text{ PSI} - \text{NEGLECTIBLE}$

SHEAR STRESS IN NOZZLE TO SHELL WELD DUE TO BENDING MOMENT.
 MAX FORCE PER IN

$$F_v = \frac{MR}{I}$$

$$I = \frac{131}{.125} t = 1048 t \text{ IN}^4$$

$$F_v = \frac{6747 (6.94)}{1048} \approx 45 \frac{\#}{\text{IN}}$$

MAX SHEAR STRESS FOR $\frac{1}{8}$ " FILLET WELD

$$f_v = \frac{45}{.125 (1.707)} = 505 \text{ PSI SR}$$

d

FROM CALC V049-1-026, P. 3, THE
 MAX WELD SHEAR STRESS DUE TO THE
 END CAP PRESSURE IS 582 PSI
 TOTAL MAX WELD SHEAR STRESS
 IS

$$\begin{aligned}
 f_v &= 505 + 582 \\
 &= 1087 \text{ psi} \quad \text{OK}
 \end{aligned}$$

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



FINITE ELEMENT ANALYSIS OF THE
200 KG SHEAR LOAD

THE FE MODEL, BHSPLI12 WILL BE
USED TO ANALYZE THE EFFECTS OF
THE SHEAR FORCE. LOAD CASE 4
WILL EVALUATE THE X-DIRECTION LOADS
AND LOAD CASE 5 WILL EVALUATE
THE Z DIRECTION LOADS. THE LOAD
WILL BE APPLIED TO THE 8 NODES
AROUND THE NOZZLE AT THE CONFLAT
FLANGE. SEE PLOT ON FOLLOWING
SHEET.



$$F_i = 55.125 \#$$

FROM NODE 2047 TO NODES 2054




IMAGES-3D
Ver. 3.0
Geometry Plot

Y range
?48,51
Z range
?23,44
?i
X range
?-55,-35
Y range
?48.5,51
Z range
?23,44
?r,20
?



Auto	Blowup	Elem#	Exit	Full	Help	Local	Move
Node	Node#	Plot	Range	Rest	Rotate	Shrink	Slice

IMAGES-3D
Version 3.0





Revision No. 0
Doc. No. V049-1-104
Page 8 of 9

Load Case
5

Stress Contour Plot
Surf: Top
Stress Intensity

7/1/96
16:1:57

IMAGES-3D
Version 3.0



Load Case
4

Stress Contour Plot
Surf: Bottom
Stress Intensity

7/ 1/96
16: 7:51

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: <i>V049-1-031</i> PAGE 1 OF 2
REV.	DEO #	DATE	BY:	CHECK	Vacuum Equipment Seismic Acceleration	
0	0.12.8	12/6/95	RDC	WDB		
					BY: <i>R.D. CIARRO</i>	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
PURPOSE: To determine maximum seismic acceleration factors for design of LIGO vacuum equipment.						
METHOD: Hand calculation using applicable construction code.						
ASSUMPTIONS:						
INPUTS: LIGO - E940002-02-4, Vacuum Equipment Specification, Rev. 2, September 6, 1995						
REFERENCES: 1. LIGO Specification (above) 2. ASCE 7-88, American Society of Civil Engineers - Minimum Design Loads for Buildings and Other Structures 3. Doc. No. <i>V049-1-066</i> , <i>LIGO VACUUM EQUIP. STRUCT. DESIGN CRITERIA.</i>						
CALCULATIONS: (SEE ATTACHED)						
CONCLUSIONS: The maximum seismic acceleration factor is .05625G. This factor will be applied to equipment weight in static analyses.						
NOTES: The maximum seismic zone for LIGO equipment is Zone 1.						

SEISMIC ACCEL FACTOR PER ASCE 7-88
ZONE = 1, SECTION 9.10 APPLIES

$$F_p = Z I C_p W_p \quad \text{EQ 16, ASCE 7-88}$$

$$Z = 3/16 \quad \text{TABLE 21}$$

$$I = 1.0 \quad \text{TABLE 22}$$

$$C_p = .3 \quad \text{FOR EQUIPMENT TABLE 25}$$

$$W_p = \text{EQUIPMENT WEIGHT}$$

$$F_p = 3/16 (1.0) (.3) W_p \\ = .05625 W_p$$

∴ SEISMIC ACCEL = .05625 G (LATERAL)

FORCES IN PRINCIPAL ORTHOGONAL
DIRECTIONS ARE NON CONCURRENT
(ASCE 7-88, 9.4.1)

REV. 0

DOC No. V049-1-031
Pg. 2 of 2

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-032 PAGE 1 OF 23
REV.	DEO #	DATE	BY:	CHECK	TITLE: Component Interface Loads	
0	139	12/29/95	RDC	AGR		
					BY: R. D. CIRITO	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
<p>PURPOSE: Determine vacuum forces on component flanges due to the venting of certain sections of the system while other sections remain under vacuum.</p>						
<p>METHOD: Hand calculation methods of statics are used to determine unbalanced vacuum loads on:</p> <ul style="list-style-type: none"> • Beam Splitter Chambers • Horizontal Access Modules • Gate Valves • 80K Pumps 						
<p>ASSUMPTIONS: Bellows impose negligible axial forces on components. Adapters and valves have no axial restraint.</p>						
<p>INPUTS: PSI Equipment Arrangement Plans and spool piece dwgs. Atmospheric pressure = 14.7 psi.</p>						
<p>REFERENCES: Senior Flexonics, Inc. - Prelim. Design Calculations of LIGO Vacuum Equipment - Bellows (attached).</p>						
<p>CALCULATIONS: (See Attachment)</p>						
<p>CONCLUSIONS: See summary on following sheet.</p>						
<p>NOTES: This calculation may be used to determine vacuum forces on adapters, spool pieces and tubes.</p>						

SUMMARY

THE MAXIMUM UNBALANCED FORCES ON THE
BEAM SPLITTER CHAMBERS (BSC) ARE
ON BSC 7 & BSC 8 OF THE
WASHINGTON CORNER STATION - (SEE PAGES 7 & 8)
THE MAX FLANGE TENSION IS 29.5K ON THE 60.5 IN FLANGE


THE MAXIMUM UNBALANCED FORCE ON
THE HORIZ. ACCESS MODULES (HAM) ARE
ON HAMS AT THE ENDS OF THE
VACUUM SYSTEM. $F = 45.5K$, NO TENSION ON
FLANGES

FOR GATE VALVES, BOLTED FLANGES CAN
HAVE TENSILE LOAD FROM FULL VACUUM,
THE SAME IS TRUE FOR WELDED FLANGES,

$$F = 29.5K \text{ FOR } 48.25" \text{ VALVE}$$
$$F = 25.4K \text{ " } 44.63" \text{ VALVE}$$

FOR THE 80K PUMPS THE MAXIMUM
FLANGE FORCE IS 25.4K IN TENSION OR
COMPRESSION.

UNBALANCED FORCES RESULTING FROM BELLOWS



$$F = P EA$$

$$P = -14.7 \text{ psi}$$

$EA =$ PRESSURE AREA OF BELLOWS
CORRESPONDING TO MEAN
DIAM. OF BELLOWS, D_m
(SEE ATTACHMENT)

48 IN TUBE (48 IN ID)

$$EA = 1983 \text{ IN}^2$$

$$F = -14.7 (1983) = -29,150 \text{ LB} = -29.2 \text{ K}$$

60 IN TUBE (60 IN ID)

$$EA = 3043$$

$$F = -14.7 (3043) = -44,730 \text{ LB} = -44.7 \text{ K}$$

72 IN TUBE (72 IN ID)

$$EA = 4330$$

$$F = -14.7 (4330) = -63,650 \text{ LB} = -63.7 \text{ K}$$

FROM THE PRESSURE AREA, EA, IT WAS DETERMINED THAT THE MEAN DIAM, D_M , IS ABOUT 2.25 IN LARGER THAN THE TUBE ID. EX. FOR 48 IN

$$r^2 = \frac{EA}{\pi} = \frac{1983}{\pi}$$

$$r = \left(\frac{1983}{\pi} \right)^{\frac{1}{2}} = 25.12$$

$$D_M = 2r = 50.25 > 48 \text{ IN}$$

FORCES FOR REVISED TUBE DIAMETERS ARE:

44.63 IN TUBE

$$D_M = 44.63 + 2.25 = 46.88 \text{ IN}$$

$$\begin{aligned} F &= p \pi \frac{D_M^2}{4} \\ &= 14.7 \frac{\pi}{4} (46.88)^2 \\ &= 25,370 \text{ LB} = 25.4 \text{ K} \end{aligned}$$

NEGATIVE POS / NEG SIGN FULL MEAN, VAC LOAD PULLS FROM SUPPORTED COMPONENT TOWARD BELLOW WHERE THERE IS A CLOSED VALVE OR IT PUSHES ON BACK SIDE OF VESSEL TOWARD BELLOW.

48.25 IN TUBE

$$D_M = 48.25 + 2.25 = 50.5 \text{ IN}$$

$$F = 14.7 \frac{\pi}{4} (50.5)^2 = 29,440 \text{ LB} = 29.44 \text{ K}$$

60.5 IN TUBE

$$D_M = 60.5 + 2.25 = 62.75$$

$$F = 14.7 \frac{\pi}{4} (62.75)^2 = 45,460 \text{ LB} = 45.46 \text{ K}$$

72.25 IN TUBE

$$D_M = 72.25 + 2.25 = 74.5 \text{ IN}$$

$$F = 14.7 \pi \frac{(74.5)^2}{4} = 64080 \text{ LB} = 64.1 \text{ K}$$


22-141 50 SHEETS
22-142 100 SHEETS
22-146 200 SHEETS



WASHINGTON CORNER STATION
REF. DWG V049-5-001 FOR LAYOUT OF EQUIPMENT
& FELLOWS

BEAM SPACIAL CHIMNEYS

BSE 1




NET FORCE

$$F = 45.5 - 29.5 \\ = 16 \text{ K}$$

NO TENSION ON
FLANGES

BSC2




NO UNBALANCED
LOADS EXCEPT FOR
OFFSETS

NO TENSION ON
FLANGES

* NO EFFECT - BELLOWS ELEVATION SAME
AS BSC PORT


BSC3



NET FORCE = 16^K

NO TENSION ON
FLANGES

BSC 8




29.5 k TEN ON LOWER FLANGE WHEN BSC IS VENTED

WHEN AREA BELOW GVI IS VENTED, UNBALANCED LOAD IS 45.5 k TOWARD TOP OF DIAGRAM.

WASHINGTON CRANER STATION COPT,
HORIZONTAL BEAMS MODULES

HAM 1




NO TENSION ON FLANGES

22-101 50 SHEETS
22-102 100 SHEETS
22-103 200 SHEETS




HAM 2



NO UNBALANCED FORCE

HAM 3




NO UNBALANCED FORCE*

- HAM 4 - SAME AS HAM 3 - NO UNBALANCED FORCE*
- HAM 5 - SAME AS HAM 2 - NO UNBALANCED FORCE
- HAM 6 - SAME AS HAM 1 - UNBALANCED FORCE = 15.5 K
- HAM 7 - " " " " " "
- HAM 8 - " " HAM 2 - NO UNBALANCED FORCE
- HAM 9 - SAME AS HAM 3 - " " " *
- HAM 10 - " " " " " *
- HAM 11 - SAME AS HAM 2 - " " " "
- HAM 12 - SAME AS HAM 1 - UNBALANCED FORCE = 15.5 K

WASHINGTON CORNER STATION CONT.

GATE VALVES

GV1




TENSILE FORCE ON VALVE BOLTED FLANGE IS 29.5K

OR COMPRESSIVE LOAD ON FLANGE IS 29.5K WHEN OTHER SIDE IS VENTED

GV2 - SAME AS GV1


GV3



FORCES ON BOLTED FLANGES ARE SAME AS GV1

GV 4

AXIAL REST




FORGED OR BOLTED
FLANGES ARE SAME AS GV 1

22-141 100 SERIES
22-142 100 SERIES
22-143 200 SERIES



GV 5




ASSUMED AXIAL REST

80K LONG PUMP

FLANGE IN TENSION
FOR CASE SHOWN

GV 6



TENSION OR COMP
ON WELDED NOZZLE
CONNECTION. NO
LOAD ON BOLTED
FLANGE.


GV 7 - SAME AS GV 5

GV 8 SAME AS GV 6

80K LONG PUMPS. SEE SPECIFICS FOR GV 5.
MAX FLANGE TENSION FOR 44.63 IN FLANGE
IS 25.4 K. COMPRESSIVE FORCE ON FLANGE HAS
SAME MAGNITUDE

WASHINGTON MID STATION
REF. DWG V049-5-004

BSC




NO UNBALANCED
LOAD

GATE VALVES. ALL GV AT WA MID ST ARE 4" W/
BOLTED FLANGE CONNECTIONS. MAX TEN ON
FLANGE IS SAME AS GV 6 ABOVE, 25.4 K.

25-124 50 SHEETS
25-122 180 SHEETS
25-124 200 SHEETS
25-124 200 SHEETS

WA MID STA (CONT.)


80K SHUNT PUMPS



VALUE AT BEAM TUBE ANCHOR WELDS ON ONE SIDE. SEE GUG ON PREVIOUS SHEET

WASHINGTON/LOUISVILLE END STATIONS
REF DWG V049-5-005

BSC



GATE VALVES. ALL VALVES HAVE 44.63 IN ID FLANGES. TENSION FORCE = 25.4K. VALUE AT BEAM TUBE ANCHOR WELDS ON ONE SIDE. SEE GUG FOR WARS

80K SHUNT PUMP. SAME AS ABOVE. MAX FLANGE LOAD = 25.4K TOW OR COMP.


50 SHEETS
100 SHEETS
200 SHEETS



LOUISIANA CORNER STATION
REF DWG V049-5-003

BEAM SPLITTER CHAMBERS

BSC 1



UNBALANCED FORCE
= 45.5 - 29.5 = 16 k

NO TON ON FLANGES

BSC 2 - SAME AS UACS BSC 2 - NO UNBALANCED LOADS

BSC 3 - SAME AS BSC 1, ABOVE, 16 k UNBAL FORCE, NO TENSION ON FLANGES.

HORIZ. ACCESS MODULES

HAM 1 - SAME AS UACS HAM 1, 45.5 k UNBAL. LOAD.

HAM 2 - " " " HAM 2, NO UNBAL. FORCE

HAM 3 - " " " " 3, " " " *

HAM 4 - " " " " 4, " " " *

HAM 5 - " " " " 5, " " " "

HAM 6 - " " " " 6, 45.5 k UNBAL LOAD

* DEFLECT = 3.94" ON BSC SIDE

22-141 20 SHEETS
22-142 100 SHEETS
22-143 200 SHEETS
22-144 300 SHEETS
COPY

LA CORNER STA CONT


80K LONG PUMP . SEE SHEET FOR GV3
MAX FLOWING FORCE IS 25.4K TEN OR
COMP.

50 SHEETS
100 SHEETS
200 SHEETS

22-104
22-102
22-106

LA MID POINT

THE ONLY COMPONENT AT THIS LOCATION IS
A BUTT WELDED 48" VALVE



$$F = 29.5K$$

(ASSUMES BELLOWS)


22-141 50 SHEETS
22-142 100 SHEETS
22-143 200 SHEETS



ATTACHMENT

THE FOLLOWING SHEETS ARE PRELIMINARY
SKETCHES AND DESIGN CALCULATIONS FOR
BELLOWS BY SENIOR FLEXONICS, INC.

THE PRESSURE AREA, EA , IS GIVEN
FOR EACH SIZE BELLOW.




NOTES:

- 1) BUILT TO EJMA STANDARD
- 2) VISUAL INSPECTION FOR BELLOWS
- 3) VACUUM TEST IS NOT INCLUDED ON BID

Revision 0
 Doc. No. V049-1-032
 Page 18 of 23

No. Req'd. 18

P/N	QTY.	DESCRIPTION	MATERIAL	GENERAL SPECIFICATIONS	CUSTOMER		REV.
9				DESIGN PRESS.	15 PSIG/FV	SENIOR FLEXONICS INC. EXPANSION JOINT DIVISION New Braunfels, TX PROCESS SYSTEMS	0
8			DESIGN TEMP.	347F			
7			SERVICE	-			
6	-	-	EFF. AREA	1983 In. sq			
5	-	-	EXPANSION	-			
4	-	-	COMPRESSION	1 3/4"			
3	4	BELLOWS ADJUSTMENT RODS 3/4"φ	A479-304L	LATERAL OFFSET	-		
2	2	WELD ENDS 48"φ 1/4" THK	A240-304L	ANGULAR ROT.	-		
1	1	BELLOWS 48"φ 1-PLY 20Ga	A240-304L	TEST PRESSURE	SOAP & AIR		
				WEIGHT	182 LBS.		
				THIS DESIGN IS THE PROPERTY OF FLEXONICS THE REPRODUCTION, MANUFACTURE OR USE OF ANY ASSEMBLY, SUB-ASSEMBLY OR PART IS PERMITTED ONLY IF AUTHORIZED BY FLEXONICS.		DRAWN BY: LDC QUOTE NO.: 5/26/LC DATE: 5/26/95 SK. NO.: C	



NOTES:

- 1) BUILT TO EJMA STANDARD
- 2) VISUAL INSPECTION FOR BELLOWS
- 3) VACUUM TEST IS NOT INCLUDED ON BID

Revision 0
 Doc. No. V049-1-032
 Page 19 of 23


No. Req'd. 26

P/N	QTY.	DESCRIPTION	MATERIAL	GENERAL SPECIFICATIONS	
9				DESIGN PRESS.	15 PSIG/FV
8				DESIGN TEMP.	347°F
7				SERVICE	-
6	-			EFF. AREA	3043 In sq
5	-			EXPANSION	-
4	-			COMPRESSION	1 3/4"
3	4	BELLOWS ADJUSTMENT RODS 3/4"φ	A479-304L	LATERAL OFFSET	-
2	2	WELD ENDS 60"φ 1/4" THK	A240-304L	ANGULAR ROT.	-
1	1	BELLOWS 60"φ 1-PLY 20Ga	A240-304L	TEST PRESSURE	SOAP & AIR
				WEIGHT	225 LBS.
				THIS DESIGN IS THE PROPERTY OF FLEXONICS. THE REPRODUCTION, MANUFACTURE OR USE OF ANY ASSEMBLY, SUB-ASSEMBLY OR PART IS PERMITTED ONLY IF AUTHORIZED BY FLEXONICS.	
				DRAWN BY:	QUOTE NO.:
				LDC	5/26/LC
				DATE:	SK. NO.:
				5/26/95	B
				REV.	0



CUSTOMER
PROCESS SYSTEMS

TITLE 60in BELLOWS




NOTES:

- 1) BUILT TO EJMA STANDARD
- 2) VISUAL INSPECTION FOR BELLOWS
- 3) VACUUM TEST IS NOT INCLUDED ON BID

Revision 0
 Doc. No. V049-1-032
 Page 20 of 23

No. Req'd. 18

				GENERAL SPECIFICATIONS			
9				DESIGN PRESS.	15 PSIG/FV	 SENIOR FLEXONICS INC. EXPANSION JOINT DIVISION New Braunfels, TX CUSTOMER PROCESS SYSTEMS TITLE 72in BELLOWS DRAWN BY: LDC QUOTE NO.: 5/26/LC DATE: 5/28/95 SK. NO.: A REV. 0	
8				DESIGN TEMP.	347F		
7				SERVICE	-		
6	-	-		EFF. AREA	230 in. sq		
5	-	-		EXPANSION	-		
4	-	-		COMPRESSION	1 3/4"		
3	4	BELLOWS ADJUSTMENT RODS 3/4"φ	A479-304L	LATERAL OFFSET	-		
2	2	WELD ENDS 72"φ 1/4" THK	A240-304L	ANGULAR ROT.	-		
1	1	BELLOWS 72"φ 1-PLY 20Ga	A240-304L	TEST PRESSURE	SOAP & AIR		
				WEIGHT	250 LBS.		
P/N	QTY.	DESCRIPTION	MATERIAL	<small>THIS DESIGN IS THE PROPERTY OF FLEXONICS THE REPRODUCTION, MANUFACTURE OR USE OF ANY ASSEMBLY, SUB-ASSEMBLY OR PART IS PERMITTED ONLY IF AUTHORIZED BY FLEXONICS.</small>			

SENIOR FLEXONICS
CIRCULAR BELLOWS
(UNREINFORCED SINGLE)

BD

CUSTOMER: PROCESS SYSTEMS

JOB #:

DATE : 5/25/95


48in E.J.

RUN BY: LDC

INPUTED DATA

- 1) Db = I.D. OF BELLOWS = 48 in
- 2) n = NUMBER OF PLYS = 1
- 3) t = NOM. THK. OF 1 PLY = .0359 in
- 4) q = CONVOLUTION PITCH = 2 in
- 5) w = CONV HEIGHT (or OD) = 2.25 in
- 6) N = NO. OF CONVOLUTIONS = 2
- 7) P = PRESSURE = 15 psig
- 8) T = TEMPERATURE = 347 deg F
- 9) Lt = LENGTH TANGENT = 1.5 in
- 10) tc = THICKNESS OF COLLAR = 0 in
- 11) Lc = LENGTH COLLAR = 0 in
- 12) ~~Ee = AXIAL EXTENSION = 0 in~~
- 13) Ec = AXIAL COMPRESSION = 1.5 in
- 14) Y+ = +ve LATERAL OFFSET = 0 in
- 15) Y- = -ve LATERAL OFFSET = 0 in
- 16) AN = ANGULAR ROTATION = 0 deg

MATERIAL INFORMATION
BELLOWS MATERIAL SECT. VIII
SA240-304
C-Mod. of E. = 2.83E+07
H-Mod. of E. = 2.6865E+07
Sa = 16412 psi



RESULTS

SPRING RATES

THEORETICAL SPRING RATE = 2,979.37 lbf/in
WORKING SPRING RATE = 1,604.44 lbf/in
LATERAL SPRING RATE = 6.077E+05 lbf/in
LATERAL MOMENT RATE = 1.215E+06 in-lbs/in
ANGULAR MOMENT RATE = 8,838.58 in-lbs/deg
TORSION MOMENT RATE = 3.955E+07 in-lbs/deg

STRESSES EJMA

S1 = 7644 psi
S1' = N/A
S2 = 3804 psi
S2' = N/A
S2'' = N/A
S3 = 480.5 psi
S4(.35) = 7007 psi
S5 = 784.7 psi
S6 = 140900 psi
ST = 156000 psi

MOVEMENTS

CONVOLUTION GAP = 0.96410 in/conv.
COMPRESSION DUE TO AXIAL MOVEMENT = 0.75000
EXTENSION DUE TO AXIAL MOVEMENT = 0.00000
AXIAL DISP. DUE TO LATERAL OFFSET = 0.00000
AXIAL DISP. DUE TO ANG. ROTATION = 0.00000
MAX. EQUIVALENT AXIAL COMPRESSION = 0.75000
MAX. EQUIVALENT AXIAL EXTENSION = 0.00000
MAX. EQUIVALENT AXIAL MOVEMENT = 0.75000

EJMA FACTORS

Cp = .6501
Cf = 1.463
Cd = 1.74
Cr = N/A
Ct = 1 0
EA = 1983 in^2
Wt. = 17.34 lbs.
LCW = N/A

OTHER DATA

CYCLE LIFE = 19,316 cycles
SQUIRM PRESSURE COLD / 2.25 = 838 psig
SQUIRM PRESSURE HOT / 2.25 = 795.5 psig
EQUIV. PIPE WALL THICKNESS = .8706 in

SENIOR FLEXONICS
CIRCULAR BELLOWS
(UNREINFORCED SINGLE)

BD

CUSTOMER: PROCESS SYSTEMS

JOB #:

DATE : 5/25/95

60in E.J.


RUN BY: LDC

INPUTED DATA

- 1) Db = I.D. OF BELLOWS = 60 in
- 2) n = NUMBER OF PLYS = 1
- 3) t = NOM. THK. OF 1 PLY = .0359 in
- 4) q = CONVOLUTION PITCH = 2 in
- 5) w = CONV HEIGHT (or OD) = 2.25 in
- 6) N = NO. OF CONVOLUTIONS = 2
- 7) P = PRESSURE = 15 psig
- 8) T = TEMPERATURE = 347 deg F
- 9) Lt = LENGTH TANGENT = 1.5 in
- 10) tc = THICKNESS OF COLLAR = 0 in
- 11) Lc = LENGTH COLLAR = 0 in
- 12) Ee = AXIAL EXTENSION = 0 in
- 13) Ec = AXIAL COMPRESSION = 1.5 in
- 14) Y+ = +ve LATERAL OFFSET = 0 in
- 15) Y- = -ve LATERAL OFFSET = 0 in
- 16) AN = ANGULAR ROTATION = 0 deg

MATERIAL INFORMATION

BELLOWS MATERIAL SECT. VIII
SA240-304
C-Mod. of E. = 2.83E+07
H-Mod. of E. = 2.6865E+07
Sa = 16412 psi



RESULTS

SPRING RATES

- THEORETICAL SPRING RATE = 3,633.83 lbf/in
- WORKING SPRING RATE = 1,945.34 lbf/in
- LATERAL SPRING RATE = 1.131E+06 lbf/in
- LATERAL MOMENT RATE = 2.261E+06 in-lbs/in
- ANGULAR MOMENT RATE = 16,446.06 in-lbs/deg
- TORSION MOMENT RATE = 7.717E+07 in-lbs/deg

STRESSES EJMA

- S1 = 8545 psi
- S1' = N/A
- S2 = 4692 psi
- S2' = N/A
- S2'' = N/A
- S3 = 478.5 psi
- S4(.35) = 7160 psi
- S5 = 769.2 psi
- S6 = 145600 psi
- ST = 161100 psi

MOVEMENTS

- CONVOLUTION GAP = 0.96410 in/conv.
- COMPRESSION DUE TO AXIAL MOVEMENT = 0.75000
- EXTENSION DUE TO AXIAL MOVEMENT = 0.00000
- AXIAL DISP. DUE TO LATERAL OFFSET = 0.00000
- AXIAL DISP. DUE TO ANG. ROTATION = 0.00000
- MAX. EQUIVALENT AXIAL COMPRESSION = 0.75000
- MAX. EQUIVALENT AXIAL EXTENSION = 0.00000
- MAX. EQUIVALENT AXIAL MOVEMENT = 0.75000

EJMA FACTORS

- Cp = .6701
- Cf = 1.506
- Cd = 1.691
- Cr = N/A
- Ct = 1 0
- EA = 3043 in^2
- Wt. = 21.67 lbs.
- LCW = N/A

OTHER DATA

- CYCLE LIFE = 16,408 cycles
- SQUIRM PRESSURE COLD / 2.25 = 1022 psig
- SQUIRM PRESSURE HOT / 2.25 = 970.3 psig
- EQUIV. PIPE WALL THICKNESS = .8706 in

SEEL
W/FIG. 7

SAME "I" AS EQUAL LATH. OF PIPE.

SENIOR FLEXONICS
CIRCULAR BELLOWS
(UNREINFORCED SINGLE)

BD

CUSTOMER: PROCESS SYSTEMS

JOB #:

DATE: 5/25/95

721n E.J.

RUN BY: LDC

INPUTED DATA

1) Db = I.D. OF BELLOWS = 72 in
 2) n = NUMBER OF PLYS = 1
 3) t = NOM. THK. OF 1 PLY = .0359 in
 4) q = CONVOLUTION PITCH = 2 in
 5) w = CONV HEIGHT (or OD) = 2.25 in
 6) N = NO. OF CONVOLUTIONS = 2
 7) P = PRESSURE = 15 psig
 8) T = TEMPERATURE = 347 deg F
 9) Lt = LENGTH TANGENT = 1.5 in
 10) tc = THICKNESS OF COLLAR = 0 in
 11) Lc = LENGTH COLLAR = 0 in
 12) Ee = AXIAL EXTENSION = 0 in
 13) Ec = AXIAL COMPRESSION = 1.5 in
 14) Y+ = +ve LATERAL OFFSET = 0 in
 15) Y- = -ve LATERAL OFFSET = 0 in
 16) AN = ANGULAR ROTATION = 0 deg

MATERIAL INFORMATION

BELLOWS MATERIAL SECT. VIII
 SA240-304
 C-Mod. of E. = 2.83E+07
 H-Mod. of E. = 2.6865E+07
 Sa = 16412 psi

RESULTS

SPRING RATES

THEORETICAL SPRING RATE = 4,290.03 lbf/in
 WORKING SPRING RATE = 2,289.71 lbf/in
 LATERAL SPRING RATE = 1.893E+06 lbf/in
 LATERAL MOMENT RATE = 3.787E+06 in-lbs/in
 ANGULAR MOMENT RATE = 27,539.77 in-lbs/deg
 TORSION MOMENT RATE = 1.333E+08 in-lbs/deg

STRESSES EJMA

S1 = 9360 psi
 S1' = N/A
 S2 = 5581 psi
 S2' = N/A
 S2'' = N/A
 S3 = 477.1 psi
 S4(.35) = 7215 psi
 S5 = 759.1 psi
 S6 = 147900 psi
 ST = 163400 psi

MOVEMENTS

CONVOLUTION GAP = 0.96410 in/conv.
 COMPRESSION DUE TO AXIAL MOVEMENT = 0.75000
 EXTENSION DUE TO AXIAL MOVEMENT = 0.00000
 AXIAL DISP. DUE TO LATERAL OFFSET = 0.00000
 AXIAL DISP. DUE TO ANG. ROTATION = 0.00000
 MAX. EQUIVALENT AXIAL COMPRESSION = 0.75000
 MAX. EQUIVALENT AXIAL EXTENSION = 0.00000
 MAX. EQUIVALENT AXIAL MOVEMENT = 0.75000

EJMA FACTORS

Cp = .6792
 Cf = 1.535
 Cd = 1.67
 Cr = N/A
 Ct = 1 0
 EA = 4330 in²
 Wt. = 26 lbs.
 LCW = N/A

OTHER DATA

CYCLE LIFE = 15,230 cycles
 SQUIRM PRESSURE COLD / 2.25 = 1206 psig
 SQUIRM PRESSURE HOT / 2.25 = 1145 psig
 EQUIV. PIPE WALL THICKNESS = .8706 in

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-042 PAGE 1 OF 37
REV.	DEO #	DATE	BY:	CHECK	Bolted Flange Analysis For Tensile Forces	
0	135	4/25/96	RDC	AGA		
					BY:	DEPT.: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> Analyze and evaluate flanges and bolts for large tensile forces resulting from normal operation from venting of parts of systems when gate valves are closed.						
<u>METHOD:</u> Hand calculations for forces using statics analysis. Finite element analysis of bolted flange using IMAGES program.						
<u>ASSUMPTIONS:</u>						
<u>INPUTS:</u> 1. Positive purge pressure = 2 psig. 2. Atmospheric pressure = 14.7 psig. 3. Component interface loads.						
<u>REFERENCES:</u> 1. IMAGES - 3D, Version 3.0, R.L. Cloud and Associates. 2. Calc V049-1-032, Component Interface Loads						
<u>CALCULATIONS:</u> (SEE ATTACHED) Appendix A: Confirmatory Hand Calculations Appendix B: Analysis of Bolt Prying Appendix C: Test Pressure to Observe Flange Behavior Under Tension						
<u>CONCLUSIONS:</u> The 30 1/4 in. flange has the maximum bolt force. The number of bolts is increased to 24 for this flange and the bolt preload is increased to 10,000 lb for all flanges.						
<u>NOTES:</u> Computer file: FLANGEC.*						

SINCE ALL FLANGES HAVE THE SAME THICKNESS AND CROSS-SECTION, EACH DIAMETER FLANGE WILL BE REVIEWED TO FIND THE MAXIMUM BOLT TENSILE FORCE.

REF: CALL V049-1-032 FOR COMPONENT INTERFACE LOADS

104 IN FLANGES (IN BSCs)

THESE ARE NOT AFFECTED BY VALVE OPERATION. THE ONLY TENSILE FORCE OCCURS FROM 2 PSI PURGE PRESSURE ANALYZED IN CALL 19.

54 IN FLANGES (HAM COVERS)

SOME AS 104 IN FLANGE - NOT AFFECTED BY VALVE OPERATION

72 1/2 IN FLANGE

THESE ARE LOCATED IN THE BEAM TUBE MANIFOLDS AND IN OTHER ADAPTERS. VALVE AT END OF BEAM TUBE MANIFOLD WILL CAUSE LARGE TENSILE LOAD IN FLANGE WHEN THE BEAM TUBE MANIFOLD IS VENTED. A 2 PSI INTERNAL PURGE PRESSURE WILL ADD TO THE TENSILE FORCE

50 SHEETS
100 SHEETS
200 SHEETS



72 1/4 IN CONT.

DWG V049-5-003 SIKING SPool A2 w/ UNBALANCED VALVE FORCE WHEN SYSTEM IS VENTED ON 1 SIDE OF VALVE.
G = 76" CALL-019, P.10

$$F = 29.44 + \pi \frac{76^2}{4} \left(\frac{2}{1000} \right) = 32.76 \text{ K}$$

↑ 2 PSI PULL

PER BOLT

$$N = 36$$

$$F_b = \frac{32.76}{36} = .91 \text{ K}$$

BOLT CIRCLE DIAM

$$D_3 = 6.78 \text{ IN}$$

REF P. 9 0.8
CALL-019


SPACING

$$S = \frac{\pi D_b}{36} = 6.78 \text{ IN}$$

FORCE PER IN

$$f = \frac{.91}{6.78} = 135 \text{ LB/IN}$$


* SEE SKETCH ON FOLLOWING SHEET FOR 60 1/2 IN FLANGE. FORCE DIAGRAM IS SIMILAR.



60 1/2 IN FLANGES

THE ONLY FLANGES OF THIS SIZE THAT ARE SUBJECTED TO TENSILE FORCES ARE THOSE IN PORTS OF BSCs 7 AND 8 OF THE WASHINGTON CORNER STATION (SEE CALL V049-1-032). IN ADDITION TO THE 29.44" VACUUM FORCE, WHICH OCCURS WHEN THE VALVE IS CLOSED AND THE BSC IS VENTED, A 2 PSIG PURGE PRESSURE WILL INCREASE THE FLANGE FORCE

SHEETS ARE FOR SHEETS 22-102 22-103 22-104 22-105 22-106 22-107 22-108 22-109 22-110 22-111 22-112 22-113 22-114 22-115 22-116 22-117 22-118 22-119 22-120 22-121 22-122 22-123 22-124 22-125 22-126 22-127 22-128 22-129 22-130 22-131 22-132 22-133 22-134 22-135 22-136 22-137 22-138 22-139 22-140 22-141 22-142 22-143 22-144 22-145 22-146 22-147 22-148 22-149 22-150 22-151 22-152 22-153 22-154 22-155 22-156 22-157 22-158 22-159 22-160 22-161 22-162 22-163 22-164 22-165 22-166 22-167 22-168 22-169 22-170 22-171 22-172 22-173 22-174 22-175 22-176 22-177 22-178 22-179 22-180 22-181 22-182 22-183 22-184 22-185 22-186 22-187 22-188 22-189 22-190 22-191 22-192 22-193 22-194 22-195 22-196 22-197 22-198 22-199 22-200



GASKET DIAM FOR 60.5 IN FLANGE IS 64 IN

$$F = 29.44 + \pi \frac{64^2}{4} (2) \left(\frac{1}{1000} \right) = 35.9 \text{ K}$$

THIS FLANGE HAS 30 BELTS, FORCE PER BELT IS

$$F_b = \frac{35.9}{30} = 1.20 \text{ K}$$

SPACING

$$s = \frac{\pi D_b}{30}$$

$$D_3 = \text{BOIT CIRCUM DIAM.} \\ = 65.75 \quad \text{REF P. 12 CALC V049-1-019}$$


$$S = \frac{\pi (65.75)}{30} \\ = 6.89 \text{ IN}$$

FORCE PER IN OF CIRCUMFERENCE

$$\frac{F}{S} = \frac{1.20}{6.89} = 174 \text{ LB/IN}$$

48 1/4 IN FLANGE

THE MAXIMUM FLANGE FORCE DUE TO WEAVING IS 29.44 K (PAGE 032)



$$F = 29.44 + \pi \frac{52^2}{4} \frac{2}{1000} = 33.7 \text{ K}$$

← LARGEST DIAM. *

FOR 24 BOLTS

$$F_B = \frac{33.7}{24} = 1.40 \text{ K PER BOLT}$$

* REF P. 16 CALC V049-1-019

22-101 50 SHEETS
22-102 100 SHEETS
22-103 200 SHEETS



SPACING

$$S = \frac{\pi C}{24}$$

$$C = 53.75$$

CALL OUT, P. 15

$$S = \frac{\pi (53.75)}{24}$$
$$= 7.04 \text{ IN}$$

FORCE PER IN

$$f = \frac{1.40}{7.04} = .199 \text{ K} = 199 \text{ LB/IN}$$

44.63 IN FLANGE

$$F = 25.37 + \pi \frac{48^2}{4} \left(\frac{2}{1000} \right)$$
$$= 29.0 \text{ K}$$

$$F_B = \frac{29}{24} = 1.21 \text{ K}$$

$$S = \frac{\pi (49.75)}{24} = 6.51$$

$$f = \frac{1.21}{6.51} = .186 = 186 \text{ LB/IN}$$


22-141 69 STAFF
25-149 100 GIBBS
22-148 260 STAFFS



THE 48 1/4 IN FLANGE HAS THE MAX BOLT FORCE (1.40 K)* AND THE MAX FORCE PER IN OF CIRCUMFERENCE (199 LB/IN).

THIS FLANGE WILL BE ANALYZED USING THE MODEL GENERATED IN CALL V049-1-017. FILE FLANGE.* OF CALL 017 WAS COPIED TO FLANGE C.* FOR THIS ANALYSIS.

NODAL FORCE AT SHELL



FROM CALL 017, P.2

$$F_y = 52.1 \text{ LB/IN} \quad \& \quad F_{yi} = 13.4 \text{ LB}$$

AT INTERIOR NODES

$$F_{yi} = 13.4 \left(\frac{199}{52.1} \right) = 51.2 \text{ LB}$$

@ NODES 1366 TO 1546, INC = 15

* SEE LATER SHEETS FOR ANALYSIS OF 30 1/4 IN FLANGE

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



$$F_y = 6.7 \left(\frac{199}{52.1} \right) = 25.6 \text{ LB}$$

NODES 1351 & 1561

IN FLANGE RILE

PRELOAD

$$F_{PL} = 8500 \text{ LB PER BOLT}$$

$$\text{OR } F_{PL} = 8500/2 = 4250 \text{ FOR 1/2 BOLT}$$

$$F_{y0} = -375 \times \frac{4250}{6000} \leftarrow \text{CALL 17, P. 3}$$

6000 ← CALL 17, P. 3

$$= -266 \text{ LB}$$

@ NODES 1374, 1375, 1377, 1378,
1389 TO 1393
1414 TO 1418

$$F_y = \frac{-266}{2} = -133 \text{ LB}$$


@ NODES 1359, 1360, 1362, 1313

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



IMAGES-3D
Version 3.0

48 1/4 IN FLANGE



Revision 0
Doc. No. V049-1-042
Page 9 of 37


Load Case
1

Stress Contour Plot
Stress Intensity

1/ 5/96
7:51: 9

IMAGES-3D
Version 3.0

48 1/4 IN FLANGE




Revision 0
Doc. No. V049-1-042
Page 10 of 37

Load Case
1

Displacement Contour Plot
DY


1/ 5/96
7:29:53

IMAGES-3D
Version 3.0



DISPLACEMENTS AT O-RING
48 IN IN RANGE

Q Bolt



IF MAXIMUM PLANNED DISPLACEMENT
SAME AS ABOVE


$$\Delta = 2(.593)(10)^{-3} = .00119$$

COMPARE TO MIN COMPRESSION OF O-RING
FROM PARALLEL HANDLING (.058 IN)

$$\text{RATIO} = \frac{.058}{.00119} = 49$$

IMAGES-3D
Version 3.0

DISPLACEMENTS AT INNER O-RING
4x 1/4 IN RADIUS



$$\Delta = 2 (.130)(10)^{-2} = .26(10)^{-2}$$

$$\text{RATIO} = \frac{.054}{.0026} = 22$$


V_y @ MAXIMUM SURFACE (Y=0)

48 1/4 IN FLANGE

IMAGES-3D
Version 3.0



COMPRESS. ← ↑



Revision 0
Doc. No. V049-1-042
Page 13 of 37

Load Case
1


Stress Contour Plot
GI St: S22

1/ 5/96
7:54:49

48 1/4 IN FLANGE CONT.

BOLT FORCE RESULTING FROM FLANGE DEFORMATION UNDER TENSILE LOAD

THE BOLT WILL BE PRELOADED TO 8500 LB WHICH WAS INPUT TO THE FLANGE, * IMAGES FILE. WHEN THE FLANGE IS LOADED IN TENSION FROM PRESSURE OR COMPONENT LOAD, THE FLANGE DEFORMS SLIGHTLY AND THE BOLT FORCE CHANGES. THE FLANGE PART IS ESTIMATED CONSERVATIVELY BY ADDING THE AXIAL BOLT STRAIN FROM THE FLANGE, * OUTPUT TO THE PRELOAD STRAIN (STRESS).



Δ_y = DEFLECTION AT NOT FOR PRELOAD PLUS F_y . FROM DISPLACEMENT CONTOUR PLOT

$$\Delta_y = .172(10)^{-4} \text{ IN MAX}$$

FOR 1 IN FLANGE THICKNESS, STRAIN IS

$$\epsilon = \frac{\Delta_y}{1} = .172(10)^{-4}$$

BOLT STRESS

$$f_a = E \epsilon = 29(10)^6 \times .172(10)^{-4} = 500 \text{ PSI}$$

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS
 (AVIATION)

48 1/4 IN FLANGE EBUT.

TIRE TENSILE STRESS AREA FOR THE BOLT IS .462 IN²* FOR THE 7/8 IN BOLT. FORCE IS

* REF AISC, P. 4-147


$$F = .462 (500) = 230 \text{ LB}$$

TO OBTAIN A CONSERVATIVE BOLT STRESS, THE NOMINAL BOLT FORCE FROM THE TIRE TENSION, F_T , ON THE 48 1/4 IN FLANGE WILL BE ADDED TO THE PRELOAD

$$\begin{aligned} F_{\text{TOTAL}} &= F_0 + F_{PL} \\ &= 1.72 + 8.50 \text{ K} \\ &= 10.22 \text{ K} \end{aligned}$$

STRESS

$$f_c = \frac{10.22}{.462} = 22.1 \text{ KSI} < S = 25 \text{ KSI @ } 405^\circ\text{F OR}$$




22-131 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



30.25 IN FLANGES

FOR THE HODE CLEANER TUBES (SPOOL B-3, DWG V049-4-B3) THE 30.25 IN FLANGE IS UNDER TENSION DURING NORMAL OPERATION

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



$$p = -14.7 \text{ psi}$$

$$F_1 = \text{FORCE AT } 60.5 \text{ IN TUBE}$$

$$= -45.46 \text{ K} \quad \text{CALL -032, P. 4}$$

$$F_2 = \text{FLANGE FORCE (TGD)}$$

$$F_3 = pA$$

$$A = \pi r_0^2$$

$$r = \frac{G}{2} = \frac{34}{2} = 17$$

G = GASKET DIA
REF. p. 22 OF CALL
V049-1-019

$$F_3 = -14.7 \pi (17)^2 = -13.35 \text{ K}$$

$$F_1 + F_2 - F_3 = 0$$

$$F_2 = F_3 - F_1 = -13.35 - (-45.46)$$

$$= 32.11 \text{ K}$$

FOR F_3 USE INNER O-RING DIAMETER
IN CASE OUTER O-RING LEAKS, THIS
GIVES MAX FLANGE FORCE F_2

$$F_3 = -14.7 \pi \left(\frac{31}{2} \right)^2 \quad \text{DWG V049-4-016}$$

$$= -11.10 \text{ K}$$

$$F_2 = -11.10 - (-45.46) = 34.36 \text{ K}$$

FOR $N = 20$ BOLTS

$$F_B = \frac{34.36}{20} = 1.72 \text{ K PER BOLT}$$

SPACING

$$S = \frac{\pi C}{20}$$

$$C = 36 \text{ * BOLT CIRCLE DIA - DWG V049-4-016}$$

$$S = 5.65 \text{ IN}$$

*ACTUAL CHANGED TO
35.75 - DOES NOT AFFECT
FINAL RESULT

FORCE PER IN

$$f = \frac{F_B}{S}$$

$$= \frac{1.72}{5.65} = 304 \text{ LB/IN}$$

FORCE PER IN AT SHELL

$$d = 30.25$$

$$f = \frac{F_2}{\pi d}$$

$$= 362 \text{ LB/IN}$$

50 SHEETS
100 SHEETS
200 SHEETS




30' IN FLANGE CONT.

THE 30' IN FLANGE HAS THE MAX BO.F
FORCE (1.72 K) AND THE MAX FORCE
PER IN OF CIRCUMFERENCE (362 LB/IN)
IN THE SHELL.

THIS FLANGE WILL BE ANALYZED USING THE
FLANGE C.I. MODEL

NODAL FORCE AT SHELL



FROM CALL 017, P. 2

$$F_y = 52.1 \text{ LB/IN} \quad \& \quad F_{y_i} = 13.4 \text{ LB}$$

AT INTERIOR NODES

$$F_{y_i} = 13.4 \left(\frac{362}{52.1} \right) = 93.1 \text{ LB}$$

@ NODES 1366 TO 1546, INC = 15

30 1/4 IN FLANGE CONT

$$F_y = 6.7 \left(\frac{362}{52.1} \right) = 44.6 \text{ LB}$$

NODES 1351 & 1561

IN FLANGE FILE

50 SHEETS
100 SHEETS
200 SHEETS

22-141
22-142
22-143



A PRELIMINARY RUN ON FLANGE SHOWED
THAT IT IS NECESSARY TO INCREASE THE
LOAD TO 10000 LB FOR THE
30 1/4 IN FLANGE

CHANGE BOLT PRELOAD FROM 8500 TO 10000 LB FOR THE 30 IN FLANGE

NODE	FORCE*	FORCE	$\frac{10}{8.5} = 1.176 = \text{FACTOR ON 8500 LB BOLT LOAD}$
	FOR 8500 LB F_1	FOR 10000 LB F_2	
1359	-133	-156	
1360	-133		
1362	-133		
1363	-133		
1374	-266	-313	
1375	-266		
1377	-266		
1378	-266		
1389	-266		
1390	-266		
1391	-266		
1392	-266		
1393	-266		
1404	-266		
1405	-266		
1406	-266		
1407	-266		
1408	-266		

REF. P. 8 THIS CALL




* REF P. 8 OF THIS CALL

50 SHEETS
 100 SHEETS
 200 SHEETS



IMAGES-3D
Version 3.0

30 1/4 IN FLANGE



Revision 0
Doc No. V049-1-042
Page 21 of 37




Load Case
1

Stress Contour Plot
Stress Intensity

2/ 2/96
9:13:50

IMAGES-3D
Version 3.0

30' IN FLANGE



Revision 0
Doc. No. V049-1-042
Page 22 of 37




Load Case
1

Displacement Contour Plot
DY

2/ 2/96
9:17:45

IMAGES-3D
Version 3.0

30 1/4 IN FLANGE
DISPLACEMENT AT INNER D-RING



Revision 0
Doc. No. V049-1-042
Page 23 of 37



Load Case
1

Displacement Contour Plot
DY

2/ 2/96
9:21: 9

30 1/4 in K102216E

IMAGES-3D
Version 3.0



↓
down

Revision 0
Doc. No. V049-1-042
Page 24 of 37

Load Case
1

Stress Contour Plot
GI St: S22

2/ 2/96
9:24: 0

30 1/4 IN FLANGE CONT

22-1/41 50 SHEETS
22-1/42 100 SHEETS
22-1/44 200 SHEETS



MAX STRESS INTENSITY

$$S_{I \text{ MAX}} = 14.4 \text{ KSI}$$

VERY LOCAL, UNDER NUT

MAX FLANGE DISPLACEMENT OCCURS AT
INNER O-RING IN Y-DIRECTION

$$\Delta = .00372 \text{ IN} \quad \text{SEE IMAGES OUTPUT P. 23}$$

FOR 2 FLANGES, THE GAP OPENING
IS $2 \times \Delta = .0074 \text{ IN}$. THIS COMPARES
TO THE MIN O-RING COMPRESSION, .058 IN.

$$\text{RATIO} = \frac{.058}{.0074} = 7.8$$

NOTE: THE MODEL IS CONSERVATIVE FOR
THIS CASE BECAUSE THE BOLT SPACING
FOR THE 30 1/4 IN FLANGE WITH
20 BOLTS IS 5.65 IN BUT THE MODEL
BOLT SPACING IS 7.2 IN.

$$\Delta_y \approx .00015 \text{ AT NUT}$$

$$\text{BOLT STRAIN } \epsilon = \frac{.00015}{1} = .00015$$

INCREASED STRESS

$$f_s = .00015(99)(10^3) \\ = 14.4 \text{ KSI}$$

FOR TIRE 10^K PRELOAD, TIRE STRESS IS

$$f_a = \frac{10}{.462} = 21.6 \text{ KSI}$$

REF: AISC P. 1-147 FOR
TENSILE AREA = .462 IN²

TOTAL STRESS IS

$$f_a = 21.6 + 4.4 = 26 \text{ KSI SAY OK} \\ \approx 25$$

OR WHEN TIRE BOLT APPLIED LOAD
IS ADDED TO PRELOAD

$$f_a = \frac{10 + 1.72}{.462} \\ = 25.4 \text{ KSI } \approx 25 \text{ OK}$$

CLEARANCE NO. OF BOLTS TO 24

$$F_B = \frac{34.36}{24} = 1.43$$


$$f_a = \frac{10 + 1.43}{.462} = 24.7 < 25$$

BOLT SPACING IS

$$S = \frac{\pi C}{24} = \frac{\pi (36)}{24} \\ = 4.71 \text{ IN OK}$$

FORRIS PER IN AT SHELL IS STILL 362 LB/IN

STRESS IN FLANGE TO SIDE WELD



THE PARTIAL PENETRATION WELD IS $1/8$ " THICK. NEGLECT STITCH WELD AND ASSUME THAT ALL LOAD IS TRANSMITTED THROUGH PARTIAL PEN WELD.

$$f_a = \frac{F_y}{.125}$$

$$= \frac{362}{.125} = 2900 \text{ OR } \text{psi}$$


REF P. 17 OF THIS CALL FOR $F_y = 362 \text{ LB/IN}$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



CONFIRMATORY HAND CALC TO VERIFY
IMAGES RESULT FOR FLANGE TENSION.

DEFLECTION & STRESS IN A 1 IN STRIP
FLANGE FOR O-RING PRESSURE



CLAMPING
ASSUMED ABOUT
ENTIRE RING

22-141 50 SHEETS
22-142 100 SHEETS
22-143 200 SHEETS



FOR A 1-IN STRIP

$$I = \frac{(1)t^3}{12}$$

W = MAX FORCE PER IN TO COMPRESS O-RING
THE NOMINAL DIAMETER IS 1/4" FROM THE
PRAKSA HANDBOOK, P A 5-13 THE MAX "SOVEREEN"
IS 28%, FROM P A 4-11 THE MAX FORCE
PER IN FOR DIAMETER 90 IS

$$W = 170 \text{ LB/IN}$$

FROM DWG V049-4-016 OUTER O-RING DIA

$$S_o = \frac{36}{2} - .5 - \left(\frac{.26}{2} + \frac{.34}{2} \right)$$

$$= .37 \text{ IN}$$

$$S_i = \frac{36}{2} - .5 - \left(\frac{.21}{2} + \frac{.34}{2} \right)$$

$$= 1.83 \text{ IN}$$

4.275 CROSS SECTION

SINCE S_0 IS SMALL, IGNORE INNER O-RING FORCE,

DEFLECTION

$$\Delta = \Delta_b + \Delta_s$$

$$\Delta_b = \text{BENDING DEFLECTION}$$

$$= \frac{w S_0^3}{3 E I}$$

$$= \frac{170 (1.83)^3}{3 (24.8 \times 10^6) \left(\frac{t^3}{12} \right)}$$

$$= \frac{1.45 (10)^{-4}}{t^3}$$

$$\Delta_s = \text{SHEAR DEFLECTION}$$

$$= \frac{w S_0}{A G}$$

$$A = t(1) = t$$

$$G = \frac{24.8 (10)^6}{2(1+\nu)} = 11.1 (10)^6 \text{ psi}$$

$$\Delta_s = \frac{170 (1.83)}{t (11.1 \times 10)^6} = \frac{.28 (10)^{-4}}{t}$$

$$\Delta = \frac{1.45 (10)^{-4}}{t^3} + \frac{.28 (10)^{-4}}{t}$$

For $t = 1$

$$\Delta = (1.45 + .28)(1.0)^{-4} = 1.73(1.0)^{-4}$$

For $t = 7/8 = .875$

$$\Delta = \frac{1.45(1.0)^{-4}}{(.875)^3} + \frac{.28(1.0)^{-4}}{.875} = 2.48(1.0)^{-4}$$

For $t = 3/4 = .75$

$$\Delta = \frac{1.45(1.0)^{-4}}{(.75)^3} + \frac{.28(1.0)^{-4}}{.75} = 3.42(1.0)^{-4}$$

MIN COMP OF O-RING IS .058 IN (PARSER HANDBOOK, PAS-13). FOR MATING FLANGE, ASSUME THAT Δ DOUBLES.

$t = 1$

$$\Delta = (2)1.73(1.0)^{-4} = 3.46(1.0)^{-4}$$

$$\text{RATIO} = \frac{.058}{3.46(1.0)^{-4}} = 16.8$$

$t = 7/8$

$$\Delta = 2(2.48)(1.0)^{-4} = 4.96(1.0)^{-4}$$

$$\text{RATIO} = \frac{.058}{4.96(1.0)^{-4}} = 11.7$$

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



$t = 3/4$

$\Delta = (2)3.42(10)^{-4} = 6.84(10)^{-4}$

RATIO = $\frac{.052}{6.84(10)^{-4}} = 85$

ADD MAXIMUM TENSILE FORCE TO BENDING LOAD, THIS IS 362 LB/IN FOR THE 20 1/4 IN FLANGE

$w = 170 + 362 = 532$

RATIOS

RATIO

IMAGES GIVES MORE CONSERVATIVE RESULTS

$t = 1 \text{ IN}$

$R = 168 \left(\frac{170}{532} \right) = 54$

$t = 7/8$

$R = 117 \left(\frac{170}{532} \right) = 37$

$t = 3/4$

$R = 85 \left(\frac{170}{532} \right) = 27$

MAX BENDING STRESS

$M = w S_c =$

$= 532 (1.83) = 974$

$t = 1$

$S_b = \frac{974 (1.5)}{1^3/12} =$

$= 5844 \text{ psi}$

22-141 50 SHEETS
 22-142 100 SHEETS
 22-143 200 SHEETS

$$t = 7/8$$

$$f_b = \frac{974 \left(\frac{.875}{2} \right)}{\frac{(.875)^3}{12}}$$

$$= 7630 \text{ psi}$$

$$t = 3/4$$

$$f_b = \frac{974 \left(\frac{.75}{2} \right)}{\frac{.75^3}{12}}$$

$$= 10400 \text{ psi}$$


22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



Given: LIGO flanges of various sizes

Req'd: look @ a typical flange
say a 60 1/4" flange and determine
if there are any significant prying
forces when the flange is put into
tension. Reference previous analysis
by Ray Ciatto 1/3/96
Reference AISC 9th edition pages 4-90, 4-91.

Solution:



$$a = 1.0" \quad a' = 1.0 + \frac{.875}{2} = 1.4375"$$

$$b = 2.05" \quad b' = 2.05 - \frac{.875}{2} = 2.0625"$$

$T+Q$ is total bolt tension force including prying
where Q is the prying force.

now calculate some constants

$$P = \frac{\pi(65.75)}{30} = 6.89'' \text{ tribut width per bolt.}$$

$$d' = 1.0'' ; \delta = 1 - \frac{d'}{P} = 1 - \frac{1}{6.89} = 0.855$$

$$d = 0.875 \text{ bolt diameter}$$

$$f = \frac{d'}{d} = \frac{2.0625}{1.4375} = 1.4348$$

now since $\sigma_{allow} = 25 \text{ ksi}$
bolts

then $B = 25(0.755)^2 / 4 \pi = 11.192 \text{ K}$
root diameter of bolt (7/8" OD)

$$T = 3509 / 30 = 1.2 \text{ K force/bolt in 30 bolts}$$

and $B = \frac{1}{f} \left(\frac{B}{T} - 1 \right)$

$$= \frac{1}{1.4348} \left[\frac{11.192}{1.2} - 1 \right] = 5.803 > 1.0$$

$$\Rightarrow \alpha' = 1.0 \quad T$$

then $t_{slg} = \sqrt{\frac{8(1.2)(2.0625)}{6.89(36)(1+0.855(1.0))}}$
for the actual force T
 $= 0.2075'' < 1.0'' \text{ actual slg thickness}$

APPENDIX B

now

Calculate req'd thickness of flange to develop the full allowable flange force B

$$t_c = \sqrt{\frac{8BB'}{PF_y}}$$

$$= \sqrt{\frac{8(11.192)(2.0625)}{6.89(36)}}$$

$$= .863''$$

again actual thickness is $t = 1.00''$ actual

now

$$\alpha = \frac{1}{\delta} \left[\frac{T/B}{(t/t_c)^2} - 1 \right]$$

$$= \frac{1}{.855} \left[\frac{1.02/11.192}{(.863)^2} - 1 \right]$$

$$= -1.076$$

since this is neg, set $\alpha = 0$

$$\therefore Q = B \delta \alpha^0 \left(\frac{t}{t_c} \right)^2 \equiv 0$$

or there is no prying force of any significance.

50 SHEETS
100 SHEETS
200 SHEETS
22-131
22-132
22-134
AMFPAI

APPENDIX C

TEST PRESSURE TO OBSERVE FLOW BEHAVIOR UNDER TENSION
 10" TEST NUMBER - REF DWG V049-4-030

HYDRO PRESSURE REQUIRED TO GIVE

3K PER BOLT

NOTE: MAX BOLT LOAD = 1.72K FOR 30/4" FLANGE
 SA X 2K. INCREASE BY 50% FOR
 HYDRO TIG

$$1.5 \times 2K = 3K$$

$$PA = 3N$$

$$N = 6 \text{ BOLTS}$$

$$A = \pi r^2$$

$$r = 5$$

$$P \pi (5)^2 = 3(6) = 18K$$

$$P = .225 \text{ K/IN}^2$$

$$= 225 \text{ PSI}$$

HOOP STRESS IN CYL

$$\sigma_a = \frac{Pr}{t}$$

$$t = 3/16$$

$$\sigma_a = \frac{270(5)}{3/16} = 6133 \text{ PSI} \text{ OK}$$

FOR 1/8 IN FILLET CONNECTING FLANGE TO CYL

$$A_w = \pi(10)(.125)(.707) = 2.8 \text{ IN}^2$$

WELD STRESS

$$f_v = \frac{18}{2.8} = 6.5 \text{ KSI} \text{ OK}$$



MAXIMUM BENDING STRESS IN 10" FLAT
PLATE

$$\sigma_M = 1.24 \frac{P r^2}{t^2}$$

$$= 1.24 \frac{(230)(5)^2}{(.5)^2}$$

$$= 28500 \text{ psi}$$

OK
FOR HYDRO

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1- 122 PAGE 1 OF 8
REV.	DEO #	DATE	BY:	CHECK	TITLE: 44" Gate Valve Weld Stub/Beam Tube Buckling Stress Evaluation	
0	349	11/6/96	ROC	WDB		
					BY: R. D. Ciatto	DEPT.: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> This is an information calculation that evaluates the effects of a partial penetration weld on the buckling resistance of the GNB gate valve weld stub. It also evaluates the potential buckling of the end of the CBI tube at the anchor in the beam tube.						
<u>METHOD:</u> Hand calculations are performed using the compressive stress formulas of the ASME Code.						
<u>ASSUMPTIONS:</u> For the calculation of the bending stress due to valve weight, the "soft" support under the valve is neglected. This is conservative since the reaction provided by this support relieves the cantilever effect of the valve.						
<u>INPUTS:</u> 1. Vacuum Pressure = -14.7 psi 2. Maximum Temperature = 400°F 3. Valve Weight = 8000 lb						
<u>REFERENCES:</u> 1. ASME Boiler & Pressure Vessel Code, Section VIII, Div. 1 2. GNB Calculation, "Duct Neck Welds", Oct. 25, 1996. 3. AISI Stainless Steel Cold-Formed Structural Design Manual						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> Bending stresses due to the weight of the valve are compressive at the bottom the weld stub and beam tube. Although these stresses are low (< 700 psi), they add to the axial compressive stresses due to external pressure. The combined stresses are less than the compressive stress allowed by the ASME Code.						
<u>NOTES:</u> The weld stub has adequate buckling resistance even with the partial penetration longitudinal weld in the stub.						

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-122
		Rev. No. 0
		Page 2 of 8
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: 44" Gate Valve Weld Stub/Beam Tube Buckling Stress Evaluation		

TABLE OF CONTENTS

Revision History	3
Weld Stub - As Designed Condition	4
Weld Stub - Reduced Thickness	5
Stress at CBI Anchor	6
Alternate Code Evaluation	8

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-122
		Rev. No. 0
		Page 3 of 8
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: 44" Gate Valve Weld Stub/Beam Tube Buckling Stress Evaluation		

REVISION HISTORY

Rev. 0 Original Issue - Nov. 1996

WELD STUB - AS DESIGNED CONDITION

GET MAX ALLOW COMPRESSIVE STRESS OF
WELD STUB PER SECT VIII-1, UG-23(b)

$$A = \frac{.125}{(R_o/t)}$$

$$R_o = \frac{D_o}{2} = \frac{49.12}{2} + .135$$

REF GNB WELD
STUB ONLY 103224

$$= 24.7$$

$$t = .135$$

$$A = \frac{.125}{(24.7/.135)} = 6.93 (10)^{-4}$$

$$B = 5250$$

FIG HA-3 FOR 304L
@ 400°F - SECT II, P. 68
MAX TEMP = 150°C - 302°F
∴ CONSERVATIVE

MAX AXIAL STRESS AT END OF WELD STUB

$$T = \frac{P_o}{2t} = \frac{14.7(24.7)}{2(.135)} = 1345 \text{ psi}$$

FROM BENDING, $T = 263 \text{ psi}$ REF: GNB CALC

$$\text{TOTAL } T = 1345 + 263 = 1608 \text{ psi}$$

$T < B$ ∴ REQUIREMENT OF UG-23(b)
ARE MET

WELD STUB - REDUCED THICKNESS

ANALYZE MAX ALLOW COMP STRESS USING $t = .070$ WHICH IS THE THICKNESS OF THE PAP. PEN. WELD. THIS WILL RESULT IN THE LOWER BOUND ALLOW. COMP. STRESS (LONG.)

$$A = \frac{.125}{(R_o/t)}$$

$$= \frac{.125}{(24.7/.070)} = 3.5 (10)^{-4}$$

$TB = 4500$

AXIAL COMP STRESS FROM PRESSURE

$$\sigma = \frac{p r}{2t} = \frac{14.7(24.7)}{2(.070)} = 2594 \text{ psi}$$

AXIAL STRESS FROM BENDING

$I = \pi r^3 t =$

$$r = \text{MEAN RAD} = \frac{48.12}{2} + \frac{.070}{2} = 24.595$$

$$I = \pi (24.595)^3 (.070) = 3272 \text{ IN}^4$$

$$M = WL = 8000(10.63) = 85040 \text{ IN-LB}$$

AT END OF WELD STUB

$$\sigma = \frac{M r_o}{I}, \text{ SAY } r_o = 24.595$$

$$\sigma = \frac{85040(24.595)}{3272} = 639$$


TOTAL STRESS AT END OF WELD STUB

$$\sigma = 2594 + 639 = 3233 < 4500 \text{ OK}$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS
AMPAD

STRESS AT CBI ANCHOR

CONSIDER STRESS IN CBI TUBE AT 1ST SUPPORT (ANCHOR) - "SOFT" SUPPORT NEGLECTED



22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



BENDING STRESS AT CBI ANCHOR (t = .070)

$$M = 8000(64.37) = 515000 \text{ IN-LB}$$

$$\sigma = \frac{515000(24.595)}{3272} = 3871 \text{ PSI}$$

ADD PRESS STRESS

$$\sigma = 3871 + 2594 = 6465 \text{ PSI} > B = 4500$$

TOO HIGH

BUT CBI TUBE IS .120 MIN THICK, W/ RF WELD
∴ ABOVE CASE IS TOO CONSERVATIVE FOR CBI TUBE

$$\sigma = \frac{14.7(24.56)}{2(.120)} = 1500 \text{ PSI FOR PRESS.}$$

$$I = \pi (24.56)^3 (.120) = 5565 \text{ IN}^4$$

$$\sigma = \frac{515000 (24.62)}{5565} = 2270$$

TOTAL STRESS

$$\sigma = 2270 + 1500 = 3770 \text{ psi}$$

CHECK ALLOW. COMP STRESS PER UG-23(b)

$$A = \frac{.125}{24.7/.12} = 6.07(10)^{-4}$$

B = 5000 FROM FIL HA-3

$\sigma < B$ FOR $t = .12$ OK

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



ALTERNATE CODE EVALUATION

ALLOWABLE COMPRESSIVE STRESS PER AISI
STAINLESS STEEL COLD-FORMED STRUCTURAL DESIGN
MANUAL - 1974 EDITION - SECTION 3.8

$$F_c = .154 F_y + \frac{1214}{D/t} \leftarrow = .070 \text{ FOR STUB}$$

$$F_y = 17.5^* \text{ KSI @ } 400^\circ\text{F FOR 304L}$$

$$D/t = \frac{(49.12 + .07)}{.07} = 703 \text{ (WORST CASE)} \\ t = .070$$

$$F_c = .154(17.5) + \frac{1214}{703} \\ = 4.47 \text{ KSI}$$

FROM P. 5, $\sigma = 3233 < 4420 \text{ PSI}$
OK FOR WORST CASE STRESS

* ASME CODE SECT II, PART D, TABLE 4-1

PROCESS SYSTEMS INTERNATIONAL, INC.
WESTBOROUGH, MA

ENGINEERING
CALCULATIONS

NO: V049-1-071

PAGE 1 OF 19

REV.	DEO #	DATE	BY:	CHECK
	0128	3-18-96	AGR	RDC

TITLE:

PIPE BRIDGE CORNER STATION

By: ART ROUSSOPOULOS DEPT.: 744

PROJECT: LIGO

PROJECT NO: V59049

PURPOSE: ANALYZE PROPOSED PIPE BRIDGE FOR AISC COMPLIANCE.

METHOD: • STAAD 3 STRUCTURAL COMPUTER SOFTWARE

ASSUMPTIONS: SEE CALCS

INPUTS: "STRUCTURAL DESIGN CRITERIA" REF: DOC. NO. V049-1-066
"DESIGN OF SUPPORT BASE PLATES" DOC. NO. V049-1-024
LIGO PIPE BRIDGE SKETCH SH1 2+3 - REF: V049-4-043 SH1 1 OF 3

Doc. No. V049-1-066, LIGO VAC. EQUIP. STRUCT. DESIGN CRITERIA

REFERENCES: • DWG. V049-4-043 • AISC - 9TH. ED., 3RD. IMP. 1/90
• STAAD3
• HILTI-TECH GUIDE - "ANCHOR & POWDER ACTUATED FASTENING"
PUBLICATION # H-427 2/87

CALCULATIONS: (SEE ATTACHED)

CONCLUSIONS: SUBJECT PIPE BRIDGE WITH REVISED 6x4x1/4 MEMBERS IS ACCEPTABLE
• ONLY TWO (2) ANCHOR BOLTS ARE REQUIRED PER PLATE
• ALL WELDS SHALL BE 3/16" FILLET EXCEPT WHEN NOTED.

NOTES: STAAD 3 FILE NAME ARTROU.STD FILED IN DIRECTORY \41896\

TABLE OF CONTENTS

	<u>PAGE</u>
1. - STAAD 3 INPUT	3
• DENSITY	
• E	
• ν	
• SEISMIC	
• PIPE LOADS	
• SEISMIC LOADS	
- PIPING	
- PIPE BRIDGE STEEL TUBING	
• MODEL FOR PIPE LOADS	4
• MODEL FOR SEISMIC LOADS	5
2. - ANCHOR/PLATES	6
• REACTION LOADS	6
• SUMMARY OF BASE PLATE/ANCHOR REACTIONS	6
• ALLOWABLE LOAD	7
3. - BASE PLATE QUALIFICATION	7
• REQUIRED PLATE THICKNESS	7
• CONCLUSIONS	8
4. - STAAD 3 COMPUTER MODEL INPUT/OUTPUT	9-18
ATTACHMENT: MARKED UP LIGG DWG V.049-4-043	19

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



1. - STAAD 3 INPUT:

- DENSITY = .283 #/IN³
- MODULUS OF ELASTICITY $E = 28 \times 10^6$ PSI
- POISSON $\nu = .3$
- SEISMIC = .05625 g
- PIPE LOADS - (REF: 460 PIPE BRIDGE SKETCH SH30P3)

$$\begin{aligned} F_1, F_3 &= (1100/2) = 550 \# & F_2 &= 1100 \# \\ F_4 &= 40 \# \\ F_5 &= 40 \# \\ F_6 &= 40 \# \\ F_7 &= 90 \# \\ F_8 &= 90 \# \\ F_9 &= 150 \# \\ F_{10} &= 90 \# \\ F_{11} &= 150 \# \end{aligned}$$

- SEISMIC LOADS F_x, F_z

- PIPING:

$$\begin{aligned} F_1, F_3 &= 550(.05625) = 31 \# & F_2 &= 1100(.05625) = 62 \# \\ F_4 &= 40(.05625) = 2.25 \# \\ F_5 &= 40(.05625) = 2.25 \# \\ F_6 &= 40(.05625) = 2.25 \# \\ F_7 &= 90(.05625) = 5.063 \# \\ F_8 &= 90(.05625) = 5.063 \# \\ F_9 &= 150(.05625) = 8.44 \# \\ F_{10} &= 90(.05625) = 5.063 \# \end{aligned}$$

- PIPE BRIDGE STEEL TUBE (SEE MODEL P. 3+4)

ELEMENT DEADWEIGHT:


- 100, 200, 103 + 203: 8X6X1/4 X 108" LONG EACH
 $WT = [(22.42 \# / FT) / 12] \times 108 = 201.8 \#$ EACH
- 300, 302 + 304: 8X6X1/4 X 72" LONG EACH
 $WT = (22.42 / 12) \times 72 = 134.5 \#$ EACH
- 101, 102, 201 + 202: 8X6X1/4 X 102" LONG EACH
 $WT = (22.42 / 12) \times 102 = 190.6 \#$ EACH
- 301 + 303: 4X3X1/4 X 124.85" LONG EACH
 $WT = (10.51 / 12) \times 124.85 = 109.3 \#$ EACH

SEISMIC LOADS:

- 100, 200, 103 + 203: $F_x, F_z = 201.8(.06) = 12.1 \#$
- 300, 302 + 304: $F_x, F_z = 134.5(.06) = 8.07 \#$
- 101, 102, 201 + 202: $F_x, F_z = 190.6(.06) = 11.1 \#$
- 301, 303: $F_x, F_z = 109.3(.06) = 6.6 \#$



STANDARD MODEL FOR PIPEBRIDGE, REF. DWG. NO. 4-043
 PIPING CADS:




REV 0
 Doc. No. Y049-1-071
 P. 4 OF 19

LOADS	
F1	= 550 #
F2	= 1100 #
F3	= 500 #
F4	= 40 #
F5	= 40 #
F6	= 90 #
F7	= 150 #
F8	= 150 #
F9	= 150 #
F10	= 150 #

REV 0
 Doc. No. Y049-1-071
 P. 4 OF 19

STA 03 - MODEL FOR PIPEBRIDGE
SEISMIC LOADS



REV 0
Doc. No. V049-1-071
P. 5 of 19

REV 0
DOC. NO. V049-1-071

STAAD 3 - RESULTS: (SEE OUTPUT P. 8-17)

- MAXIMUM WELD SIZE OF $2/16"$ $< 3/16$ MINIMUM \therefore OK
- ALL STEEL TUBE ELEMENT MEMBERS PASS AISC ACCEPTANCE CRITERIA \therefore THE PIPE BRIDGE WITH REVISED FROM $8 \times 6 \times 1/4$ TO $6 \times 6 \times 1/4$ MEMBERS IS ACCEPTABLE
- A MAXIMUM JOINT DISPLACEMENT OF $.27606"$ OCCURS AT JOINT 30 (SEE P. 12)
 $.27606"$ IS DEEMED ACCEPTABLE

2. - ANCHOR / PLATES: - LOCATED AT NODES 10, 50, 60 + 100

- DESIGN OF ANCHOR / SUPPORT BASE PLATES SHALL BE BASED ON THE DESIGN METHODOLOGY FOUND IN DOC. NO. V049-1-024
- REACTION LOADS FROM STAAD 3 OUTPUT P.

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z
10	1	50.70	390.45	-3.30	0.00	0.00	0.00
	2	144.50	3454.01	-215.09	0.00	0.00	0.00
	3	195.20	3844.46	-218.39	0.00	0.00	0.00
50	1	-50.70	390.45	-3.30	0.00	0.00	0.00
	2	-464.87	3698.52	-182.35	0.00	0.00	0.00
	3	-515.56	4088.97	-185.65	0.00	0.00	0.00
60	1	49.03	390.45	3.30	0.00	0.00	0.00
	2	42.51	566.27	-128.68	0.00	0.00	0.00
	3	91.54	956.72	-125.38	0.00	0.00	0.00
100	1	-49.03	390.45	3.30	0.00	0.00	0.00
	2	-340.81	951.20	-92.55	0.00	0.00	0.00
	3	-389.84	1341.64	-89.25	0.00	0.00	0.00

• SUMMARY OF BASE PLATE / ANCHOR REACTIONS

LOAD	NODES			
	10	50	60	100
F _x (#)	195	-516	92	-390
F _y (#)	3845	4089	957	1342
F _z (#)	-218	-186	-125	-89

- VERTICAL LOADS ARE ALL COMPRESSIVE
 \therefore ONLY HORIZONTAL SHEAR LOADS ARE IMPOSED ONTO ANCHOR BOLTING.
- ANALYZE NODE 50 FOR WORSE CASE LOADING
- MAXIMUM SHEAR LOAD:


$$F_{S \text{ MAX}} = [F_x^2 + F_z^2]^{1/2} = [(-516)^2 + (-186)^2]^{1/2} = 549 \# \text{ (TOTAL)}$$



2. - CONT

- ALLOWABLE LOAD (REF: MILIT-SPEC TABLE FOR 3/4" HAS ANCHOR ROD)

- THE ALLOWABLE SHEAR LOAD FOR A 3/4" DIA. HAS STD. (SAE 1018) ANCHOR ROD IS: 4,800#. WHICH IS GREATER THAN THE MAXIMUM APPLIED SHEAR LOAD OF 549#. ∴ TWO (2) 3/4" DIAMETER ANCHOR BOLTS PER BASE PLATE IS ADEQUATE.



$$d' = 4 - .25 = 3.75"$$

$$m = (N - d')/2$$

$$m = \frac{14 - 3.75}{2} = 5.125"$$

$$b' = 6 - .25 = 5.75"$$

$$n = (B - b')/2$$

$$n = \frac{14 - 5.75}{2} = 4.125"$$

3. - BASE PLATE QUALIFICATION REF: AISC P. 3-106

• REQUIRED PLATE THICKNESS:

$$t_p = 2(m \text{ OR } n) \left[\frac{f_p}{F_y} \right]^{1/2} = 2(5.125) \left[\frac{21}{36000} \right]^{1/2} = .25"$$

WHERE: $m = 4.3125"$ (MAX OF m OR n)

$F_y = 36,000$ PSI FOR PLATE MIN YIELD STRESS

$f_p =$ ACTUAL BEARING PRESSURE

$$f_p = P / (B \times N) = 4,089 / (14 \times 14) = 21 \text{ PSI}$$

WHERE: $P = 4,089$ (MAX COMPRESSIVE LOAD)

$$f_p = 21 \text{ PSI} < .35 f'_c = .35(3000) = 1,050 \text{ PSI} \therefore \text{OK}$$

$$t_p = .25" < 1" \therefore \text{OK}$$

REVO
DOC. NO. V049-1-071
P. 7 OF 19

CONCLUSIONS:

- PIPE BRIDGE WITH REVISED 6X4 X 1/4 MEMBERS IS ACCEPTABLE.
- ONLY TWO(2) 3/4" DIA ANCHOR BOLTS PER BASE PLATE ARE REQUIRED
- ALL WELDS SHALL BE 3/16" FILLET

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



4.-

```
*****  
*  
*          S T A A D - III          *  
*          Revision 21.0            *  
*          Proprietary Program of   *  
*          Research Engineers, Inc.  *  
*          Date=    MAR 23, 1996    *  
*          Time=    12:32:33        *  
*  
*          USER ID: Process Systems International *  
*****
```

1. STAAD SPACE PIPE BRIDGE
2. INPUT WIDTH 72
3. *FILE NAME:ARTROU
4. *PIPE BRIDGE
5. UNIT INCHES POUND
6. JOINT COORDINATES
7. 10 0. 0. 0.; 20 0. 108. 0.; 30 102. 108. 0.; 40 204. 108. 0.
8. 50 204. 0. 0.; 60 0. 0. -72.; 70 0. 108. -72.; 80 102. 108. -72.
9. 90 204. 108. -72.; 100 204. 0. -72.
10. MEMBER INCIDENCES
11. 100 10 20; 101 20 30; 102 30 40; 103 40 50; 200 60 70; 201 70 80
12. 202 80 90; 203 90 100; 300 20 70; 301 30 70; 302 30 80; 303 30 90
13. 304 40 90
14. MEMBER PROPERTY AMER
15. 100 TO 103 200 TO 203 300 302 304 TABLE ST TUBE TH 0.25 WT 4. DT 6.
16. 301 303 TABLE ST TUBE TH 0.25 WT 4. DT 3.
17. SUPPORTS
18. 10 50 60 100 FIXED BUT MX MY MZ
19. CONSTANTS
20. E 27999998. ALL
21. DENSITY 0.283 ALL
22. POISSON 0.3 ALL
23. BETA 0. ALL
24. E STEEL ALL
25. POISSON STEEL ALL
26. LOAD 1 TRUSS SELFWEIGHT (D1)
27. SELFWEIGHT Y -1.
28. LOAD 2 PIPE LOADS (D2)
29. JOINT LOAD
30. 20 FX 31. FY -550. FZ 31.
31. 30 FX 31. FY -550. FZ 31.
32. 40 FX 31. FY -550. FZ 31.
33. MEMBER LOAD
34. 100 CON GX 12.1 54. 0.
35. 100 CON GZ 12.1 54. 0.
36. 200 CON GX 12.1 54. 0.
37. 200 CON GZ 12.1 54. 0.
38. 103 CON GX 12.1 54. 0.
39. 103 CON GZ 12.1 54. 0.
40. 203 CON GX 12.1 54. 0.
41. 203 CON GZ 12.1 54. 0.

REV 0
Doc. No. V049-1-071
P. 9 OF 19

PIPE BRIDGE

42.	300	CON	GX	8.07	36.	0.
43.	300	CON	GZ	8.07	36.	0.
44.	302	CON	GX	8.07	36.	0.
45.	302	CON	GZ	8.07	36.	0.
46.	304	CON	GX	8.07	36.	0.
47.	304	CON	GZ	8.07	36.	0.
48.	101	CON	GX	11.1	51.	0.
49.	101	CON	GZ	11.1	51.	0.
50.	102	CON	GX	11.1	51.	0.
51.	102	CON	GZ	11.1	51.	0.
52.	201	CON	GX	11.1	51.	0.
53.	201	CON	GZ	11.1	51.	0.
54.	202	CON	GX	11.1	51.	0.
55.	202	CON	GZ	11.1	51.	0.
56.	301	CON	GX	6.6	62.43	0.
57.	301	CON	GZ	6.6	62.43	0.
58.	303	CON	GX	6.6	62.43	0.
59.	303	CON	GZ	6.6	62.43	0.
60.	300	CON	GX	62.	10.	0.
61.	300	CON	GY	-1100.	10.	0.
62.	300	CON	GZ	62.	10.	0.
63.	300	CON	GX	31.	20.	0.
64.	300	CON	GY	-550.	20.	0.
65.	300	CON	GZ	31.	20.	0.
66.	300	CON	GX	2.25	25.25	0.
67.	300	CON	GY	-40.	25.25	0.
68.	300	CON	GZ	2.25	25.25	0.
69.	300	CON	GX	2.25	29.75	0.
70.	300	CON	GY	-40.	29.75	0.
71.	300	CON	GZ	2.25	29.75	0.
72.	300	CON	GX	2.25	34.25	0.
73.	300	CON	GY	-40.	34.25	0.
74.	300	CON	GZ	2.25	34.25	0.
75.	300	CON	GX	5.063	40.	0.
76.	300	CON	GY	-90.	40.	0.
77.	300	CON	GZ	5.063	40.	0.
78.	300	CON	GX	5.063	47.5	0.
79.	300	CON	GY	-90.	47.5	0.
80.	300	CON	GZ	5.063	47.5	0.
81.	300	CON	GX	8.44	55.	0.
82.	300	CON	GY	-150.	55.	0.
83.	300	CON	GZ	8.44	55.	0.
84.	300	CON	GX	5.063	62.5	0.
85.	300	CON	GY	-90.	62.5	0.
86.	300	CON	GZ	5.063	62.5	0.
87.	300	CON	GX	8.44	70.	0.
88.	300	CON	GY	-150.	70.	0.
89.	300	CON	GZ	8.44	70.	0.
90.	302	CON	GX	62.	10.	0.
91.	302	CON	GY	-1100.	10.	0.
92.	302	CON	GZ	62.	10.	0.
93.	302	CON	GX	31.	20.	0.
94.	302	CON	GY	-550.	20.	0.
95.	302	CON	GZ	31.	20.	0.
96.	302	CON	GX	2.25	25.25	0.
97.	302	CON	GY	-40.	25.25	0.

REV 0
DOC. NO. V049-1-071
P.10 OF 19

98. 302 CON GZ 2.25 25.25 0.
99. 302 CON GX 2.25 29.75 0.
100. 302 CON GY -40. 29.75 0.
101. 302 CON GZ 2.25 29.75 0.
102. 302 CON GX 2.25 34.25 0.
103. 302 CON GY -40. 34.25 0.
104. 302 CON GZ 2.25 34.25 0.
105. 302 CON GX 5.063 40. 0.
106. 302 CON GY -90. 40. 0.
107. 302 CON GZ 5.063 40. 0.
108. 302 CON GX 5.063 47.5 0.
109. 302 CON GY -90. 47.5 0.
110. 302 CON GZ 5.063 47.5 0.
111. 302 CON GX 8.44 55. 0.
112. 302 CON GY -150. 55. 0.
113. 302 CON GZ 8.44 55. 0.
114. 302 CON GX 5.063 62.5 0.
115. 302 CON GY -90. 62.5 0.
116. 302 CON GZ 5.063 62.5 0.
117. 302 CON GX 8.44 70. 0.
118. 302 CON GY -150. 70. 0.
119. 302 CON GZ 8.44 70. 0.
120. 304 CON GX 62. 10. 0.
121. 304 CON GY -1100. 10. 0.
122. 304 CON GZ 62. 10. 0.
123. 304 CON GX 31. 20. 0.
124. 304 CON GY -550. 20. 0.
125. 304 CON GZ 31. 20. 0.
126. 304 CON GX 2.25 25.25 0.
127. 304 CON GY -40. 25.25 0.
128. 304 CON GZ 2.25 25.25 0.
129. 304 CON GX 2.25 29.75 0.
130. 304 CON GY -40. 29.75 0.
131. 304 CON GZ 2.25 29.75 0.
132. 304 CON GX 2.25 34.25 0.
133. 304 CON GY -40. 34.25 0.
134. 304 CON GZ 2.25 34.25 0.
135. 304 CON GX 5.063 40. 0.
136. 304 CON GY -90. 40. 0.
137. 304 CON GZ 5.063 40. 0.
138. 304 CON GX 5.063 47.5 0.
139. 304 CON GY -90. 47.5 0.
140. 304 CON GZ 5.063 47.5 0.
141. 304 CON GX 8.44 55. 0.
142. 304 CON GY -150. 55. 0.
143. 304 CON GZ 8.44 55. 0.
144. 304 CON GX 5.063 62.5 0.
145. 304 CON GY -90. 62.5 0.
146. 304 CON GZ 5.063 62.5 0.
147. 304 CON GX 8.44 70. 0.
148. 304 CON GY -150. 70. 0.
149. 304 CON GZ 8.44 70. 0.
150. LOAD COMB 3
151. 1 1. 2 1.
152. PERFORM ANALYSIS

P R O B L E M S T A T I S T I C S

NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS = 10/ 13/ 4
ORIGINAL/FINAL BAND-WIDTH = 6/ 3
TOTAL PRIMARY LOAD CASES = 2, TOTAL DEGREES OF FREEDOM = 48
SIZE OF STIFFNESS MATRIX = 1152 DOUBLE PREC. WORDS
REQD/AVAIL. DISK SPACE = 12.03/ 378.2 MB, EXMEM = 6.69 MB

++ PROCESSING ELEMENT STIFFNESS MATRIX. 12:32:36
++ PROCESSING GLOBAL STIFFNESS MATRIX. 12:32:37
++ PROCESSING TRIANGULAR FACTORIZATION. 12:32:37
++ CALCULATING JOINT DISPLACEMENTS. 12:32:37
++ CALCULATING MEMBER FORCES. 12:32:38

153. *PRINT MATERIAL PROPERTIES ALL
154. *PRINT JOINT COORDINATES ALL
155. *PRINT SUPPORT INFORMATION ALL
156. *PRINT MEMBER INFORMATION ALL
157. *PRINT MEMBER PROPERTIES ALL
158. PRINT JOINT DISPLACEMENTS ALL

JOINT DISPLACEMENT (INCH RADIAN) STRUCTURE TYPE = SPACE

JOINT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
10	1	0.00000	0.00000	0.00000	0.00003	0.00000	0.00016
	2	0.00000	0.00000	0.00000	0.00384	0.00022	-0.00145
	3	0.00000	0.00000	0.00000	0.00387	0.00022	-0.00129
20	1	0.00004	-0.00027	0.00141	-0.00003	0.00000	-0.00033
	2	0.20601	-0.00286	0.27114	-0.00015	0.00022	-0.00286
	3	0.20604	-0.00313	0.27255	-0.00018	0.00022	-0.00318
30	1	0.00000	-0.03539	0.00146	0.00002	0.00000	0.00000
	2	0.20579	-0.24067	0.24518	0.00084	0.00025	0.00042
	3	0.20579	-0.27606	0.24665	0.00086	0.00025	0.00042
40	1	-0.00004	-0.00027	0.00141	-0.00003	0.00000	0.00033
	2	0.20554	-0.00306	0.21760	-0.00023	0.00023	0.00105
	3	0.20550	-0.00333	0.21901	-0.00026	0.00023	0.00138
50	1	0.00000	0.00000	0.00000	0.00003	0.00000	-0.00016
	2	0.00000	0.00000	0.00000	0.00314	0.00023	-0.00337
	3	0.00000	0.00000	0.00000	0.00317	0.00023	-0.00353
60	1	0.00000	0.00000	0.00000	-0.00001	0.00000	0.00015
	2	0.00000	0.00000	0.00000	0.00330	0.00028	-0.00159
	3	0.00000	0.00000	0.00000	0.00330	0.00028	-0.00144
70	1	0.00004	-0.00027	0.00141	0.00005	0.00000	-0.00031
	2	0.18703	-0.00047	0.27119	0.00094	0.00028	-0.00203
	3	0.18707	-0.00074	0.27260	0.00099	0.00028	-0.00234
80	1	0.00000	-0.03030	0.00146	0.00010	0.00000	0.00000
	2	0.18679	-0.12860	0.24522	0.00199	0.00027	0.00039
	3	0.18679	-0.15890	0.24668	0.00209	0.00027	0.00039
90	1	-0.00004	-0.00027	0.00141	0.00005	0.00000	0.00031
	2	0.18651	-0.00079	0.21762	0.00090	0.00030	0.00044
	3	0.18647	-0.00105	0.21903	0.00095	0.00030	0.00075
100	1	0.00000	0.00000	0.00000	-0.00001	0.00000	-0.00015
	2	0.00000	0.00000	0.00000	0.00258	0.00030	-0.00280
	3	0.00000	0.00000	0.00000	0.00257	0.00030	-0.00295

***** END OF LATEST ANALYSIS RESULT *****

- 159. *PRINT MEMBER FORCES ALL
- 160. *PRINT MEMBER STRESSES ALL
- 161. PRINT SUPPORT REACTIONS

SUPPORT REACTIONS -UNIT POUN INCH STRUCTURE TYPE = SPACE

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z
10	1	50.70	390.45	-3.30	0.00	0.00	0.00
	2	144.50	3454.01	-215.09	0.00	0.00	0.00
	3	195.20	3844.46	-218.39	0.00	0.00	0.00
50	1	-50.70	390.45	-3.30	0.00	0.00	0.00
	2	-464.87	3698.52	-182.35	0.00	0.00	0.00
	3	-515.56	4088.97	-185.65	0.00	0.00	0.00
60	1	49.03	390.45	3.30	0.00	0.00	0.00
	2	42.51	566.27	-128.68	0.00	0.00	0.00
	3	91.54	956.72	-125.38	0.00	0.00	0.00
100	1	-49.03	390.45	3.30	0.00	0.00	0.00
	2	-340.81	951.20	-92.55	0.00	0.00	0.00
	3	-389.84	1341.64	-89.25	0.00	0.00	0.00

***** END OF LATEST ANALYSIS RESULT *****

- 162. PARAMETER
- 163. CODE AISC
- 164. MAIN 0. ALL
- 165. WELD 1. ALL
- 166. CHECK CODE ALL

STAAD-III CODE CHECKING - (AISC)

ALL UNITS ARE - POUN INCH (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
100	ST TUB E	PASS 3706.97 C	AISC- H1-3 22932.28	0.393 -21734.79	3 108.00
101	ST TUB E	PASS 335.58 C	AISC- H1-3 -464.13	0.444 65820.25	3 102.00
102	ST TUB E	PASS 362.87 C	AISC- H1-3 -398.99	0.449 -66632.07	3 0.00
103	ST TUB E	PASS 3951.48 C	AISC- H1-3 -19396.53	0.585 55027.61	3 0.00
200	ST TUB E	PASS 819.23 C	AISC- H1-3 12887.65	0.192 -10539.33	3 108.00
201	ST TUB E	PASS 361.06 C	AISC- H1-3 227.05	0.241 35356.93	3 102.00
202	ST TUB E	PASS 407.22 C	AISC- H1-3 337.93	0.241 -35233.39	3 0.00
203	ST TUB E	PASS 1204.16 C	AISC- H1-3 -8985.98	0.368 41448.94	3 0.00
300	ST TUB E	PASS 177.87 C	AISC- H1-3 359.43	0.175 25713.20	3 0.00
301	ST TUB E	PASS 228.27 T	AISC- H2-1 -23.11	0.110 -5896.90	2 0.00
302	ST TUB E	PASS 9.01 C	AISC- H1-3 -564.98	0.045 -5998.97	3 72.00
303	ST TUB E	PASS 103.18 T	AISC- H2-1 -28.97	0.133 -7279.46	3 124.85
304	ST TUB E	PASS 125.55 C	AISC- H1-3 771.02	0.156 22401.43	3 0.00

167. SELECT WELD ALL

STAAD-III WELD DESIGN

ALL UNITS ARE - INCH POUN

MEMBER	LOCATION/ LOADING	WELD TYPE/ HOR STRESS	WELD SIZE/ VERT STRESS	COMB STRESS/ DIR STRESS
100	STA 3	1 174.71	1/16 156.16	3084.49 3075.57
100	END 3	1 82.51	2/16 82.92	12567.55 12567.00
101	STA 3	1 802.92	1/16 1297.58	11632.56 11532.04
101	END 3	1 270.60	3/16 397.90	9936.68 9925.02
102	STA 3	1 290.05	3/16 499.31	10057.32 10040.73
102	END 3	1 439.51	2/16 800.91	13151.09 13119.32
103	STA 3	1 46.28	3/16 134.26	12733.40 12732.61
103	END 3	1 148.52	1/16 412.45	3300.42 3271.18
200	STA 3	1 100.30	1/16 73.23	775.38 765.37
200	END 3	1 90.62	1/16 82.91	12369.77 12369.16
201	STA 3	1 858.48	1/16 932.89	3032.48 2754.75
201	END 3	1 424.80	2/16 414.50	8085.26 8063.44
202	STA 3	1 444.35	2/16 535.50	8114.59 8084.70
202	END 3	1 439.91	2/16 587.44	7635.14 7599.78
203	STA 3	1 30.86	2/16 151.09	12144.24 12143.26
203	END 3	1 71.40	1/16 311.87	1119.99 1073.32

REVO
DOC. NO. V049-1-071
P. 16 OF 19

STAAD-III WELD DESIGN

ALL UNITS ARE - INCH POUN

MEMBER	LOCATION/ LOADING	WELD TYPE/ HOR STRESS	WELD SIZE/ VERT STRESS	COMB STRESS/ DIR STRESS
300	STA 3	1 986.83	1/16 2373.86	12044.01 11766.44
300	END 3	1 960.86	1/16 795.31	8890.62 8802.69
301	STA 2	1 410.22	1/16 620.97	6614.24 6572.24
301	END 3	1 458.68	1/16 758.17	4511.28 4423.39
302	STA 2	1 110.58	1/16 1194.18	1405.35 732.61
302	END 3	1 72.49	1/16 771.92	3080.75 2981.59
303	STA 2	1 17.50	1/16 120.31	6359.39 6358.23
303	END 3	1 39.66	1/16 226.60	7912.75 7909.41
304	STA 3	1 767.11	1/16 2155.18	10724.02 10477.19
304	END 3	1 721.40	1/16 707.88	7439.25 7370.27

***** END OF TABULATED WELD DESIGN *****

168. STEEL TAKE OFF

REV 0
 DOC. NO. V049-1-071
 P172E 19

STEEL TAKE-OFF

PROFILE	LENGTH(INCH)	WEIGHT(POUN)
ST TUB E	1056.00	1344.293
ST TUB E	249.70	217.493

	TOTAL =	1561.79

***** END OF DATA FROM INTERNAL STORAGE *****

- 169. LOAD LIST ALL
- 170. LOAD LIST 2 3
- 171. FINISH

***** END OF STAAD-III *****

**** DATE= MAR 23,1996 TIME= 12:32:39 ****

 * For questions on STAAD-III, contact: *
 * Research Engineers, Inc at *
 * Ph: (714) 974-2500 Fax: (714) 921-2543 *

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-107 PAGE 1 OF 31
REV.	DEO #	DATE	BY:	CHECK	TITLE: Welds for 60.5 in Nozzle to Shell Joints	
0	0253	8/1/96	RDC	WDB		
					BY: R. D. Ciatto	DEPT.: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> Evaluate nozzle to shell welded joints in BSCs and HAMs for the 60.5 nozzles using an alternative design to the full penetration butt weld.						
<u>METHOD:</u> Hand calculations are used to determine the weld stresses from the moments and forces obtained from the BSC and HAM FE analyses.						
<u>ASSUMPTIONS:</u> N/A						
<u>INPUTS:</u> LIGO project drawing V049-4-001 - Beam Splitter Chamber. LIGO project drawing V049-4-002 - Horizontal Access Module Calc. No. V049-1-066, Structural Design Criteria Calc. No. V049-1-022, BSC, FE Analysis of Lower Section, V049-1-039, HAM FE Analysis						
<u>REFERENCES:</u> See INPUTS						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> The nozzle to shell welds shown in this calculation have the strength required to resist the discontinuity forces computed in the FE analysis. The calculation results were verified by bend tests that simulated the proposed configuration of the connection.						
<u>NOTES:</u> See the attachment to this calculation for sketches of the revised nozzle to shell weld connection.						

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-107
		Rev. No. 0
		PAGE 2 OF 31
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO: V59049	
CALCULATION TITLE: Welds for 60.5" Nozzle to Shell Joints		

TABLE OF CONTENTS

BSC - Beam Splitter Chamber

Review of Nozzle Welds	3
Stress Contour Plots	4
IMAGES-3D Finite Element Model	6
Plate Stresses	7
Analytical Review	9
Partial Penetration Weld	12
1/4" Stitch Fillet Weld	14
1/8" Partial Penetration Weld	15
3/16" Stitch Fillet Weld	17

HAM - Horizontal Access Module


Review of Nozzle Welds	18
Stress Contour Plots	19
IMAGES-3D Finite Element Model	22
Plate Stresses	24
Analytical Review	26
1/8" Partial Penetration Weld	27
3/16" Stitch Fillet Weld	27
Review of Connection Bend Tests	29
Attachment 'A'	
Welded Joints at Nozzle to Shell Connections	A-1
Welded Joint Connection Details	A-2
Bend Test Procedure	A-4



THE CURRENT WELD DESIGN FOR THE BEAM SPLITTER NOZZLE-TO-SHELL WELD AT THE GDS IN PORTS IS A FULL PEN WELD. THE STRESSES COMPUTED DIRECTLY BY IMAGES ARE APPROPRIATE FOR THE EVALUATION OF THIS WELD AS PERFORMED IN CALL V049-1-022 FOR THE BSC




THAT CALL SHOWED THAT THE MAX SI AT THE NOZZLE SHELL JUNCTION IS 23.5 KSI AT THE BOTTOM OF THE NOZZLE. A REVIEW OF THE BHSPL12 IMAGES FILE CONFIRMED THAT ALL OTHER LOCATIONS AT THIS WELD HAD LOWER STRESSES. THE REVIEW WAS PERFORMED BY OBSERVING STRESS INTENSITY CONTOUR PLOTS OF THE BEAM SPLITTER MODEL FOR THE 3 LOAD CASES THAT HAD BEEN EVALUATED.

THE MOST HIGHLY STRESSED ELEMENT FOR THE BEAM SPLITTER IS PLATE 1 (P1). TO EVALUATE THE ALTERNATE WELDED CONNECTION, THE PLATE LOADS PER UNIT LENGTH HAVE BEEN PRINTED FOR P1.



Sign convention for Plate Loads/Unit Length

IMAGES-3D
Version 3.0



Load Case
1




Surf: Top

Stress Contour Plot
Stress Intensity

7/30/96
15:27:43

IMAGES-3D
Version 3.0

NOZZLE - SKULL JUNCTION
AT BOTTOM OF NOZZLE





Load Case
1

Stress Contour Plot
Surf: Top
Stress Intensity

7/30/96
15:46:47

IMAGES-3D
Version 3.0



Auto Node# Blowup Move Contour Rotate Displ Range Elem# Scale Exit Shade Help Slice Lcase Stress


PLATE LOADS AND/OR STRESSES

Lloads		fx		fy		fxy		mx		my		mxy
Lloads		f1		f2		Angle		m1		m2		Angle
Lloads		Vx		Vy								
Stress	Surf	Sigma	X	Sigma	Y	Tau XY		Sigma 1		Sigma 2		Angle
Stress		Sigma	Z	Von Mises		Tau XZ		Tau YZ				
PLATE NO. 1												
Lloads		-.3926E+03		-.9719E+04		-.6371E+02		.4350E+03		.2220E+03		.1080E+02
Lloads		-.3922E+03		-.9720E+04		-.39		.4355E+03		.2214E+03		2.89
Lloads		.2171E+03		-.3003E+02								
Stress	TOP	.9654E+04		-.1411E+05		.1317E+03		.9655E+04		-.1411E+05		.32
				.2070E+05								
Stress	MID	-.7853E+03		-.1944E+05		-.1274E+03		-.7844E+03		-.1944E+05		-.39
				.1906E+05		.6513E+03		-.9008E+02				
Stress	BOT	-.1122E+05		-.2477E+05		-.3865E+03		-.1121E+05		-.2478E+05		-1.63
				.2149E+05								

SHIFT
 COMMANDS F2 F3 F4 F5 F6 scroll speed
 ↑↓ auto scroll

PLATE P1

NODES ARE 1, 2, 5, 4
I, J, K, L



LOCAL X = 0 => LOCAL Y-AXIS IS
FROM I TO J = 1 TO 2

LOADS PER UNIT LENGTH FOR PLATE 1
FROM BMSPL12.30U FILE

$$f_y = 393$$

$$f_j = 9719$$

$$f_{xy} = 64$$

$$m_y = 435$$

$$m_j = 222$$

$$m_{xy} = 11$$

$$f_1 = 393$$

$$f_2 = 9720$$

$$m_1 = 436$$

$$m_2 = 221$$

$$v_y = 217$$

$$v_j = 30$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



MAXIMUM BENDING MOMENT $M_y = 435 \text{ W-LB/IN}$
 CHECK BENDING STRESS

$$f_b = \frac{6 M_y}{t^2}$$

$$= \frac{6(435)}{.5^2}$$

$$= 10440 \text{ PSI}$$

DIRECT STRESS DUE TO MEMBRANE LOAD


$$f_a = \frac{f_x}{t} = \frac{393 \text{ LB/IN}}{.5}$$

$$= 786$$

TOTAL SURFACE STRESS

$$f = 10440 + 786 = 11226 \text{ OR}$$

$$= \sigma_y \text{ BOT}$$




$$\frac{6 M_y}{t^2} + \frac{f_x}{t} = \frac{6(222)}{.5^2} + \frac{9719}{.5}$$


$$= 5328 + 19438 = 24766$$

CHECKS W/ σ_y ON BOT OR

PARTIAL END VIEW OF NOZZLE
LOOKING IN




x, y, z ARE
LOCAL AXES




22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



ISOMETRIC VIEW OF PI SHOWING PROPOSED WELD



FROM THE ABOVE SKETCH, IT IS OBSERVED THAT M_y IS REACTED BY A FORCE COUPLE IN THE WELDS. IN ADDITION, F_y SHEARS THE WELDS AND V_y STRESSES THE WELDS IN TENSION OR COMPRESSION.



22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



IT MAY BE ASSUMED THAT THE PAR
PEN WELD RESISTS V_x (TEN), f_y (SHEAR)

AND ONE OF THE FORCES FROM THE
COUPLE RESULTING FROM M_x WHICH WILL
IMPOSE TENSION.

$$M_x = 435 \text{ IN-LB/IN}$$

THE COUPLE FORCES ARE .5 IN APART.

$$P(.5) = 435$$

$$P = \frac{435}{.5} = 870 \frac{\text{LB}}{\text{IN}}$$

$$V_y = 217 \text{ LB/IN}$$

TENSILE STRESS IN PAR PEN WELD
WHICH IS .25 IN WIDE

$$\begin{aligned} f_t &= \frac{P + V_y}{.25} \\ &= \frac{870 + 217}{.25} = 4348 \text{ psi} \end{aligned}$$


SUPERPOSE THE WORST CASE
FLANGE TENSION FORCE WHICH IS
362 LB/IN FOR THE 30.25 IN FLANGE
(REF CALC 042, P. 17)

$$\begin{aligned} f_t &= 4348 + \frac{362}{.25} = 4348 + 1448 \\ &= 5800 \text{ psi} \end{aligned}$$

SHEAR STRESS IN PAR PEN WELD

$$\begin{aligned} \tau &= \frac{f_x}{.25} \\ &= \frac{393}{.25} \\ &= 1572 \text{ psi} \end{aligned}$$

COMPUTE PRINCIPAL STRESS IN PAR PEN WELD



$$\sigma_{1,2} = \frac{1}{2} (\sigma_x + \sigma_y) \pm \left\{ \left[\frac{1}{2} (\sigma_x - \sigma_y) \right]^2 + \tau^2 \right\}^{\frac{1}{2}}$$

$$\sigma_x = 0$$

$$\sigma_y = f_t = 5800$$

$$\tau = 1572$$

$$\sigma_{1,2} = \frac{5800}{2} \pm \sqrt{\left(\frac{5800}{2}\right)^2 + 1572^2}$$

$$= 2900 \pm 3300$$

$$\sigma_1 = 6200 \text{ psi } \checkmark$$

$$\sigma_2 = -400 \text{ psi } \checkmark$$

THE MAX STRESS INTENSITY IS

$$SI = \sigma_1 - \sigma_2 = 6600 \text{ psi } \text{ OR}$$



SHEAR STRESS IN THE STITCH FILLET WELD. ASSUME 1/4 IN

$$\tau = \frac{P}{.707(.25)} \times \frac{S}{L}$$

$$P = 870 \frac{LB}{IN}$$

S = WELD SPACING - ASSUME 4 IN

L = WELD LENGTH - ASSUME 3 IN

$$\tau = \frac{870}{.707(.25)} \times \frac{4}{3}$$

$$\approx 6600 \text{ psi}$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



FOR THE PARTIAL PENETRATION WELD TRY
A 1/8" THROAT THICKNESS

SHEAR STRESS

$$\begin{aligned} \tau &= \frac{f_v}{.125} \\ &= \frac{393}{.125} = \\ &= 3144 \text{ PSI} \end{aligned}$$

TENSILE STRESS

$$\begin{aligned} f_t &= \frac{P + V_y}{.125} \\ &= \frac{870 + 217}{.125} \\ &= 8696 \text{ PSI} \end{aligned}$$

ADD WORST CASE TENSILE FORCE FROM
EXTERNAL LOAD (362 LB/IN)

$$\begin{aligned} f_t &= 8696 + \frac{362}{.125} = 8696 + 2896 \\ &= 11592 \end{aligned}$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



PRINCIPAL STRESS FOR 1/8" PAR PEN WELD

$$\sigma_{1,2} = \frac{11552}{2} \pm \sqrt{\left(\frac{11552}{2}\right)^2 + 3144^2}$$

$$= 5800 \pm \sqrt{5800^2 + 3144^2}$$

$$= 5800 \pm 6594 \text{ psi}$$

$$\sigma_1 = 12400 \text{ psi}$$

$$\sigma_2 = -800 \text{ psi}$$

MAX STRESS INTENSITY AT 1/8" PAR PEN WELD

$$SI = \sigma_1 - \sigma_2 = 12400 - (-800) \\ = 13200 \text{ psi}$$

THIS STRESS MAY BE CONSIDERED A PRIMARY LOCAL MEMBRANE STRESS SINCE IT ACCOUNTS FOR DISCONTINUITY MOMENT AND FORCE AT THE NOZZLE SHELL JUNCTION. IT IS IN THE PL CATEGORY PER ASME VIII -2, PAR 4-132.

$$P_L = 13200 < 1.5 S_M = 28.0 \text{ ksi @ } 480^\circ\text{F} \\ \text{FOR DUAL GRADE 304/304L} \quad \text{OR}$$

NOTE 308L WELD WIRE HAS HIGHER STRENGTH THAN EITHER 304 OR 304L.

TRY A 3/16 STITCH FILLET WELD ON
THE OUTSIDE OF THE SHELL

$$\tau = \frac{P}{.707 (3/16)} \frac{S}{L}$$

$$S = 4 \text{ IN}$$

$$L = 3 \text{ IN}$$

$$\tau = \frac{870}{.707 (18.75)} \times \frac{4}{3}$$
$$= 8750 \text{ PSI}$$

SINCE THIS WELD RESISTS PURE SHEAR
AT THE MIN THROAT, IT WILL BE
COMPARED TO $.6 S_H$ IN ACCORDANCE WITH
AD 132.2 OR THE CODE (SECT VIII, DIV 2).

$$\tau = 8.75 \text{ KSI} < .6 S_H = .6 (18.7) = 11.2 \text{ KSI}$$

OK

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



HAM NOZZLE

THE MAXIMUM STRESS IS AT PLATE ELEMENT P1828. THE ELEMENT LISTING OF THIS ELEMENT IS


1828) P 1673, 1668, 1903, 1904, 2, 0

LOC X \downarrow




FOR THE HAM 6 IMAGES FILE.

THIS ELEMENT IS LOCATED AT THE NOZZLE SHELL JUNCTION ON THE 60 IN NOZZLE WHICH IS ADJACENT TO THE BELLOWS. THE MAX STRESS IS FOR LOAD CASE 1 WHICH ACCOUNTS FOR THE UNBALANCED FORCE FROM HAVING THE COVER ON ONE SIDE AND THE BELLOWS ON THE OTHER. THE MAX SI AT P1828 IS 28.5 KSI AS SHOWN ON THE FOLLOWING PLOTS.

SINCE $LOC X = 0$, THE LOCAL Y AXIS IS DEFINED BY THE LINE FROM I TO J (1673 TO 1668). THE ELEMENT IS ORIENTED AS FOLLOWS.



IMAGES-3D
Version 3.0






Load Case
1

Stress Contour Plot
Surf: Top
Stress Intensity

7/31/96
9: 6:43

IMAGES-3D
Version 3.0





Load Case
1

Stress Contour Plot
Surf: Top
Stress Intensity

7/31/96
10:51:32

IMAGES-3D
Version 3.0



Load Case
1

Stress Contour Plot
Surf: Top **Stress Intensity**


7/31/96
9:36:49

IMAGES-3D
Version 3.0

Select an option

- 1-Plate or 1,F,I
- 2-Axi-Shell or 2,F,I
- 3-Axi-Solid or 3,F,I
- 4-Solid or 4,F,I
- 5-No element numbers
- 6-All elemt. numbers
- 7-Exit or 7,Size

?7,1
?b
?#
?



Auto	Blowup	Contour	Displ	Elem#	Exit	Help	Lcase
Node#	Move	Rotate	Range	Scale	Shade	Slice	Stress

DATE: 04/01/96 11:57:00

MSOFF (06/17/96)

PLATE NO. 1828

LLoads	-.6605E+04	-.6634E+02	.1845E+03	.4388E+03	.1172E+04	.5480E+02
LLoads	-.6114E+02	-.6610E+04	88.39	.1176E+04	.4347E+03	85.75
LLoads	.6542E+02	-.1700E+03				

PROCESS ENGINEERING INC. S/N:802506A

07/31/96

PAGE 532

Run ID=

13:43:20

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

SOLVE PLATE LOADS/STRESSES

Version 3.0 12/31/93

Filename=HAM6

Title =

Load Case 1:ONE BAFFLE LOADING

SOLVE

COMMANDE F2 F3 F4 F5 F6

is done onll

Filename=HAM6

Title =

Load Case 1: ONE BAFFLE LOADING

Lloads		fx	fy	fxy	mx	my	mxY
Lloads		f1	f2	Angle	m1	m2	Angle
Lloads		Ux	Uy				
Stress Surf		Sigma X	Sigma Y	Tau XY	Sigma 1	Sigma 2	Angle
Stress		Sigma Z	Von Mises	Tau XZ	Tau YZ		
Stress	TOP	-.2680E+04	.2799E+05	.1684E+04	.2808E+05	-.2772E+04	86.87
			.2957E+05				
Stress	MID	-.1321E+05	-.1327E+03	.3689E+03	-.1223E+03	-.1322E+05	88.39
			.1316E+05	.1963E+03	-.5099E+03		
Stress	BOT	-.2374E+05	-.2826E+05	-.9462E+03	-.2355E+05	-.2845E+05	-11.37
			.2634E+05				

PLATE NO. 1829

0.000000
 0.000000 F2 F3 F4 F5 F6
 0.000000

FROM THE HAM6.300 FILE

$$f_x = 605 \text{ LB}$$

$$f_y = 66$$

$$f_{xy} = 185$$

$$m_x = 439 \text{ IN-LB}$$

$$m_y = 1172$$

$$m_{xy} = 55$$

$$v_x = 65 \text{ LB}$$

$$v_y = 170$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



PRINCIPAL STRESS FOR 1/8" PAW PEN WELD

$$\sigma_{1,2} = \frac{22176}{2} \pm \sqrt{\left(\frac{22176}{2}\right)^2 + 1360^2}$$

$$= 11088 \pm \left(11088^2 + 1360^2\right)^{\frac{1}{2}}$$

$$= 11088 \pm 11171$$

$$\sigma_1 = 22260 \text{ psi}$$

$$\sigma_2 = -80 \text{ psi}$$

$$SE = 22260 - (-80) = 22340$$

$$< 1.5 S_M = 28.0 \text{ ksi @ } 400^\circ\text{F}$$

FOR THE 3/16 STITCH FILLET WELD ON THE OUTSIDE

$$\tau = \frac{P}{.707(3/16)} \frac{L}{L}$$

$$= \frac{2344}{.707(3/16)} \times \frac{4}{3}$$

$$= 23576 > 11.2 \text{ ksi} \quad \checkmark$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



CHECK THE WELD USING THE AISC
CRITERIA FOR FILLET WELDS

$$\tau < .30 F_u \text{ OR WELD METAL}$$


$$F_u = 85 \text{ KSI FOR 308 L FILLER}$$

$$\tau = 23.6 < .30(85) = 25.5 \text{ KSI} *$$

BUT WELD METAL STRENGTH IS GREATER
THAN THE BASE METAL

* @ 70°F - $F_u < 85$ FOR ELEVATED TEMP.

NOTE THIS FILLET WELD WILL BE
CHANGED TO A 1/4" FOR 18" AT
THE MID HEIGHT ON THE NOZZLE.



MAKE IT CONTINUOUS FOR THIS LENGTH


$$\tau = \frac{2344}{.707(.25)} = 13.3 \text{ KSI} \approx 11.2 \text{ KSI}$$




THE INTEGRITY OF THE 1/4 PAA PEN WELD COMBINED WITH THE 3/16 FILLET WELD WAS VERIFIED IN BEND TESTS OF SEVERAL SPECIMENS.

SEE THE ATTACHMENT FOR THE TEST SEQUENCE. THE TESTS WERE PERFORMED ON 8/9/96. THE OBJECTIVE OF THE TESTS WAS TO SHOW THAT THE CONNECTION DEVELOPS MOST OF THE MOMENT CAPACITY OF THE 1/2" SHELL. THIS IS IMPORTANT SINCE THE FILLET WELD STRENGTH IS CLOSE TO ITS ALLOWABLE.

TO DEVELOP BENDING MOMENT AT THE WELD, THE SPECIMENS WERE LOADED AS FOLLOWS



PARTIAL PEN IN TENSION



FILLET IN TENSION

THE LOAD P WAS APPLIED BY AN TENERPAC TEST MACHINE WITH A 2 IN Φ HYDRAULIC PISTON. THE PRESSURE WAS NEVER BELOW 1000 PSI FOR ANY TEST

$$P = pA = 1000 \text{ PSI} (1)^2$$

$$P_{MIN} = 3142 \text{ LB}$$



THE MIN MOMENT AT THE WELD IS

$$M = \frac{PL}{4}$$

$$= 3142 \left(\frac{4}{4} \right) = 3142 \text{ IN-LB}$$

FOR THE SA 240 TP 304/304L MATERIAL, THE MIN YIELD STRESS AT ROOM TEMP IS

$$S_y = 30 \text{ KSI AND THE}$$

ULT STRENGTH IS

$$S_u = 75 \text{ KSI}$$

THE YIELD MOMENT OF THE 1/2 IN SECTION IS

$$M_y = \frac{bt^2}{6} S_y$$

$$b = 1 \text{ IN FOR SPECIMENS}$$

$$t = .5 \text{ IN}$$

$$M_y = \frac{1 (.5)^2}{6} (30000)$$

$$= 1250 \text{ IN-LB}$$


THE FULL PLASTIC MOMENT IS

$$M_p = \frac{bt^2}{4} S_y$$

$$= 1875 \text{ IN-LB}$$

THEREFORE, THE WELDS DEVELOPED MOMENTS THAT ARE GREATER THAN THE MOMENT CAPACITY OF THE BASE METAL AND THERE WAS CONSIDERABLE STRAIN HARDENING OF THE BASE METAL.

THE DEFORMED SPECIMENS SHOWED YIELDING OF THE 1/2" SECTION



IT IS CONCLUDED THAT THE REVISED NOZZLE TO SHELL WELDED CONNECTION WILL DEVELOP FULL STRENGTH OF THE SHELL.



ATTACHMENT

PROCESS SYSTEMS INTERNATIONAL, INC.

✓ **LIGO PROJECT**

Doc. No. V049-I-85

To: Phil Ferland

From: Ray Ciatto *RDC*

Subject: Welded Joints at Nozzle to Shell Connections

Date: August 2, 1996

A modified welded joint for the 60.5 in nozzle to shell connection has been designed for the BSC and HAM. The joint will consist of a partial penetration weld on the inside and an intermittent fillet weld on the outside as shown on the attached sketches which are included in the supporting calculation for the modified joint.

I request that bend tests of this weld configuration be performed; these are necessary to qualify the connection. The requirements for these bend tests are also attached. So that we may compute the maximum bending moment, we should note the maximum force applied by the test machine.


Please call if you have any questions on the weld tests.

cc: Rich Bagley Dave McWilliams Tom Starr Dick Curtis
 Dave Evers Paul Hendry Stu Motew Walt Bilynsky
 Roberto Than Lynne Long/project file

ATTACHMENT

WELDS FOR 60.5 IN NOZZLE TO SHELL JOINTS IN BSCs AND HAMS.

BSC WELD




22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS




HAM WELD

SAME AS BSC WELD EXCEPT THAT
 FILLET WELD SHOULD BE 1/4 IN
 FOR AN 18" LENGTH AT MID HEIGHT
 OF NOZZLE

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



TEST A - FILLET WELD IN TENSION



3 TESTS

TEST B - PAR PEN WELD IN TENSION




3 TESTS

TESTS C AND D - SAME AS TESTS A & B BUT INCREASE PP WELD TO 3/16" AND INCREASE FILLET TO 1/4"

NOTE: AN ALTERNATE METHOD OF LOADING THE SPECIMENS TO OBTAIN THE MAXIMUM MOMENT AT THE WELD IS ACCEPTABLE.

WELD TEST



BASE METAL SA 240 304/304L

PLATE WIDTH, W , REQUIRED FOR TEST SHALL BE DETERMINED.

PLATES SHALL BE FLAT. AFTER WELDING CUT INTO COUPONS FOR BOND TESTS.

PERFORM 3 BOND TESTS THAT APPLY TENSILE STRESS TO PAR BOW WELDS AND 3 TESTS THAT APPLY TENSILE STRESS TO FILLET WELDS.

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-039 PAGE 1 OF 19
REV.	DEO #	DATE	BY:	CHECK	TITLE: HAM Finite Element Analysis	
0	0128	11/22/97	KM	RDC		
					BY: Kyle Martini	DEPT.: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> Evaluate the horizontal access module (HAM)						
<u>METHOD:</u> Finite element method and hand calculations.						
<u>ASSUMPTIONS:</u> See attached.						
<u>INPUTS:</u> LIGO project drawings and sketches. Shell thickness = 0.5 in, 60 in nozzle thickness = .5 in, head thickness = 0.375 in Thickness of other nozzles = 0.125 in, saddle wear plate thickness = 0.75 in, Thickness of saddle and stiffeners = 0.5 in, baseplate thickness = 1.0 in						
<u>REFERENCES:</u> <i>Doc. No V049-1-000, LIGO VE STRUCT. DESIGN CRITERIA</i> 1. ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Div. 1 and Div. 2. 2. IMAGES 3D, Version 3.0, R. L. Cloud & Associates 3. Hilti Concrete Fastener Catalog						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> Stress are within the limits of the ASME Code, Section VIII, Div. 2.						
<u>NOTES:</u> Computer files are HAM6.*						

SUMMARY

<u>Load case</u>	<u>Max Stress Intensity</u>	<u>ASME SECDIII DW2 Allowable Stress</u>
1. One Bellow Design	$P_L + P_B + Q = 28.6 \text{ KSI}$ $P_L = 26.5 \text{ KSI}$ Bolt Force = 8683 lb	$3S_m = 56.1 \text{ KSI}$ $1.5S_m = 28.0 \text{ KSI}$ 10,960 lb
2. Two Bellow Design	$P_L + P_B + Q = 16.5 \text{ KSI}$ $P_L = 15.8 \text{ KSI}$	$3S_m = 56.1 \text{ KSI}$ $1.5S_m = 28.0 \text{ KSI}$
3. Seismic	$X = 0.15 \text{ KSI}$ $Y = 0.05 \text{ KSI}$ $Z = 0.11 \text{ KSI}$	
4. Lifting	2.7 KSI	

50 SHEETS
100 SHEETS
200 SHEETS



1.0 MODEL (ref Dwg. V049-4-002)

The HAM finite element model was created using Images. A computer plot of the model is shown in Figure 1. Additional information including a listing, diagrams identifying nodes and elements, loads and plots can be found in Appendix A.

The model is $1/2$ symmetrical using B.C to represent the second half. The total weight of the model is 6300^{lb}.

2.0 ANALYSIS

2.1 One Bellows External Pressure Analysis

The HAM can be configured with one or two opposing bellows. In the analysis it is assumed that the bellows does not transmit any loads or add any stiffness. With one bellows an external pressure unbalance occurs and there are external reaction. A pressure load of -14.7 PSI is applied everywhere. At nozzle which are conservatively modeled with caps the load is applied as a line load equal to P_{nozzle}

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS
AMRAD

The unbalance loading is shown on the deform plot of Figure 2. The effect of the overturning moment can be vividly seen. On the bellow side (opposite the unbalance loaded side) the compressive forces due to the overturning moment combine with the compressive forces from the external pressure. This produces greater deformation and higher stresses. On the loaded side the forces due to the overturning moment subtract from the external pressure forces.

Figure 3 is a contour plot of the resultant displacements $\delta_s = \sqrt{\delta_x^2 + \delta_y^2 + \delta_z^2}$. The maximum displacements occurs at the locations farthest from the center of rotation of the overturning moment. This occurs at the top of nozzle "B" the tube is 22 in. The maximum and minimum displacements in each directions are

<u>direction</u>	<u>max</u>	<u>min</u>
X	+0.11"	-0.04"
Y	+0.14"	-0.30"
Z	+0.05"	-0.34"

Stress Intensity contour plots of the model at the top surface, bottom surface, and averaged across the thickness (membrane) are shown in Figures 4-6. The highest stresses occur at local discontinuities such as nozzle-vessel junction and saddle support locations on the vessel. The maximum stress intensities are

Top Surface	- 26.9 KSI
Bottom Surface	28.6 KSI
Membrane	26.5 KSI

Using ASME SEC VIII Div 2 rules.
The basic allowable stress intensity is

$$S_m = 18.7 \text{ KSI @ } 400^\circ\text{F for TP 304}$$


These stresses are discontinuity stresses and the maximum allowable stress for combined bending and membrane are

$$P_L + P_b + Q = 28.6 < 3 S_m = 56.1 \text{ KSI } \underline{\text{OK}}$$

For membrane alone

$$P_L = 26.5 \text{ KSI} < 1.5 S_m = 27.8 \text{ KSI } \underline{\text{OK}}$$

The maximum anchor load due to the off balance load is calculated as follows



$$P = \frac{(14.7)(60.5)^2 \pi}{(4)(12 \text{ bolts})} = 21,129 \#$$

$$h = 65.75''$$

$$l = \frac{P}{h}$$

Assume only outer bolts take load

$$F_{\text{bolt}} = \frac{Ph}{l(2 \text{ bolts})} = \frac{(21129 \#)(65.75'')}{(80'')(2 \text{ bolts})}$$

$$F_{\text{bolt}} = 8683 \#$$

For 3000 psi concrete, and a 1" Hilti adhesive anchor embedded @ 4" $F_{\text{anchor}} = 10960 \#$

$$F.S. = \frac{10960}{8683} = 1.26 \quad \text{OK}$$

2.2 Two Bellow External Pressure Analysis

In this configuration there is no unbalance loading and no external reaction. The contour plot of the deflection is shown in Figure 7. The maximum deflections for each direction are

<u>Direction</u>	<u>MAX</u>	<u>MIN</u>
X	+1.05	-0.04
Y	+1.06	-0.16
Z	+1.05	-1.05

Figures 8, 9, and 10 plot the stress intensities for this configuration. The max values are

Top surface	15.3 KSI	L 56.1 KSI
Bottom surface	16.5 KSI	L 56.1 KSI
Membrane	15.8 KSI	L 27.8 KSI

There are no external reaction.


2.3 SEISMIC

The seismic acceleration (per ASCE 7-88) are 0.05625 g in each direction. The weight of the HAM model is 6269#

$$F_{\text{seismic}} = (0.05625)(6269) = 352\#$$


This is a small force compared to the unbalance force due to the external pressure which is 42,258#. The corresponding stresses are also small. From the computer model the maximum stresses are

<u>Direction</u>	<u>Stress</u>
X	150 PSI
Y	54 PSI
Z	108 PSI

2.4 LIFTING LUGS

For the lifting lug analysis, the vessel was supported at four points on the stittees for the lifting lug. The maximum stress for a 2 "g" load (DLF = 2.0) is 2.7 KSI

The maximum ^{lift} force on lug 1575#





12/19/98

Fig 1 - FE Model

MASS MODEL

UNDEFORMED SHAPE

IMAGES-3D
Version 3.0
L Case 1
S= .300E+02



Revision No. 0
Doc. No. V049-1-039
Page 11 of 19




Fig 2

Deflected Shape - Wireframe Plot

12/20/95
9: 8:53

11 of 19

IMAGES-3D
Version 3.0



Revision No. 0
Doc. No. V049-1-039
Page 12 of 19

Load Case
1

Fig 3

Displacement Contour Plot
DS




1- Bellows Model

1/20/96
17:26:51

12-3-19

3

IMAGES-3D
Version 3.0



Revision No. 0
Doc. No. V049-1-039
Page 13 of 19

Load Case
1

Surf: Top

Stress Contour Plot
Stress Intensity




1/16/96
11:50:53

Fig 4 One Bellows Model

13 20 19

4

IMAGES-3D
Version 3.0



Revision No. 0
Doc. No. V049-1-039
Page 14 of 19

Load Case
1



Stress Contour Plot
Surf: Bottom Stress Intensity

1/16/96
12:15: 4

Fig 5: One Bottom Area

1/16/96

IMAGES-3D
Version 3.0



Revision No. 0
Doc. No. V049-1-039
Page 15 of 19

Load Case
1

Membrane




Stress Contour Plot
Stress Intensity

1/16/96
12: 5:39

Fig 6 one Bellows Model

15 07/19

IMAGES-3D
Version 3.0



Revision No. 0
Doc. No. V049-1-039
Page 16 of 19

Load Case
2




Displacement Contour Plot
DS

1/20/96
17:34:46

Fig 7 Two Bellows Model

1/20/96

IMAGES-3D
Version 3.0



Revision No. 0
Doc. No. V049-1-039
Page 17 of 19

Load Case
2




Stress Contour Plot
Stress Intensity
Surf: Top

1/16/96
12:53:58

Fig 8 Two Bellows Model

170-19

IMAGES-3D
Version 3.0



Revision No. 0
Doc. No. V049-1-039
Page 18 of 19

Load Case
2




Stress Contour Plot
Surf: Bottom Stress Intensity

1/16/96
13:19:28

Fig 9 Two Bellows Model

180419

IMAGES-3D
Version 3.0



Revision No. 0
Doc. No. V049-1-039
Page 19 of 19

Load Case
2

Membrane

Stress Contour Plot
Stress Intensity

1/20/96
17:50:52

Fig 10 Two Bellows Model


19 07-19

10

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-041 PAGE 1 OF 6
REV.	DEO #	DATE	BY:	CHECK	TITLE: HAM Buckling Analysis	
0	0128	1/29/96	KM	RDC		
					BY: Kyle Martini	DEPT.: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> Evaluate the horizontal access module (HAM) for buckling modes.						
<u>METHOD:</u> Finite element method and hand calculation.						
<u>ASSUMPTIONS:</u> See attached.						
<u>INPUTS:</u> LIGO project drawings and sketches. Shell thickness = 0.5 in, 60 in nozzle thickness = 0.5 in, head thickness = 0.375 in Thickness of other nozzles = 0.125 in, saddle wear plate thickness = 0.75 in, Thickness of saddle and stiffeners = 0.5 in, baseplate thickness = 1.0 in						
<u>REFERENCES:</u> NASTRAN Finite Element Program <i>Doc. No. V049-1-060, LIGO VAC. EQUIP. STRUCT. DES. CRITERIA</i>						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> The minimum factor of safety against elastic buckling for vacuum loading is 3.58.						
<u>NOTES:</u> <i>COMPUTER FILE: HAM6D.WP</i>						

1.0 Hand Analysis

- Assumptions:
- (1) Extra material at nozzle replaces slittness of vessel material removed
 - (2) pressure uniform
 - (3) Cylinder length 74.8"



Per. Root sch. ed Table 35 case 19b
 Shell cylinder of length 74.8" ends
 held circular bolt otherwise
 not constrained, no end loads

$$P_{cr} = 0.807 \frac{Et^2}{Lr} \sqrt{\frac{I}{(1-\nu)^2} \frac{t^2}{r^2}}$$

$$L = 74.8"$$

$$r = 42.25"$$

$$\nu = 0.13$$

$$t = 0.15"$$

$$E = 29(10^6) \text{ PSI}$$

$$P_{cr} = 216.1 \text{ PSI}$$

$$F.S. = \frac{P_{cr}}{14.7} = \underline{\underline{14.7}}$$

2.0 Computer Analysis

- a. The same length shell is analyzed using NASTRAN buckling program
- b. The shell is $\frac{1}{2}$ " thick with the opening for the 60" diameter tubes.
- c. The small nozzles are not modeled. It is assumed the stiffness of the nozzle replaces the stiffness removed by the hole.
- d. The stiffness of the tube nozzles are modeled as beams. Assuming the nozzles extend 3" and are $\frac{1}{2}$ " thick.
- e. The vessel junction with the side heads are modeled as reinforced areas 3" x $\frac{1}{2}$ "
- f. An external pressure of 12.7 PSI is applied to all plate elements.
- g. An axial ring load is applied to the ends of the vessel equal to $-pA$
- h. The vessel is restrained at its supports
- i. Two configurations are modeled. A two bellows configuration and a one bellows

2.1 Results

	Model	Factor of Safety
2	- bellows	11.8
1	- bellow (see fig)	11.9

REV 0
 Doc. No U049-1-041
 P. 3 OF 6

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS
 AIRCAD

3.01 Alternative Model

Analysis on static stress model. (See Fig 2)
 Reference Calc. V049-1-039

<u>Model</u>	<u>Factor of Safety</u>	
1 - bellows	3.58	> 3.0
2 - bellows	3.89	> 3.0


These values are believed to be conservative.
 The buckling modes extracted by NASTRAN
 are spurious due to the complicated model.
 The real modes are higher.

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



Fig 5a5


2/18/98 MAX-DEF. = 1.00000000



HAM 1/1 SYAM MODEL
BUCKLING SOLUTION
MODAL DEFORM. SUBCASE 2 MODE 5 EIGENV. 11.76848 MASS MODEL.

Fig 1 - one bellows buckling shape

REV D
DOE, No V049-1-041
P. 5 OF 6



MASS MODEL

UNDEFORMED SHAPE

Fig. 2 - F.E. Model

REV 0
DOC. NO. V049-1-DV1
P. 6 OF 6

12/19/98

1

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-073
REV.	DEO #	DATE	BY:	CHECK	PAGE 1 OF 29	
0	0029	4-1-96	AGR	ROC	TITLE: 60" F+D HEAD/NOZZLE DESIGN FOR HAM	
					By: ART ROUSSOPOLIOS DEPT.: 749	
PROJECT: L160					PROJECT NO: V59049	
PURPOSE: <u>QUALIFY THE DESIGN OF THE 60" HAM COVER TO ASME VIII REQUIREMENTS</u>						
METHOD: <u>COMPRESS 5.53 COMPUTER PRESSURE VESSEL SOFTWARE</u>						
ASSUMPTIONS: <u>SEE CALCS</u>						
INPUTS: <u>"STRUCTURAL DESIGN CRITERIA" REF DOC. NO. V049-PL-73</u>						
REFERENCES: <u>DOC. NO. V049-PL-73</u> <u>DOC. NO. V049-1-066, L160 VACUUM EQUIP. STRUCT. DESIGN CRITERIA</u>						
CALCULATIONS: (SEE ATTACHED)						
CONCLUSIONS: <u>COVER/NOZZLE DESIGN IS IN CONFORMANCE WITH ASME VIII REQUIREMENTS</u>						
NOTES: <u>INSIDE DIAM ANALYZED = 60.25". ACTUAL ID = 60.5"</u> <u>RESULTS ARE NOT REFLECTED</u>						

TABLE OF CONTENTS

	<u>PAGE</u>
1. - SCOPE	3
2. - DESIGN CRITERIA	3
3. - MODEL	3
4. - COMPRESS 5.53 - INPUT DATA	4
5. - COMPRESS 5.53 - OUTPUT	5

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



1.- SCOPE:


QUALIFY THE 60" HAM COVER TO ASME VIII REQUIREMENTS FOR THE NOZZLE LAYOUT AS PSI PROPOSED AND CUSTOMER MODIFIED PER DOC. NO. V049-PL-73

2.- DESIGN CRITERIA:

$$P_{EXT} = 14.7 \text{ PSI}$$

$$T = 400^{\circ}\text{F}$$

3.- MODEL:



- NOZZLE LOCATION DATA:

- N1 $r_1 = 8"$
 $\theta_1 = 0^{\circ}$
- N2 $r_2 = 15.75"$
 $\theta_2 = 90^{\circ}$
- N3 $r_3 = 15.75"$
 $\theta_3 = 270^{\circ}$



4. - COMPRESS 5.53 INPUT DATA:

• MATERIAL:

- F+D HEAD: SA 240 304L HIGH
- NOZZLES (ALL): SA 240 304L HIGH

• EXTERNAL PRESSURE = 14.7 PSI

• DESIGN TEMP = 400°F

FOR F+D HEAD:

- LONG SEAM X-RAY
- SEAMLESS ∴ NO X-RAY
- HEAD/SHELL SEAM X-RAY
- SPOT PER UW-11(b) TYPE I
- ID = 60.25"
- CROWN INTERNAL RADIUS = 60.25"
- KNUCKLE INTERNAL RADIUS = 3.75"
- FORMING ALLOWANCE = 0"
- STRAIGHT FLANGE = 1"
- THICKNESS = .250"

FOR NOZZLES:

- ID = 7.5" (ALL)
- THICKNESS = .25" (ALL)
- ANGLE θ DISTANCE r
- N1: $\theta_1 = 0^\circ$ r₁ = 8"
- N2: $\theta_2 = 90^\circ$ r₂ = 15.75"
- N3: $\theta_3 = 270^\circ$ r₃ = 15.75"

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



5. - COMPRESS 5.53 - OUTPUT

OUTPUT FOR 60" F+D HEAD INCLUDING NOZZLES
1 + 2 ARE ATTACHED TO VERIFY COMPLIANCE
TO ASME VIII, 1992 EDITION INCLUDING A93
ADDENDA

NOTE: ANALYSIS/RESULTS FOR NOZZLE # 3
IS SYMMETRICALLY IDENTICAL TO
NOZZLE # 2.

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



TABLE OF CONTENTS

Pressure Summary	1
Weight Summary	2
Nozzle Summary	3
Thickness Summary	4
60" F&D HAM HEAD	5
N1-CENTER	6
N2-RIGHT	15
Total Pages In This Report	23

Pressure Summary

Pressure summary for pressure chamber 1

Identifier	Nozzle	T	MAWP	MAP	Pe	UG-99	UCS-66		Corrosion
	Status (UG-45)	design (deg F)	(psi)	(psi)	external (psi)	Ratio	MDMT (deg F)	Exemption or Stress Reduction	Allowance (in)
60" F&D HAM HEAD		0.0	67.2	67.2	20.6	1.000		Not applicable	0.000
n1 N1-CENTER	ok	0.0	79.0	79.0	15.5	1.000		Not applicable	0.000
n2 N2-RIGHT	ok	0.0	79.0	79.0	15.3	1.000		Not applicable	0.000
n3 N3-LEFT	ok	0.0	79.0	79.0	15.3	1.000		Not applicable	0.000

Vessel MAWP hot & corroded is 67.2 psi @ 0 degrees F.

Vessel MAP new & cold is 67.2 psi @ 70 degrees F.

Vessel allowable external pressure is 15.31 psi @ 400 degrees F.

Hydrotest pressure calculation based on MAWP

$$= 1.5 * (\text{MAWP} + \text{Operating Liquid Head}) * 1 = 100.8 \text{ psi}$$

Vessel hydrotest pressure is 100.8 psi.

Note: vessel MAP rating not valid unless hydrotest pressure based on MAP.

Weight Summary

Component	Weight (lbs) Contributed by Vessel Elements											
	Metal	Metal	Trays	Packed	Insul	Lining	Piping	Ladder	Rings	Oper	Test	Nozzle
	New	Corr	& sup	Beds				& plat	& Misc	Liquid	Liquid	& flg
60" f&d ham hea	273	273	0	0	0	0	0	0	0	0	741	24
	273	273	0	0	0	0	0	0	0	0	741	24

Vessel operating weight, corroded: 297 lbs
 Vessel empty weight, corroded: 297 lbs
 Vessel empty weight, new: 297 lbs
 Vessel test weight, new: 1,038 lbs

Vessel center of gravity location (from right weld seam)

Vessel lift weight, new: 297 lbs
 Center of gravity to seam: 7.6 in

Nozzle Summary

Nozzle mark	OD (in)	tn (in)	Req tn (in)	A1?	A2?	Nom t (in)	Req t (in)	User t (in)	Corr (in)	Aa/Ar (%)
n1	8.00	0.2500	0.1427	y	y	0.2500	0.1973	0.2500	0.0000	100.5
n2	8.00	0.2500	0.1427	y	y	0.2500	0.1937	0.2500	0.0000	104.3
n3	8.00	0.2500	0.1427	y	y	0.2500	0.1937	0.2500	0.0000	104.3

tn - nozzle thickness

Req tn - nozzle thickness required per UG-45/16

Nom t - vessel wall thickness

Req t - required vessel wall thickness due to pressure + corr per UG-37

User t - local vessel wall thickness (near opening)

Aa - area available per UG-37, governing condition

Ar - area required per UG-37, governing condition

Corr - corrosion allowance on nozzle id.

Thickness Summary

Component Identifier	ID (in)	Length (in)	Nom t (in)	Req t (in)	Joint E	Governing Load Status	Stress	Deflect (in)
60" f&d ham head	60.25		0.2500	0.2500	0.85			

Nom t - vessel wall thickness
Req t - required vessel wall thickness due to governing loading
E - longitudinal seam joint efficiency

Load:

internal - circ stress due to internal pressure governs
external - external pressure governs
wind - combined long stress due to STATUS + wind governs
seismic - combined long stress due to STATUS + seismic governs

60" F&D HAM HEAD

ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: F&D head
Material specification: SA 240 304L HIGH

Corrosion allowance: Inner C = 0 Outer= 0 in

PWHT is not performed

Radiography: Category A joints - Seamless NO X-Ray
Head to shell seam - Spot UW-11(b) type 1

Estimated weight: new = 272.9 corr = 272.9 lb
capacity: new = 88.89 corr = 88.89 US ga

ID = 60.25 crown L = 60.25 knuckle r = 3.75 t = .25 in (min)

Straight flange = 1 forming allowance = 0 in

MAP: (New & at 70 deg F) Appendix 1-4(d) Eq 3

$$\begin{aligned} P &= 2*S*E*t / (L*M + 0.2*t) - P_s \\ &= 2*16700*0.85*0.25 / (60.25*1.7521 + 0.2*0.25) - 0 \\ &= 67.20225 \text{ psi} \end{aligned}$$

MAWP: (Corroded & at 0 deg F) Appendix 1-4(d) Eq 3

$$\begin{aligned} P &= 2*S*E*t / (L*M + 0.2*t) - P_s \\ &= 2*16700*0.85*0.25 / (60.25*1.7521 + 0.2*0.25) - 0 \\ &= 67.20225 \text{ psi} \end{aligned}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$\begin{aligned} A &= .125 / (R_o/t) \\ &= .125 / (60.5/0.25) \\ &= 0.000517 \end{aligned}$$

From table HA-3: B = 5004.1

$$\begin{aligned} P_a &= B / (R_o/t) \\ &= 5004.1 / (60.5/0.25) \\ &= 20.6781 \text{ psi} \end{aligned}$$

Check the Maximum External Pressure: UG-33(a)(1) & App. 1-4(d)

$$\begin{aligned} P_e &= 2*S*E*t / ((M*Lo - t*(M-0.2))*1.67) \\ &= 2*14700*1*0.25 / ((1.7521*60.5 - 0.25*(1.7521-0.2))*1.67) \\ &= 41.67247 \text{ psi} \end{aligned}$$

The maximum allowable external pressure is 20.6781 psi.


N1-CENTER

Opening n1 Reinforcement Calculations Per UG-37

Located on: 60" F&D HAM HEAD
User input vessel thickness: .25 in
Liquid static head included: 0 psi
Flange description: Not installed

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 0 degrees
End of nozzle to datum line: 14.53 in
Nozzle calculated as hillside: yes
Projection outside vessel Lpr: 3.527 in



corrosion allow = 0 in
noz thick new tn= .25 in
nozzle id. new d= 7.5 in
fillet weld tw1 = .25 in
groove weld tw2 = .1875 in

To head center R= 8 in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.567$ in
Normal to the vessel wall outside $2.5*(tn-Cn) + te = .625$ in
Normal to the vessel wall inside $2.5*(tn-Cn-C) = .625$ in

Determination of Chord Length

$$\begin{aligned}\text{Theta1} &= \text{ArcCos}((Lo + Rn)/Rm) \\ &= \text{ArcCos}((8 + 3.75)/60.32135) \\ &= 78.76797\end{aligned}$$

$$\begin{aligned}\text{Theta2} &= \text{ArcCos}((Lo - Rn)/Rm) \\ &= \text{ArcCos}((8 - 3.75)/60.32135) \\ &= 85.96029\end{aligned}$$

$$\begin{aligned}d &= 2*Rm*\text{Sin}((\text{Theta2} - \text{Theta1})/2) \\ &= 2*60.32135*\text{Sin}((85.96029 - 78.76797)/2) \\ &= 7.567 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{aligned}trn &= P*Rn/(Sn*E - 0.6*P) \\ &= 79.06141*3.75/(16700*1 - 0.6*79.06141) \\ &= 0.0178 \text{ in}\end{aligned}$$

N1-CENTER

Required thickness tr from UG-37(a) (1)

$$\begin{aligned} tr &= P*L*M/(2*S*E - 0.2*P) \\ &= 79.06141*60.25*1/(2*16700*1 - 0.2*79.06141) \\ &= 0.1427 \text{ in} \end{aligned}$$

Area required

Allowable stresses: Sn = 16700, Sv = 16700, psi

fr1 = lesser of 1 or Sn/Sv so fr1 =1
fr2 = lesser of 1 or Sn/Sv so fr2 =1

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.567*0.1427*1 + 2*0.25*0.1427*1*(1 - 1) \\ &= 1.0798 \text{ in}^2 \end{aligned}$$

Area available

A1 = larger of the following = .812 in²

$$\begin{aligned} &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.567*(1*0.25-1*0.1427) - 2*0.25*(1*0.25-1*0.1427)*(1-1) \\ &= .812 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.25+0.25)*(1*0.25-1*0.1427) - 2*0.25*(1*0.25-1*0.1427)*(1-1) \\ &= .107 \text{ in}^2 \end{aligned}$$

A2 = smaller of the following = 0.29 in²

$$\begin{aligned} &= 5*(tn - trn)*fr2*t \\ &= 5*(0.25 - 0.0178)*1*0.25 \\ &= .29 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*tn \\ &= 5*(0.25 - 0.0178)*1*0.25 \\ &= .29 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= Leg^2*fr2 \\ &= 0.25^2*1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.812 + 0.29 + 0.063 \\ &= 1.165 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 79.06141 at 0 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$A = d*tr*F + 2*tn*tr*F*(1 - fr1)$$

N1-CENTER

$$= 7.5*0.1427*1 + 2*0.25*0.1427*1*(1 - 1)$$
$$= 1.07025 \text{ in}^2$$

Area available

$$A1 = \text{larger of the following} = .805 \text{ in}^2$$

$$= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)$$
$$= 7.5*(1*0.25-1*0.1427) - 2*0.25*(1*0.25-1*0.1427)*(1-1)$$
$$= .805 \text{ in}^2$$

$$= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)$$
$$= 2*(0.25+0.25)*(1*0.25-1*0.1427) - 2*0.25*(1*0.25-1*0.1427)*(1-1)$$
$$= .107 \text{ in}^2$$

$$\text{Area} = A1 + A2 + A41$$
$$= 0.805 + 0.29 + 0.063$$
$$= 1.158 \text{ in}^2$$

As Area > A the reinforcement is adequate for MAWP = 79.06141 at 0 Deg F

Check the welds - From UW-16(d):

$$t_{min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{min} = 0.25 \text{ in}$$
$$t_1 \text{ or } t_2(\text{min}) = \text{lesser of } 0.25 \text{ or } 0.7*t_{min}, t_1(\text{min}) = 0.175 \text{ in}$$
$$t_1(\text{actual}) = 0.7*\text{Leg} = 0.7*0.25 = 0.175 \text{ in}$$
$$t_2(\text{actual}) = 0.1875 \text{ in}$$
$$t_1 + t_2 = 0.3625 \geq 1.25*t_{min}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0178 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.1427 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.1427 in
The lesser of tr4 or tr5:	tr6 = 0.1427 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.1427 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

$$\text{Groove weld in tension} = 0.74*16700 = 12358 \text{ psi}$$
$$\text{Nozzle wall in shear} = 0.7*16700 = 11690 \text{ psi}$$
$$\text{Inner fillet weld in shear} = 0.49*16700 = 8183 \text{ psi}$$

Strength of welded joints:

N1-CENTER

(1) Inner fillet weld in shear

$$(\text{Pi}/2) * \text{Nozzle O.D.} * \text{Leg} * \text{Si} = 1.57 * 8 * 0.25 * 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\text{Pi}/2) * \text{Mean nozzle dia.} * \text{tn} * \text{Sn} = 1.57 * 7.75 * 0.25 * 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\text{Pi}/2) * \text{Nozzle O.D.} * \text{tw} * \text{Sg} = 1.57 * 8 * 0.1875 * 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 * \text{tn}) * (E1 * t - F * \text{tr})) * \text{Sv} \\ &= (1.0798 - (7.567 - 2 * 0.25) * (1 * 0.25 - 1 * 0.1427)) * 16700 \\ &= 5369.232 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42) * \text{Sv} \\ &= (0.29 + 0 + 0.063 + 0) * 16700 \\ &= 5895.1 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W2-2 &= (A2 + A3 + A41 + A43 + 2 * \text{tn} * t * \text{fr1}) * \text{Sv} \\ &= (0.29 + 0 + 0.063 + 0 + 2 * 0.25 * 0.25 * 1) * 16700 \\ &= 7982.6 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or W1-1 = 5369.232 lbf

Path 1-1 Thru (1) & (3) = 25694.62 + 35559.52 = 61254.14 lbf

Path 1-1 is stronger than W so it is acceptable per UG-41(b) (2) .

Load for path 2-2 lesser of W or W2-2 = 5369.232 lbf

Path 2-2 Thru (1), (4) = 25694.62 + 29103.09 = 54797.71 lbf

Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2) .

Reinforcement Calculations For Nozzle MAP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.567$ in

Normal to the vessel wall outside $2.5 * (\text{tn} - \text{Cn}) + \text{te} = .625$ in

Normal to the vessel wall inside $2.5 * (\text{tn} - \text{Cn} - \text{C}) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta1} &= \text{ArcCos}((\text{Lo} + \text{Rn}) / \text{Rm}) \\ &= \text{ArcCos}((8 + 3.75) / 60.32135) \\ &= 78.76797 \end{aligned}$$

$$\begin{aligned} \text{Theta2} &= \text{ArcCos}((\text{Lo} - \text{Rn}) / \text{Rm}) \\ &= \text{ArcCos}((8 - 3.75) / 60.32135) \\ &= 85.96029 \end{aligned}$$

$$\begin{aligned} d &= 2 * \text{Rm} * \text{Sin}((\text{Theta2} - \text{Theta1}) / 2) \\ &= 2 * 60.32135 * \text{Sin}((85.96029 - 78.76797) / 2) \\ &= 7.567 \text{ in} \end{aligned}$$

N1-CENTER

Nozzle required thickness

$$\begin{aligned} \text{trn} &= P \cdot R_n / (S_n \cdot E - 0.6 \cdot P) \\ &= 79.06141 \cdot 3.75 / (16700 \cdot 1 - 0.6 \cdot 79.06141) \\ &= 0.0178 \text{ in} \end{aligned}$$

Required thickness tr from UG-37(a)(1)

$$\begin{aligned} \text{tr} &= P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P) \\ &= 79.06141 \cdot 60.25 \cdot 1 / (2 \cdot 16700 \cdot 1 - 0.2 \cdot 79.06141) \\ &= 0.1427 \text{ in} \end{aligned}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi

$$\begin{aligned} \text{fr1} &= \text{lesser of } 1 \text{ or } S_n / S_v \text{ so } \text{fr1} = 1 \\ \text{fr2} &= \text{lesser of } 1 \text{ or } S_n / S_v \text{ so } \text{fr2} = 1 \end{aligned}$$

$$\begin{aligned} A &= d \cdot \text{tr} \cdot F + 2 \cdot t_n \cdot \text{tr} \cdot F \cdot (1 - \text{fr1}) \\ &= 7.567 \cdot 0.1427 \cdot 1 + 2 \cdot 0.25 \cdot 0.1427 \cdot 1 \cdot (1 - 1) \\ &= 1.0798 \text{ in}^2 \end{aligned}$$

Area available

$$A_1 = \text{larger of the following} = .812 \text{ in}^2$$

$$\begin{aligned} &= d \cdot (E_1 \cdot t - F \cdot \text{tr}) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot \text{tr}) \cdot (1 - \text{fr1}) \\ &= 7.567 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) - 2 \cdot 0.25 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) \cdot (1 - 1) \\ &= .812 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + t_n) \cdot (E_1 \cdot t - F \cdot \text{tr}) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot \text{tr}) \cdot (1 - \text{fr1}) \\ &= 2 \cdot (0.25 + 0.25) \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) - 2 \cdot 0.25 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) \cdot (1 - 1) \\ &= .107 \text{ in}^2 \end{aligned}$$

$$A_2 = \text{smaller of the following} = 0.29 \text{ in}^2$$

$$\begin{aligned} &= 5 \cdot (t_n - \text{trn}) \cdot \text{fr2} \cdot t \\ &= 5 \cdot (0.25 - 0.0178) \cdot 1 \cdot 0.25 \\ &= .29 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5 \cdot (t_n - \text{trn}) \cdot \text{fr2} \cdot t_n \\ &= 5 \cdot (0.25 - 0.0178) \cdot 1 \cdot 0.25 \\ &= .29 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{41} &= \text{Leg}^2 \cdot \text{fr2} \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A_1 + A_2 + A_{41} \\ &= 0.812 + 0.29 + 0.063 \\ &= 1.165 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 79.06141 at 70 Deg F

N1-CENTER

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.5*0.1427*1 + 2*0.25*0.1427*1*(1 - 1) \\ &= 1.07025 \text{ in}^2 \end{aligned}$$

Area available

$$\begin{aligned} A1 &= \text{larger of the following} &&= .805 \text{ in}^2 \\ &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.5*(1*0.25-1*0.1427) - 2*0.25*(1*0.25-1*0.1427)*(1-1) \\ &= .805 \text{ in}^2 \\ &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.25+0.25)*(1*0.25-1*0.1427) - 2*0.25*(1*0.25-1*0.1427)*(1-1) \\ &= .107 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.805 + 0.29 + 0.063 \\ &= 1.158 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 79.06141 at 70 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{min} &= \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{min} = 0.25 \text{ in} \\ t_1 \text{ or } t_2(\text{min}) &= \text{lesser of } 0.25 \text{ or } 0.7*t_{min}, t_1(\text{min}) = 0.175 \text{ in} \\ t_1(\text{actual}) &= 0.7*Leg = 0.7*0.25 = 0.175 \text{ in} \\ t_2(\text{actual}) &= 0.1875 \text{ in} \\ t_1 + t_2 &= 0.3625 \geq 1.25*t_{min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0178 in (E = 1)
Wall thickness per UG-45(b) (1):	tr2 = 0.1427 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b) (4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.1427 in
The lesser of tr4 or tr5:	tr6 = 0.1427 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.1427 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAP.

Allowable stresses in joints UG-45(c) and UW-15(c)

N1-CENTER

Groove weld in tension = $0.74 \times 16700 = 12358$ psi
Nozzle wall in shear = $0.7 \times 16700 = 11690$ psi
Inner fillet weld in shear = $0.49 \times 16700 = 8183$ psi

Strength of welded joints:

(1) Inner fillet weld in shear

$$(\pi/2) \times \text{Nozzle O.D.} \times \text{Leg} \times \text{Si} = 1.57 \times 8 \times 0.25 \times 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\pi/2) \times \text{Mean nozzle dia.} \times \text{tn} \times \text{Sn} = 1.57 \times 7.75 \times 0.25 \times 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\pi/2) \times \text{Nozzle O.D.} \times \text{tw} \times \text{Sg} = 1.57 \times 8 \times 0.1875 \times 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 \times \text{tn}) \times (E1 \times t - F \times \text{tr})) \times \text{Sv} \\ &= (1.0798 - (7.567 - 2 \times 0.25) \times (1 \times 0.25 - 1 \times 0.1427)) \times 16700 \\ &= 5369.232 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42) \times \text{Sv} \\ &= (0.29 + 0 + 0.063 + 0) \times 16700 \\ &= 5895.1 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W2-2 &= (A2 + A3 + A41 + A43 + 2 \times \text{tn} \times t \times \text{fr1}) \times \text{Sv} \\ &= (0.29 + 0 + 0.063 + 0 + 2 \times 0.25 \times 0.25 \times 1) \times 16700 \\ &= 7982.6 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or W1-1 = 5369.232 lbf
Path 1-1 Thru (1) & (3) = $25694.62 + 35559.52 = 61254.14$ lbf
Path 1-1 is stronger than W so it is acceptable per UG-41(b) (2).

Load for path 2-2 lesser of W or W2-2 = 5369.232 lbf
Path 2-2 Thru (1), (4) = $25694.62 + 29103.09 = 54797.71$ lbf
Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations for External Pressure

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.567$ in
Normal to the vessel wall outside $2.5 \times (\text{tn} - \text{Cn}) + \text{te} = .625$ in
Normal to the vessel wall inside $2.5 \times (\text{tn} - \text{Cn} - \text{C}) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta1} &= \text{ArcCos}((L_o + R_n) / R_m) \\ &= \text{ArcCos}((8 + 3.75) / 60.34865) \\ &= 78.77312 \end{aligned}$$

$$\begin{aligned} \text{Theta2} &= \text{ArcCos}((L_o - R_n) / R_m) \\ &= \text{ArcCos}((8 - 3.75) / 60.34865) \end{aligned}$$

N1-CENTER

= 85.96212

d = 2*Rm*Sin((Theta2 - Theta1)/2)
= 2*60.34865*Sin((85.96212 - 78.77312)/2)
= 7.567 in

Nozzle required thickness

L/Do = 3.527/8 = .4409
From table G:
From table HA-3:

Do/t = 8/0.01981 = 403.8364
A = 0.000383
B = 4746.9

Pa = 4*B/(3*Do/t)
= 4*4746.9/(3*8/0.01981)
= 15.6727 psi

Nozzle required thickness trn = .01981 in

Required thickness tr from UG-37(d) (1) = .1973 in

Area required

Allowable stresses: Sn = 14700, Sv = 14700, psi

fr1 = lesser of 1 or Sn/Sv so fr1 =1
fr2 = lesser of 1 or Sn/Sv so fr2 =1

A = 0.5*(d*tr*F + 2*tn*tr*F*(1 - fr1))
= 0.5*(7.567*0.1973*1 + 2*0.25*0.1973*1*(1 - 1))
= .7465 in²

Area available

A1 = larger of the following = .399 in²

= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)
= 7.567*(1*0.25-1*0.1973) - 2*0.25*(1*0.25-1*0.1973)*(1-1)
= .399 in²

= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)
= 2*(0.25+0.25)*(1*0.25-1*0.1973) - 2*0.25*(1*0.25-1*0.1973)*(1-1)
= .053 in²

A2 = smaller of the following = 0.288 in²

= 5*(tn - trn)*fr2*t
= 5*(0.25 - 0.01981)*1*0.25
= .288 in²

= 5*(tn - trn)*fr2*tn
= 5*(0.25 - 0.01981)*1*0.25
= .288 in²

N1-CENTER

$$\begin{aligned} A41 &= \text{Leg}^2 * fr2 \\ &= 0.25^2 * 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.399 + 0.288 + 0.063 \\ &= .75 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.58935 at 400 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= 0.5 * (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \\ &= 0.5 * (7.5 * 0.1973 * 1 + 2 * 0.25 * 0.1973 * 1 * (1 - 1)) \\ &= .739875 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = .395 \text{ in}^2$$

$$\begin{aligned} &= d * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1) \\ &= 7.5 * (1 * 0.25 - 1 * 0.1973) - 2 * 0.25 * (1 * 0.25 - 1 * 0.1973) * (1 - 1) \\ &= .395 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 * (t + tn) * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1) \\ &= 2 * (0.25 + 0.25) * (1 * 0.25 - 1 * 0.1973) - 2 * 0.25 * (1 * 0.25 - 1 * 0.1973) * (1 - 1) \\ &= .053 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.395 + 0.288 + 0.063 \\ &= .746 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.58935 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.01981 in (E = 1)
Wall thickness per UG-45(b)(2):	tr2 = 0.032 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for Pe.


N2-RIGHT

Opening n2 Reinforcement Calculations Per UG-37

Located on: 60" F&D HAM HEAD
User input vessel thickness: .25 in
Liquid static head included: 0 psi
Flange description: Not installed

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 90 degrees
End of nozzle to datum line: 14.53 in
Nozzle calculated as hillside: yes
Projection outside vessel Lpr: 5.082 in



corrosion allow = 0 in
noz thick new $tn = .25$ in
nozzle id. new $d = 7.5$ in
fillet weld $tw1 = .25$ in
groove weld $tw2 = .1875$ in

To head center $R = 15.75$ in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.771$ in
Normal to the vessel wall outside $2.5*(tn - Cn) + te = .625$ in
Normal to the vessel wall inside $2.5*(tn - Cn - C) = .625$ in

Determination of Chord Length

$$\begin{aligned}\text{Theta1} &= \text{ArcCos}((Lo + Rn)/Rm) \\ &= \text{ArcCos}((15.75 + 3.75)/60.32135) \\ &= 71.13968\end{aligned}$$

$$\begin{aligned}\text{Theta2} &= \text{ArcCos}((Lo - Rn)/Rm) \\ &= \text{ArcCos}((15.75 - 3.75)/60.32135) \\ &= 78.52576\end{aligned}$$

$$\begin{aligned}d &= 2*Rm*\text{Sin}((\text{Theta2} - \text{Theta1})/2) \\ &= 2*60.32135*\text{Sin}((78.52576 - 71.13968)/2) \\ &= 7.771 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{aligned}trn &= P*Rn/(Sn*E - 0.6*P) \\ &= 79.06141*3.75/(16700*1 - 0.6*79.06141) \\ &= 0.0178 \text{ in}\end{aligned}$$

N2-RIGHT

Required thickness tr from UG-37(a) (1)

$$\begin{aligned} tr &= P*L*M/(2*S*E - 0.2*P) \\ &= 79.06141*60.25*1/(2*16700*1 - 0.2*79.06141) \\ &= 0.1427 \text{ in} \end{aligned}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi

$$\begin{aligned} fr1 &= \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr1 = 1 \\ fr2 &= \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1 \end{aligned}$$

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.771*0.1427*1 + 2*0.25*0.1427*1*(1 - 1) \\ &= 1.1089 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = .834 \text{ in}^2$$

$$\begin{aligned} &= d*(E1*t - F*tr) - 2*tn*(E1*t - F*tr)*(1 - fr1) \\ &= 7.771*(1*0.25 - 1*0.1427) - 2*0.25*(1*0.25 - 1*0.1427)*(1 - 1) \\ &= .834 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t + tn)*(E1*t - F*tr) - 2*tn*(E1*t - F*tr)*(1 - fr1) \\ &= 2*(0.25 + 0.25)*(1*0.25 - 1*0.1427) - 2*0.25*(1*0.25 - 1*0.1427)*(1 - 1) \\ &= .107 \text{ in}^2 \end{aligned}$$

$$A2 = \text{smaller of the following} = 0.29 \text{ in}^2$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*t \\ &= 5*(0.25 - 0.0178)*1*0.25 \\ &= .29 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*tn \\ &= 5*(0.25 - 0.0178)*1*0.25 \\ &= .29 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= \text{Leg}^2*fr2 \\ &= 0.25^2*1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.834 + 0.29 + 0.063 \\ &= 1.187 \text{ in}^2 \end{aligned}$$

As $\text{Area} > A$ the reinforcement is adequate for MAWP = 79.06141 at 0 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$A = d*tr*F + 2*tn*tr*F*(1 - fr1)$$

N2-RIGHT

$$= 7.5 * 0.1427 * 1 + 2 * 0.25 * 0.1427 * 1 * (1 - 1)$$
$$= 1.07025 \text{ in}^2$$

Area available

$$A1 = \text{larger of the following} = .805 \text{ in}^2$$

$$= d * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1)$$
$$= 7.5 * (1 * 0.25 - 1 * 0.1427) - 2 * 0.25 * (1 * 0.25 - 1 * 0.1427) * (1 - 1)$$
$$= .805 \text{ in}^2$$

$$= 2 * (t + tn) * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1)$$
$$= 2 * (0.25 + 0.25) * (1 * 0.25 - 1 * 0.1427) - 2 * 0.25 * (1 * 0.25 - 1 * 0.1427) * (1 - 1)$$
$$= .107 \text{ in}^2$$

$$\text{Area} = A1 + A2 + A41$$
$$= 0.805 + 0.29 + 0.063$$
$$= 1.158 \text{ in}^2$$

As Area > A the reinforcement is adequate for MAWP = 79.06141 at 0 Deg F

Check the welds - From UW-16(d):

$$t_{\min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{\min} = 0.25 \text{ in}$$
$$t1 \text{ or } t2(\min) = \text{lesser of } 0.25 \text{ or } 0.7 * t_{\min}, t1(\min) = 0.175 \text{ in}$$
$$t1(\text{actual}) = 0.7 * \text{Leg} = 0.7 * 0.25 = 0.175 \text{ in}$$
$$t2(\text{actual}) = 0.1875 \text{ in}$$
$$t1 + t2 = 0.3625 \geq 1.25 * t_{\min}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0178 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.1427 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.1427 in
The lesser of tr4 or tr5:	tr6 = 0.1427 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.1427 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

$$\text{Groove weld in tension} = 0.74 * 16700 = 12358 \text{ psi}$$
$$\text{Nozzle wall in shear} = 0.7 * 16700 = 11690 \text{ psi}$$
$$\text{Inner fillet weld in shear} = 0.49 * 16700 = 8183 \text{ psi}$$

Strength of welded joints:

3.12.1996

REVO
V049-1-073
Page 23 of 29

N2-RIGHT

(1) Inner fillet weld in shear

$$(\text{Pi}/2) * \text{Nozzle O.D.} * \text{Leg} * \text{Si} = 1.57 * 8 * 0.25 * 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\text{Pi}/2) * \text{Mean nozzle dia.} * \text{tn} * \text{Sn} = 1.57 * 7.75 * 0.25 * 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\text{Pi}/2) * \text{Nozzle O.D.} * \text{tw} * \text{Sg} = 1.57 * 8 * 0.1875 * 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 * \text{tn}) * (E1 * t - F * \text{tr})) * \text{Sv} \\ &= (1.1089 - (7.771 - 2 * 0.25) * (1 * 0.25 - 1 * 0.1427)) * 16700 \\ &= 5489.652 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42) * \text{Sv} \\ &= (0.29 + 0 + 0.063 + 0) * 16700 \\ &= 5895.1 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W2-2 &= (A2 + A3 + A41 + A43 + 2 * \text{tn} * t * \text{fr1}) * \text{Sv} \\ &= (0.29 + 0 + 0.063 + 0 + 2 * 0.25 * 0.25 * 1) * 16700 \\ &= 7982.6 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or W1-1 = 5489.652 lbf

Path 1-1 Thru (1) & (3) = 25694.62 + 35559.52 = 61254.14 lbf

Path 1-1 is stronger than W so it is acceptable per UG-41(b) (2).

Load for path 2-2 lesser of W or W2-2 = 5489.652 lbf

Path 2-2 Thru (1), (4) = 25694.62 + 29103.09 = 54797.71 lbf

Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations For Nozzle MAP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.771 \text{ in}$

Normal to the vessel wall outside $2.5 * (\text{tn} - \text{Cn}) + \text{te} = .625 \text{ in}$

Normal to the vessel wall inside $2.5 * (\text{tn} - \text{Cn} - \text{C}) = .625 \text{ in}$

Determination of Chord Length

$$\begin{aligned} \text{Theta1} &= \text{ArcCos}((\text{Lo} + \text{Rn}) / \text{Rm}) \\ &= \text{ArcCos}((15.75 + 3.75) / 60.32135) \\ &= 71.13968 \end{aligned}$$

$$\begin{aligned} \text{Theta2} &= \text{ArcCos}((\text{Lo} - \text{Rn}) / \text{Rm}) \\ &= \text{ArcCos}((15.75 - 3.75) / 60.32135) \\ &= 78.52576 \end{aligned}$$

$$\begin{aligned} d &= 2 * \text{Rm} * \text{Sin}((\text{Theta2} - \text{Theta1}) / 2) \\ &= 2 * 60.32135 * \text{Sin}((78.52576 - 71.13968) / 2) \\ &= 7.771 \text{ in} \end{aligned}$$

N2-RIGHT

Nozzle required thickness

$$\begin{aligned} trn &= P \cdot Rn / (Sn \cdot E - 0.6 \cdot P) \\ &= 79.06141 \cdot 3.75 / (16700 \cdot 1 - 0.6 \cdot 79.06141) \\ &= 0.0178 \text{ in} \end{aligned}$$

Required thickness tr from UG-37(a) (1)

$$\begin{aligned} tr &= P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P) \\ &= 79.06141 \cdot 60.25 \cdot 1 / (2 \cdot 16700 \cdot 1 - 0.2 \cdot 79.06141) \\ &= 0.1427 \text{ in} \end{aligned}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi

$fr_1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_1 = 1$
 $fr_2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_2 = 1$

$$\begin{aligned} A &= d \cdot tr \cdot F + 2 \cdot t_n \cdot tr \cdot F \cdot (1 - fr_1) \\ &= 7.771 \cdot 0.1427 \cdot 1 + 2 \cdot 0.25 \cdot 0.1427 \cdot 1 \cdot (1 - 1) \\ &= 1.1089 \text{ in}^2 \end{aligned}$$

Area available

$A_1 = \text{larger of the following} = .834 \text{ in}^2$

$$\begin{aligned} &= d \cdot (E_1 \cdot t - F \cdot tr) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot tr) \cdot (1 - fr_1) \\ &= 7.771 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) - 2 \cdot 0.25 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) \cdot (1 - 1) \\ &= .834 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + t_n) \cdot (E_1 \cdot t - F \cdot tr) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot tr) \cdot (1 - fr_1) \\ &= 2 \cdot (0.25 + 0.25) \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) - 2 \cdot 0.25 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) \cdot (1 - 1) \\ &= .107 \text{ in}^2 \end{aligned}$$

$A_2 = \text{smaller of the following} = 0.29 \text{ in}^2$

$$\begin{aligned} &= 5 \cdot (t_n - trn) \cdot fr_2 \cdot t \\ &= 5 \cdot (0.25 - 0.0178) \cdot 1 \cdot 0.25 \\ &= .29 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5 \cdot (t_n - trn) \cdot fr_2 \cdot t_n \\ &= 5 \cdot (0.25 - 0.0178) \cdot 1 \cdot 0.25 \\ &= .29 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{41} &= Leg^2 \cdot fr_2 \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A_1 + A_2 + A_{41} \\ &= 0.834 + 0.29 + 0.063 \\ &= 1.187 \text{ in}^2 \end{aligned}$$

As $\text{Area} > A$ the reinforcement is adequate for $MAP = 79.06141$ at $70 \text{ Deg } F$

N2-RIGHT

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= d \cdot t_r \cdot F + 2 \cdot t_n \cdot t_r \cdot F \cdot (1 - f_r) \\ &= 7.5 \cdot 0.1427 \cdot 1 + 2 \cdot 0.25 \cdot 0.1427 \cdot 1 \cdot (1 - 1) \\ &= 1.07025 \text{ in}^2 \end{aligned}$$

Area available

$$A_1 = \text{larger of the following} = .805 \text{ in}^2$$

$$\begin{aligned} &= d \cdot (E_1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot t_r) \cdot (1 - f_r) \\ &= 7.5 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) - 2 \cdot 0.25 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) \cdot (1 - 1) \\ &= .805 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + t_n) \cdot (E_1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot t_r) \cdot (1 - f_r) \\ &= 2 \cdot (0.25 + 0.25) \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) - 2 \cdot 0.25 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) \cdot (1 - 1) \\ &= .107 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A_1 + A_2 + A_4 \\ &= 0.805 + 0.29 + 0.063 \\ &= 1.158 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 79.06141 at 70 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{\min} &= \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{\min} = 0.25 \text{ in} \\ t_1 \text{ or } t_2 (\min) &= \text{lesser of } 0.25 \text{ or } 0.7 \cdot t_{\min}, t_1 (\min) = 0.175 \text{ in} \\ t_1 (\text{actual}) &= 0.7 \cdot \text{Leg} = 0.7 \cdot 0.25 = 0.175 \text{ in} \\ t_2 (\text{actual}) &= 0.1875 \text{ in} \\ t_1 + t_2 &= 0.3625 \geq 1.25 \cdot t_{\min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0178 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.1427 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.1427 in
The lesser of tr4 or tr5:	tr6 = 0.1427 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.1427 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAP.

Allowable stresses in joints UG-45(c) and UW-15(c)

N2-RIGHT

Groove weld in tension = $0.74 \times 16700 = 12358$ psi
Nozzle wall in shear = $0.7 \times 16700 = 11690$ psi
Inner fillet weld in shear = $0.49 \times 16700 = 8183$ psi

Strength of welded joints:

(1) Inner fillet weld in shear

$$(Pi/2) * \text{Nozzle O.D.} * \text{Leg} * Si = 1.57 * 8 * 0.25 * 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(Pi/2) * \text{Mean nozzle dia.} * tn * Sn = 1.57 * 7.75 * 0.25 * 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(Pi/2) * \text{Nozzle O.D.} * tw * Sg = 1.57 * 8 * 0.1875 * 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2*tn) * (E1*t - F*tr)) * Sv \\ &= (1.1089 - (7.771 - 2*0.25) * (1*0.25 - 1*0.1427)) * 16700 \\ &= 5489.652 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42) * Sv \\ &= (0.29 + 0 + 0.063 + 0) * 16700 \\ &= 5895.1 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W2-2 &= (A2 + A3 + A41 + A43 + 2*tn*t*fr1) * Sv \\ &= (0.29 + 0 + 0.063 + 0 + 2*0.25*0.25*1) * 16700 \\ &= 7982.6 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or W1-1 = 5489.652 lbf
Path 1-1 Thru (1) & (3) = $25694.62 + 35559.52 = 61254.14$ lbf
Path 1-1 is stronger than W so it is acceptable per UG-41(b) (2).

Load for path 2-2 lesser of W or W2-2 = 5489.652 lbf
Path 2-2 Thru (1), (4) = $25694.62 + 29103.09 = 54797.71$ lbf
Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations for External Pressure

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.77$ in
Normal to the vessel wall outside $2.5 * (tn - Cn) + te = .625$ in
Normal to the vessel wall inside $2.5 * (tn - Cn - C) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta1} &= \text{ArcCos}((Lo + Rn) / Rm) \\ &= \text{ArcCos}((15.75 + 3.75) / 60.34685) \\ &= 71.14795 \end{aligned}$$

$$\begin{aligned} \text{Theta2} &= \text{ArcCos}((Lo - Rn) / Rm) \\ &= \text{ArcCos}((15.75 - 3.75) / 60.34685) \end{aligned}$$

N2-RIGHT

= 78.53069

d = 2*Rm*Sin((Theta2 - Theta1)/2)
= 2*60.34685*Sin((78.53069 - 71.14795)/2)
= 7.77 in

Nozzle required thickness

L/Do = 5.082/8 = .6352 Do/t = 8/0.02205 = 362.8118
From table G: A = 0.000317
From table HA-3: B = 4194.4

Pa = 4*B/(3*Do/t)
= 4*4194.4/(3*8/0.02205)
= 15.4144 psi

Nozzle required thickness trn = .02205 in

Required thickness tr from UG-37(d) (1) = .1937 in

Area required

Allowable stresses: Sn = 14700, Sv = 14700, psi

fr1 = lesser of 1 or Sn/Sv so fr1 =1
fr2 = lesser of 1 or Sn/Sv so fr2 =1

A = 0.5*(d*tr*F + 2*tn*tr*F*(1 - fr1))
= 0.5*(7.77*0.1937*1 + 2*0.25*0.1937*1*(1 - 1))
= .7525 in^2

Area available

A1 = larger of the following = .437 in^2

= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)
= 7.77*(1*0.25-1*0.1937) - 2*0.25*(1*0.25-1*0.1937)*(1-1)
= .437 in^2

= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)
= 2*(0.25+0.25)*(1*0.25-1*0.1937) - 2*0.25*(1*0.25-1*0.1937)*(1-1)
= .056 in^2

A2 = smaller of the following = 0.285 in^2

= 5*(tn - trn)*fr2*t
= 5*(0.25 - 0.02205)*1*0.25
= .285 in^2

= 5*(tn - trn)*fr2*tn
= 5*(0.25 - 0.02205)*1*0.25
= .285 in^2

N2-RIGHT

$$\begin{aligned} A41 &= \text{Leg}^2 * \text{fr}2 \\ &= 0.25^2 * 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.437 + 0.285 + 0.063 \\ &= .785 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.31362 at 400 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= 0.5 * (d * \text{tr} * F + 2 * \text{tn} * \text{tr} * F * (1 - \text{fr}1)) \\ &= 0.5 * (7.5 * 0.1937 * 1 + 2 * 0.25 * 0.1937 * 1 * (1 - 1)) \\ &= .726375 \text{ in}^2 \end{aligned}$$

Area available

$$\begin{aligned} A1 &= \text{larger of the following} &&= .422 \text{ in}^2 \\ &= d * (E1 * t - F * \text{tr}) - 2 * \text{tn} * (E1 * t - F * \text{tr}) * (1 - \text{fr}1) \\ &= 7.5 * (1 * 0.25 - 1 * 0.1937) - 2 * 0.25 * (1 * 0.25 - 1 * 0.1937) * (1 - 1) \\ &= .422 \text{ in}^2 \\ &= 2 * (t + \text{tn}) * (E1 * t - F * \text{tr}) - 2 * \text{tn} * (E1 * t - F * \text{tr}) * (1 - \text{fr}1) \\ &= 2 * (0.25 + 0.25) * (1 * 0.25 - 1 * 0.1937) - 2 * 0.25 * (1 * 0.25 - 1 * 0.1937) * (1 - 1) \\ &= .056 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.422 + 0.285 + 0.063 \\ &= .77 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.31362 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.02205 in (E = 1)
Wall thickness per UG-45(b) (2):	tr2 = 0.0314 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b) (4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for Pe.

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-074
REV.	DEO #	DATE	BY:	CHECK	PAGE 1 OF 38	
0	002A	3-30-96	AGR	ROC	TITLE: 84" F+D HEAD/NOZZLE DESIGN FOR HAM	
					By: AAT ROUSSOPOULOS DEPT.: 749	
<u>PROJECT:</u> LIGO					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> QUALIFY THE DESIGN OF THE 84" HAM COVER TO ASME VIII REQUIREMENTS						
<u>METHOD:</u> COMPRESS 5.53 COMPUTER PRESSURE VESSEL SOFTWARE						
<u>ASSUMPTIONS:</u> SEE CALCS						
<u>INPUTS:</u> "STRUCTURAL DESIGN CRITERIA" REF DOC. NO. V049-1-066						
<u>REFERENCES:</u> DOC. NO. V049-PL-73 DWG. NO. V049-A-040 Doc. No. V049-1-066, LIGO VACUUM EQUIP., STRUCTURAL DESIGN CRITERIA						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> COVER/NOZZLE DESIGN IS IN CONFORMANCE WITH ASME VIII REQUIREMENTS						
<u>NOTES:</u>						

TABLE OF CONTENTS

	<u>PAGE</u>
1. - SCOPE:	3
2. - DESIGN CRITERIA:	3
3. - MODEL	3
4. - COMPRESS S.53 - INPUT DATA	4
5. - COMPRESS S.53 - OUTPUT	J-38

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS




1. - SCOPE:

QUALIFY THE 84" HAM COVER TO ASME VIII REQUIREMENTS FOR THE NOZZLE LAYOUT AS PSl PROPOSED AND CUSTOMER ACCEPTANCE PER DOC. NO. V049-PL-73

2. DESIGN CRITERIA:

$P_{EXT.} = 14.7 \text{ PSI}$
 $T = 400^\circ \text{ F}$

3. MODEL:



- NOZZLE LOCATION DATA:

- N1 $r_1 = 7.875"$; $\theta_1 = 0^\circ$
- N2 $r_2 = \sqrt{21.25^2 + 7.875^2} = 22.66"$; $\theta_2 = \tan^{-1} \frac{21.25}{7.875} = 69.7^\circ$
- N3 $r_3 = r_2 = 22.66"$; $\theta_3 = (90 - 69.7) + 270 = 290.3^\circ$
- N4 $r_4 = \sqrt{10.8125^2 + 20.3125^2} = 23.01"$; $\theta_4 = \tan^{-1} \frac{10.8125}{20.3125} = 28.03^\circ$
- N5 $r_5 = r_4 = 23.01"$; $\theta_5 = (90 - 28.03) + 270 = 331.97^\circ$

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



A - COMPRESS 5.53 - INPUT DATA:

• MATERIAL:

- F+D HEAD: SA 240 304L HIGH
- NOZZLES (ALL) SA 240 304L HIGH

• EXTERNAL PRESSURE = 14.7 PSI

• DESIGN TEMP. = 400°F

FOR F+D HEAD:

- LONG. SEAM X-RAY
- SEAMLESS ∴ NO XRAY
- HEAD/SHELL SEAM X-RAY
- SPOT PER UW-11(b) TYPE I
- ID = 84.25"
- CROWN INTERNAL RADIUS = 85"
- KNUCKLE INTERNAL RADIUS = 5.25"
- FORMING ALLOWANCE = 0"
- STRAIGHT FLANGE = 2"
- THICKNESS = .375"

FOR NOZZLES:

- ID = 7.75" (ALL)
- THICKNESS = .1875" (ALL)
- ANGLE θ DISTANCE r
- N1: $\theta_1 = 0^\circ$ $r_1 = 7.875"$
- N2: $\theta_2 = 69.7^\circ$ $r_2 = 22.66"$
- N3: $\theta_3 = 290.7^\circ$ $r_3 = 22.66"$
- N4: $\theta_4 = 28.03^\circ$ $r_4 = 23.01"$
- N5: $\theta_5 = 331.97^\circ$ $r_5 = 23.01"$



5. COMPRESS 5.53 - OUTPUT

OUTPUT FOR 84" F+D HEAD, NOZZLES 1, 2 AND 4 ARE ATTACHED TO VERIFY COMPLIANCE TO ASME VIII EDITION, INCLUDING A9 ADDENDA.

NOTE: THAT ANALYSIS/RESULTS FOR NOZZLE #3 IS SYMMETRICALLY IDENTICAL TO NOZZLE #2 AND NOZZLE #5 IS IDENTICAL TO #4

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



TABLE OF CONTENTS

Pressure Summary	1
Weight Summary	2
Nozzle Summary	3
Thickness Summary	4
84" F&D HAM HEAD	5
N1-1ST ROW-CENTER	6
N2-1ST ROW-RIGHT	15
N4-2ND ROW-RIGHT	24
Total Pages In This Report	32

Pressure Summary

Pressure summary for pressure chamber 1

Identifier	Nozzle	T	MAWP	MAP	Pe	UG-99	UCS-66		Corrosion
	Status	design			external	Ratio	NDMT	Exemption or	Allowance
	(UG-45)	(deg F)	(psi)	(psi)	(psi)		(deg F)	Stress Reduction	(in)
84" F&D HAM HEAD		0.0	72.1	72.1	22.4	1.000		Not applicable	0.000
N1 N1-1ST ROW-CENTR	ok	0.0	83.5	83.5	15.7	1.000		Not applicable	0.000
N2 N2-1ST ROW-RIGHT	ok	0.0	83.2	83.0	15.8	1.000		Not applicable	0.000
N3 N3-1ST ROW-LEFT	ok	0.0	83.2	83.0	15.8	1.000		Not applicable	0.000
N4 N4-2ND ROW-RIGHT	ok	0.0	83.2	83.0	15.8	1.000		Not applicable	0.000
N5 N5-2ND ROW-LEFT	ok	0.0	83.2	83.0	15.8	1.000		Not applicable	0.000

Vessel MAWP hot & corroded is 72.11 psi @ 0 degrees F.

Vessel MAP new & cold is 72.11 psi @ 70 degrees F.

Vessel allowable external pressure is 15.76 psi @ 400 degrees F.

Hydrotest pressure calculation based on MAWP

$$= 1.5 * (\text{MAWP} + \text{Operating Liquid Head}) * 1 = 108.2 \text{ psi}$$

Vessel hydrotest pressure is 108.2 psi.

Note: vessel MAP rating not valid unless hydrotest pressure based on MAP.

Weight Summary

Component	Weight (lbs) Contributed by Vessel Elements											
	Metal	Metal	Trays	Packed	Insul	Lining	Piping	Ladder	Rings	Oper	Test	Nozzle
	New	Corr	& sup	Beds				& plat	& Misc	Liquid	Liquid	& flg
84" f&d ham hea	822	822	0	0	0	0	0	0	0	0	2149	28
	822	822	0	0	0	0	0	0	0	0	2149	28

Vessel operating weight, corroded: 850 lbs
 Vessel empty weight, corroded: 850 lbs
 Vessel empty weight, new: 850 lbs
 Vessel test weight, new: 2,999 lbs

Vessel center of gravity location (from right weld seam)

Vessel lift weight, new: 848 lbs
 Center of gravity to seam: 10.6 in

Nozzle Summary

Nozzle mark	OD	tn	Req tn		Nom t	Req t	User t	Corr	Aa/Ar	
	(in)	(in)	(in)	A1?	A2?	(in)	(in)	(in)	(%)	
N1	8.00	0.2500	0.2108	y	y	0.3750	0.2777	0.3750	0.0000	100.1
N2	8.00	0.2500	0.2101	y	y	0.3750	0.2789	0.3750	0.0000	100.0
N3	8.00	0.2500	0.2101	y	y	0.3750	0.2788	0.3750	0.0000	100.0
N4	8.00	0.2500	0.2101	y	y	0.3750	0.2787	0.3750	0.0000	100.0
N5	8.00	0.2500	0.2101	y	y	0.3750	0.2790	0.3750	0.0000	100.0

tn - nozzle thickness

Req tn - nozzle thickness required per UG-45/16

Nom t - vessel wall thickness

Req t - required vessel wall thickness due to pressure + corr per UG-37

User t - local vessel wall thickness (near opening)

Aa - area available per UG-37, governing condition

Ar - area required per UG-37, governing condition

Corr - corrosion allowance on nozzle id.

Thickness Summary

Component Identifier	ID (in)	Length (in)	Nom t (in)	Req t (in)	Joint E	Load	Governing Status	Stress	Deflect (in)
84" f&d ham head	84.25		0.3750	0.3750	0.85				

Nom t - vessel wall thickness
Req t - required vessel wall thickness due to governing loading
E - longitudinal seam joint efficiency

Load:

internal - circ stress due to internal pressure governs
external - external pressure governs
wind - combined long stress due to STATUS + wind governs
seismic - combined long stress due to STATUS + seismic governs

84" F&D HAM HEAD

ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: F&D head
Material specification: SA 240 304L HIGH

Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Seamless NO X-Ray
Head to shell seam - Spot UW-11(b) type 1

Estimated weight: new = 821.5 corr = 821.5 lb
capacity: new = 257.65 corr = 257.65 US ga

ID = 84.25 crown L = 84.25 knuckle r = 5.25 t = .375 in (min)

Straight flange = 2 forming allowance = 0 in

MAP: (New & at 70 deg F) Appendix 1-4(d) Eq 3

$$\begin{aligned} P &= 2*S*E*t / (L*M + 0.2*t) - P_s \\ &= 2*16700*0.85*0.375 / (84.25*1.7515 + 0.2*0.375) - 0 \\ &= 72.11008 \text{ psi} \end{aligned}$$

MAWP: (Corroded & at 0 deg F) Appendix 1-4(d) Eq 3

$$\begin{aligned} P &= 2*S*E*t / (L*M + 0.2*t) - P_s \\ &= 2*16700*0.85*0.375 / (84.25*1.7515 + 0.2*0.375) - 0 \\ &= 72.11008 \text{ psi} \end{aligned}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$\begin{aligned} A &= .125 / (R_o/t) \\ &= .125 / (84.625/0.375) \\ &= 0.000554 \end{aligned}$$

From table HA-3: B = 5065.4

$$\begin{aligned} P_a &= B / (R_o/t) \\ &= 5065.4 / (84.625/0.375) \\ &= 22.4464 \text{ psi} \end{aligned}$$

Check the Maximum External Pressure: UG-33(a)(1) & App. 1-4(d)

$$\begin{aligned} P_e &= 2*S*E*t / ((M*Lo - t*(M-0.2))*1.67) \\ &= 2*14700*1*0.375 / ((1.7515*84.625 - 0.375*(1.7515-0.2))*1.67) \\ &= 44.71584 \text{ psi} \end{aligned}$$

The maximum allowable external pressure is 22.4464 psi.


N1-1ST ROW-CENTER

Opening N1 Reinforcement Calculations Per UG-37

Located on: 84" F&D HAM HEAD
User input vessel thickness: .375 in
Liquid static head included: 0 psi
Flange description: Not installed

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 0 degrees
End of nozzle to datum line: 19.782 in
Nozzle calculated as hillside: yes
Projection outside vessel Lpr: 3.39 in



corrosion allow = 0 in
noz thick new $tn = .25$ in
nozzle id. new $d = 7.5$ in
fillet weld $tw1 = .25$ in
groove weld $tw2 = .1875$ in

To head center $R = 7.875$ in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.533$ in
Normal to the vessel wall outside $2.5*(tn - Cn) + te = .625$ in
Normal to the vessel wall inside $2.5*(tn - Cn - C) = .625$ in

Determination of Chord Length

$$\begin{aligned}\text{Theta1} &= \text{ArcCos}((Lo + Rn)/Rm) \\ &= \text{ArcCos}((7.875 + 3.75)/84.3554) \\ &= 82.07932\end{aligned}$$

$$\begin{aligned}\text{Theta2} &= \text{ArcCos}((Lo - Rn)/Rm) \\ &= \text{ArcCos}((7.875 - 3.75)/84.3554) \\ &= 87.19758\end{aligned}$$

$$\begin{aligned}d &= 2*Rm*\text{Sin}((\text{Theta2} - \text{Theta1})/2) \\ &= 2*84.3554*\text{Sin}((87.19758 - 82.07932)/2) \\ &= 7.533 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{aligned}trn &= P*Rn/(Sn*E - 0.6*P) \\ &= 83.53057*3.75/(16700*1 - 0.6*83.53057) \\ &= 0.0188 \text{ in}\end{aligned}$$

3.12.1996

N1-1ST ROW-CENTER

Required thickness tr from UG-37(a)(1)

$$\begin{aligned} tr &= P*L*M / (2*S*E - 0.2*P) \\ &= 83.53057*84.25*1 / (2*16700*1 - 0.2*83.53057) \\ &= 0.2108 \text{ in} \end{aligned}$$

Area required

Allowable stresses: Sn = 16700, Sv = 16700, psi

$$\begin{aligned} fr1 &= \text{lesser of 1 or } Sn/Sv \text{ so } fr1 = 1 \\ fr2 &= \text{lesser of 1 or } Sn/Sv \text{ so } fr2 = 1 \end{aligned}$$

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.533*0.2108*1 + 2*0.25*0.2108*1*(1 - 1) \\ &= 1.588 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = 1.237 \text{ in}^2$$

$$\begin{aligned} &= d*(E1*t - F*tr) - 2*tn*(E1*t - F*tr)*(1 - fr1) \\ &= 7.533*(1*0.375 - 1*0.2108) - 2*0.25*(1*0.375 - 1*0.2108)*(1 - 1) \\ &= 1.237 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t + tn)*(E1*t - F*tr) - 2*tn*(E1*t - F*tr)*(1 - fr1) \\ &= 2*(0.375 + 0.25)*(1*0.375 - 1*0.2108) - 2*0.25*(1*0.375 - 1*0.2108)*(1 - 1) \\ &= .205 \text{ in}^2 \end{aligned}$$

$$A2 = \text{smaller of the following} = 0.289 \text{ in}^2$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*t \\ &= 5*(0.25 - 0.0188)*1*0.375 \\ &= .433 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*tn \\ &= 5*(0.25 - 0.0188)*1*0.25 \\ &= .289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= Leg^2*fr2 \\ &= 0.25^2*1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.237 + 0.289 + 0.063 \\ &= 1.589 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 83.53057 at 0 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$A = d*tr*F + 2*tn*tr*F*(1 - fr1)$$

N1-1ST ROW-CENTER

= 7.5*0.2108*1 + 2*0.25*0.2108*1*(1 - 1)
= 1.581 in^2

Area available

A1 = larger of the following = 1.231 in^2

= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)
= 7.5*(1*0.375-1*0.2108) - 2*0.25*(1*0.375-1*0.2108)*(1-1)
= 1.231 in^2

= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)
= 2*(0.375+0.25)*(1*0.375-1*0.2108) - 2*0.25*(1*0.375-1*0.2108)*(1-1)
= .205 in^2

Area = A1 + A2 + A41
= 1.231 + 0.289 + 0.063
= 1.583 in^2

As Area > A the reinforcement is adequate for MAWP = 83.53057 at 0 Deg F

Check the welds - From UW-16(d):

tmin = lesser of 0.75 or tn or t, tmin = 0.25 in
t1 or t2(min) = lesser of 0.25 or 0.7*tmin, t1(min) = 0.175 in
t1(actual) = 0.7*Leg = 0.7*0.25 = 0.175 in
t2(actual) = 0.1875 in
t1 + t2 = 0.3625 >= 1.25*tmin

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a): tr1 = 0.0188 in (E = 1)
Wall thickness per UG-45(b)(1): tr2 = 0.2108 in
Wall thickness per UG-16(b): tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4): tr4 = 0.28175 in
The greater of tr2 or tr3: tr5 = 0.2108 in
The lesser of tr4 or tr5: tr6 = 0.2108 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.2108 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

Groove weld in tension = 0.74*16700 = 12358 psi
Nozzle wall in shear = 0.7*16700 = 11690 psi
Inner fillet weld in shear = 0.49*16700 = 8183 psi

Strength of welded joints:

N1-1ST ROW-CENTER

(1) Inner fillet weld in shear

$$(Pi/2)*Nozzle\ O.D.*Leg*Si = 1.57*8*0.25*8183 = 25694.62\ lbf$$

(3) Nozzle wall in shear

$$(Pi/2)*Mean\ nozzle\ dia.*tn*Sn = 1.57*7.75*0.25*11690 = 35559.52\ lbf$$

(4) Groove weld in tension

$$(Pi/2)*Nozzle\ O.D.*tw*Sg = 1.57*8*0.1875*12358 = 29103.09\ lbf$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2*tn)*(E1*t - F*tr))*Sv \\ &= (1.588 - (7.533 - 2*0.25)*(1*0.375 - 1*0.2108))*16700 \\ &= 7234.131\ lbf \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42)*Sv \\ &= (0.289 + 0 + 0.063 + 0)*16700 \\ &= 5878.4\ lbf \end{aligned}$$

$$\begin{aligned} W2-2 &= (A2 + A3 + A41 + A43 + 2*tn*t*fr1)*Sv \\ &= (0.289 + 0 + 0.063 + 0 + 2*0.25*0.375*1)*16700 \\ &= 9009.65\ lbf \end{aligned}$$

Load for path 1-1 lesser of W or W1-1 = 5878.4 lbf

Path 1-1 Thru (1) & (3) = 25694.62 + 35559.52 = 61254.14 lbf

Path 1-1 is stronger than W1-1 so it is acceptable per UG-41(b) (1).

Load for path 2-2 lesser of W or W2-2 = 7234.131 lbf

Path 2-2 Thru (1), (4) = 25694.62 + 29103.09 = 54797.71 lbf

Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations For Nozzle MAP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.533$ in

Normal to the vessel wall outside $2.5*(tn-Cn) + te = .625$ in

Normal to the vessel wall inside $2.5*(tn-Cn-C) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta1} &= \text{ArcCos}((Lo + Rn)/Rm) \\ &= \text{ArcCos}((7.875 + 3.75)/84.3554) \\ &= 82.07932 \end{aligned}$$

$$\begin{aligned} \text{Theta2} &= \text{ArcCos}((Lo - Rn)/Rm) \\ &= \text{ArcCos}((7.875 - 3.75)/84.3554) \\ &= 87.19758 \end{aligned}$$

$$\begin{aligned} d &= 2*Rm*\text{Sin}((\text{Theta2} - \text{Theta1})/2) \\ &= 2*84.3554*\text{Sin}((87.19758 - 82.07932)/2) \\ &= 7.533\ \text{in} \end{aligned}$$

N1-1ST ROW-CENTER

Nozzle required thickness

$$\begin{aligned} \text{trn} &= P \cdot R_n / (S_n \cdot E - 0.6 \cdot P) \\ &= 83.54077 \cdot 3.75 / (16700 \cdot 1 - 0.6 \cdot 83.54077) \\ &= 0.0188 \text{ in} \end{aligned}$$

Required thickness tr from UG-37(a)(1)

$$\begin{aligned} \text{tr} &= P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P) \\ &= 83.54077 \cdot 84.25 \cdot 1 / (2 \cdot 16700 \cdot 1 - 0.2 \cdot 83.54077) \\ &= 0.2108 \text{ in} \end{aligned}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi

$\text{fr}_1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } \text{fr}_1 = 1$
 $\text{fr}_2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } \text{fr}_2 = 1$

$$\begin{aligned} A &= d \cdot \text{tr} \cdot F + 2 \cdot t_n \cdot \text{tr} \cdot F \cdot (1 - \text{fr}_1) \\ &= 7.533 \cdot 0.2108 \cdot 1 + 2 \cdot 0.25 \cdot 0.2108 \cdot 1 \cdot (1 - 1) \\ &= 1.588 \text{ in}^2 \end{aligned}$$

Area available

$A_1 = \text{larger of the following} = 1.237 \text{ in}^2$

$$\begin{aligned} &= d \cdot (E_1 \cdot t - F \cdot \text{tr}) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot \text{tr}) \cdot (1 - \text{fr}_1) \\ &= 7.533 \cdot (1 \cdot 0.375 - 1 \cdot 0.2108) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2108) \cdot (1 - 1) \\ &= 1.237 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + t_n) \cdot (E_1 \cdot t - F \cdot \text{tr}) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot \text{tr}) \cdot (1 - \text{fr}_1) \\ &= 2 \cdot (0.375 + 0.25) \cdot (1 \cdot 0.375 - 1 \cdot 0.2108) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2108) \cdot (1 - 1) \\ &= .205 \text{ in}^2 \end{aligned}$$

$A_2 = \text{smaller of the following} = 0.289 \text{ in}^2$

$$\begin{aligned} &= 5 \cdot (t_n - \text{trn}) \cdot \text{fr}_2 \cdot t \\ &= 5 \cdot (0.25 - 0.0188) \cdot 1 \cdot 0.375 \\ &= .433 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5 \cdot (t_n - \text{trn}) \cdot \text{fr}_2 \cdot t_n \\ &= 5 \cdot (0.25 - 0.0188) \cdot 1 \cdot 0.25 \\ &= .289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{41} &= \text{Leg}^2 \cdot \text{fr}_2 \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A_1 + A_2 + A_{41} \\ &= 1.237 + 0.289 + 0.063 \\ &= 1.589 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 83.54077 at 70 Deg F

N1-1ST ROW-CENTER

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.5*0.2108*1 + 2*0.25*0.2108*1*(1 - 1) \\ &= 1.581 \text{ in}^2 \end{aligned}$$

Area available

$$\begin{aligned} A1 &= \text{larger of the following} && = 1.231 \text{ in}^2 \\ &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.5*(1*0.375-1*0.2108) - 2*0.25*(1*0.375-1*0.2108)*(1-1) \\ &= 1.231 \text{ in}^2 \\ &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.375+0.25)*(1*0.375-1*0.2108) - 2*0.25*(1*0.375-1*0.2108)*(1-1) \\ &= .205 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.231 + 0.289 + 0.063 \\ &= 1.583 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 83.54077 at 70 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{min} &= \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{min} = 0.25 \text{ in} \\ t_1 \text{ or } t_2(\text{min}) &= \text{lesser of } 0.25 \text{ or } 0.7*t_{min}, t_1(\text{min}) = 0.175 \text{ in} \\ t_1(\text{actual}) &= 0.7*\text{Leg} = 0.7*0.25 = 0.175 \text{ in} \\ t_2(\text{actual}) &= 0.1875 \text{ in} \\ t_1 + t_2 &= 0.3625 \geq 1.25*t_{min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0188 in (E = 1)
Wall thickness per UG-45(b) (1):	tr2 = 0.2108 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b) (4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.2108 in
The lesser of tr4 or tr5:	tr6 = 0.2108 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.2108 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAP.

Allowable stresses in joints UG-45(c) and UW-15(c)

N1-1ST ROW-CENTER

Groove weld in tension = $0.74 \times 16700 = 12358$ psi
Nozzle wall in shear = $0.7 \times 16700 = 11690$ psi
Inner fillet weld in shear = $0.49 \times 16700 = 8183$ psi .

Strength of welded joints:

(1) Inner fillet weld in shear

$$(\text{Pi}/2) \times \text{Nozzle O.D.} \times \text{Leg} \times \text{Si} = 1.57 \times 8 \times 0.25 \times 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\text{Pi}/2) \times \text{Mean nozzle dia.} \times \text{tn} \times \text{Sn} = 1.57 \times 7.75 \times 0.25 \times 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\text{Pi}/2) \times \text{Nozzle O.D.} \times \text{tw} \times \text{Sg} = 1.57 \times 8 \times 0.1875 \times 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 \times \text{tn}) \times (E1 \times t - F \times \text{tr})) \times \text{Sv} \\ &= (1.588 - (7.533 - 2 \times 0.25) \times (1 \times 0.375 - 1 \times 0.2108)) \times 16700 \\ &= 7234.131 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42) \times \text{Sv} \\ &= (0.289 + 0 + 0.063 + 0) \times 16700 \\ &= 5878.4 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W2-2 &= (A2 + A3 + A41 + A43 + 2 \times \text{tn} \times t \times \text{fr1}) \times \text{Sv} \\ &= (0.289 + 0 + 0.063 + 0 + 2 \times 0.25 \times 0.375 \times 1) \times 16700 \\ &= 9009.65 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or W1-1 = 5878.4 lbf
Path 1-1 Thru (1) & (3) = $25694.62 + 35559.52 = 61254.14$ lbf
Path 1-1 is stronger than W1-1 so it is acceptable per UG-41(b) (1) .

Load for path 2-2 lesser of W or W2-2 = 7234.131 lbf
Path 2-2 Thru (1), (4) = $25694.62 + 29103.09 = 54797.71$ lbf
Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2) .

Reinforcement Calculations for External Pressure

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.533$ in
Normal to the vessel wall outside $2.5 \times (\text{tn} - \text{Cn}) + \text{te} = .625$ in
Normal to the vessel wall inside $2.5 \times (\text{tn} - \text{Cn} - \text{C}) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta1} &= \text{ArcCos}((\text{Lo} + \text{Rn})/\text{Rm}) \\ &= \text{ArcCos}((7.875 + 3.75)/84.38885) \\ &= 82.08248 \end{aligned}$$

$$\begin{aligned} \text{Theta2} &= \text{ArcCos}((\text{Lo} - \text{Rn})/\text{Rm}) \\ &= \text{ArcCos}((7.875 - 3.75)/84.38885) \end{aligned}$$

N1-1ST ROW-CENTER

$$= 87.19869$$

$$\begin{aligned}d &= 2*Rm*\sin((\text{Theta}2 - \text{Theta}1)/2) \\ &= 2*84.38885*\sin((87.19869 - 82.08248)/2) \\ &= 7.533 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{aligned}L/Do &= 3.39/8 = .4238 \\ \text{From table G:} \\ \text{From table HA-3:}\end{aligned}$$

$$\begin{aligned}Do/t &= 8/0.01987 = 402.617 \\ A &= 0.000401 \\ B &= 4785.4\end{aligned}$$

$$\begin{aligned}Pa &= 4*B/(3*Do/t) \\ &= 4*4785.4/(3*8/0.01987) \\ &= 15.8476 \text{ psi}\end{aligned}$$

$$\text{Nozzle required thickness } trn = .01987 \text{ in}$$

Required thickness tr from UG-37(d) (1) = .2777 in

Area required

$$\text{Allowable stresses: } Sn = 14700, \quad Sv = 14700, \quad \text{psi}$$

$$\begin{aligned}fr1 &= \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr1 = 1 \\ fr2 &= \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr2 = 1\end{aligned}$$

$$\begin{aligned}A &= 0.5*(d*tr*F + 2*tn*tr*F*(1 - fr1)) \\ &= 0.5*(7.533*0.2777*1 + 2*0.25*0.2777*1*(1 - 1)) \\ &= 1.046 \text{ in}^2\end{aligned}$$

Area available

$$A1 = \text{larger of the following} \quad = .733 \text{ in}^2$$

$$\begin{aligned}&= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.533*(1*0.375-1*0.2777) - 2*0.25*(1*0.375-1*0.2777)*(1-1) \\ &= .733 \text{ in}^2\end{aligned}$$

$$\begin{aligned}&= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.375+0.25)*(1*0.375-1*0.2777) - 2*0.25*(1*0.375-1*0.2777)*(1-1) \\ &= .122 \text{ in}^2\end{aligned}$$

$$A2 = \text{smaller of the following} \quad = 0.288 \text{ in}^2$$

$$\begin{aligned}&= 5*(tn - trn)*fr2*t \\ &= 5*(0.25 - 0.01987)*1*0.375 \\ &= .431 \text{ in}^2\end{aligned}$$

$$\begin{aligned}&= 5*(tn - trn)*fr2*tn \\ &= 5*(0.25 - 0.01987)*1*0.25 \\ &= .288 \text{ in}^2\end{aligned}$$

N1-1ST ROW-CENTER

$$\begin{aligned} A41 &= \text{Leg}^2 * fr2 \\ &= 0.25^2 * 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.733 + 0.288 + 0.063 \\ &= 1.084 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.76347 at 400 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= 0.5 * (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \\ &= 0.5 * (7.5 * 0.2777 * 1 + 2 * 0.25 * 0.2777 * 1 * (1 - 1)) \\ &= 1.041375 \text{ in}^2 \end{aligned}$$

Area available

$$\begin{aligned} A1 &= \text{larger of the following} && = .73 \text{ in}^2 \\ &= d * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1) \\ &= 7.5 * (1 * 0.375 - 1 * 0.2777) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2777) * (1 - 1) \\ &= .73 \text{ in}^2 \\ &= 2 * (t + tn) * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1) \\ &= 2 * (0.375 + 0.25) * (1 * 0.375 - 1 * 0.2777) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2777) * (1 - 1) \\ &= .122 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.73 + 0.288 + 0.063 \\ &= 1.081 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.76347 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.01987 in (E = 1)
Wall thickness per UG-45(b) (2):	tr2 = 0.0452 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b) (4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for Pe.


N2-1ST ROW-RIGHT

Opening N2 Reinforcement Calculations Per UG-37

Located on: 84" F&D HAM HEAD
User input vessel thickness: .375 in
Liquid static head included: 0 psi
Flange description: Not installed

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 69.7 degrees
End of nozzle to datum line: 16.7521 in
Nozzle calculated as hillside: yes
Projection outside vessel Lpr: 3.083 in



corrosion allow = 0 in
noz thick new $tn = .25$ in
nozzle id. new $d = 7.5$ in
fillet weld $tw1 = .25$ in
groove weld $tw2 = .1875$ in

To head center $R = 22.66$ in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.787$ in
Normal to the vessel wall outside $2.5*(tn - Cn) + te = .625$ in
Normal to the vessel wall inside $2.5*(tn - Cn - C) = .625$ in

Determination of Chord Length

$$\begin{aligned}\text{Theta1} &= \text{ArcCos}((Lo + Rn)/Rm) \\ &= \text{ArcCos}((22.66 + 3.75)/84.35505) \\ &= 71.75536\end{aligned}$$

$$\begin{aligned}\text{Theta2} &= \text{ArcCos}((Lo - Rn)/Rm) \\ &= \text{ArcCos}((22.66 - 3.75)/84.35505) \\ &= 77.04626\end{aligned}$$

$$\begin{aligned}d &= 2*Rm*\text{Sin}((\text{Theta2} - \text{Theta1})/2) \\ &= 2*84.35505*\text{Sin}((77.04626 - 71.75536)/2) \\ &= 7.787 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{aligned}trn &= P*Rn/(Sn*E - 0.6*P) \\ &= 83.26131*3.75/(16700*1 - 0.6*83.26131) \\ &= 0.0188 \text{ in}\end{aligned}$$

N2-1ST ROW-RIGHT

Required thickness tr from UG-37(a) (1)

$$\begin{aligned} tr &= P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P) \\ &= 83.26131 \cdot 84.25 \cdot 1 / (2 \cdot 16700 \cdot 1 - 0.2 \cdot 83.26131) \\ &= 0.2101 \text{ in} \end{aligned}$$

Area required

Allowable stresses: Sn = 16700, Sv = 16700, psi

$$\begin{aligned} fr1 &= \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr1 = 1 \\ fr2 &= \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr2 = 1 \end{aligned}$$

$$\begin{aligned} A &= d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1) \\ &= 7.787 \cdot 0.2101 \cdot 1 + 2 \cdot 0.25 \cdot 0.2101 \cdot 1 \cdot (1 - 1) \\ &= 1.636 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = 1.284 \text{ in}^2$$

$$\begin{aligned} &= d \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 7.787 \cdot (1 \cdot 0.375 - 1 \cdot 0.2101) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2101) \cdot (1 - 1) \\ &= 1.284 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + tn) \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 2 \cdot (0.375 + 0.25) \cdot (1 \cdot 0.375 - 1 \cdot 0.2101) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2101) \cdot (1 - 1) \\ &= .206 \text{ in}^2 \end{aligned}$$

$$A2 = \text{smaller of the following} = 0.289 \text{ in}^2$$

$$\begin{aligned} &= 5 \cdot (tn - trn) \cdot fr2 \cdot t \\ &= 5 \cdot (0.25 - 0.0188) \cdot 1 \cdot 0.375 \\ &= .433 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5 \cdot (tn - trn) \cdot fr2 \cdot tn \\ &= 5 \cdot (0.25 - 0.0188) \cdot 1 \cdot 0.25 \\ &= .289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= Leg^2 \cdot fr2 \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.284 + 0.289 + 0.063 \\ &= 1.636 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 83.26131 at 0 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$A = d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1)$$

N2-1ST ROW-RIGHT

$$= 7.5*0.2101*1 + 2*0.25*0.2101*1*(1 - 1) \\ = 1.57575 \text{ in}^2$$

Area available

$$A1 = \text{larger of the following} = 1.237 \text{ in}^2$$

$$= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ = 7.5*(1*0.375-1*0.2101) - 2*0.25*(1*0.375-1*0.2101)*(1-1) \\ = 1.237 \text{ in}^2$$

$$= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ = 2*(0.375+0.25)*(1*0.375-1*0.2101) - 2*0.25*(1*0.375-1*0.2101)*(1-1) \\ = .206 \text{ in}^2$$

$$\text{Area} = A1 + A2 + A41 \\ = 1.237 + 0.289 + 0.063 \\ = 1.589 \text{ in}^2$$

As Area > A the reinforcement is adequate for MAWP = 83.26131 at 0 Deg F

Check the welds - From UW-16(d):

$$t_{min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{min} = 0.25 \text{ in} \\ t1 \text{ or } t2(\text{min}) = \text{lesser of } 0.25 \text{ or } 0.7*t_{min}, t1(\text{min}) = 0.175 \text{ in} \\ t1(\text{actual}) = 0.7*\text{Leg} = 0.7*0.25 = 0.175 \text{ in} \\ t2(\text{actual}) = 0.1875 \text{ in} \\ t1 + t2 = 0.3625 \geq 1.25*t_{min}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0188 in (E = 1)
Wall thickness per UG-45(b) (1):	tr2 = 0.2101 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b) (4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.2101 in
The lesser of tr4 or tr5:	tr6 = 0.2101 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.2101 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

$$\text{Groove weld in tension} = 0.74*16700 = 12358 \text{ psi} \\ \text{Nozzle wall in shear} = 0.7*16700 = 11690 \text{ psi} \\ \text{Inner fillet weld in shear} = 0.49*16700 = 8183 \text{ psi}$$

Strength of welded joints:

3.12.1996

N2-1ST ROW-RIGHT

(1) Inner fillet weld in shear

$$(\pi/2) * \text{Nozzle O.D.} * \text{Leg} * S_i = 1.57 * 8 * 0.25 * 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\pi/2) * \text{Mean nozzle dia.} * t_n * S_n = 1.57 * 7.75 * 0.25 * 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\pi/2) * \text{Nozzle O.D.} * t_w * S_g = 1.57 * 8 * 0.1875 * 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 * t_n) * (E_1 * t - F * t_r)) * S_v \\ &= (1.636 - (7.787 - 2 * 0.25) * (1 * 0.375 - 1 * 0.2101)) * 16700 \\ &= 7254.041 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{1-1} &= (A_2 + A_5 + A_{41} + A_{42}) * S_v \\ &= (0.289 + 0 + 0.063 + 0) * 16700 \\ &= 5878.4 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{2-2} &= (A_2 + A_3 + A_{41} + A_{43} + 2 * t_n * t * f_{r1}) * S_v \\ &= (0.289 + 0 + 0.063 + 0 + 2 * 0.25 * 0.375 * 1) * 16700 \\ &= 9009.65 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or W₁₋₁ = 5878.4 lbf

Path 1-1 Thru (1) & (3) = 25694.62 + 35559.52 = 61254.14 lbf

Path 1-1 is stronger than W₁₋₁ so it is acceptable per UG-41(b) (1).

Load for path 2-2 lesser of W or W₂₋₂ = 7254.041 lbf

Path 2-2 Thru (1), (4) = 25694.62 + 29103.09 = 54797.71 lbf

Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations For Nozzle MAP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.787 \text{ in}$

Normal to the vessel wall outside $2.5 * (t_n - C_n) + t_e = .625 \text{ in}$

Normal to the vessel wall inside $2.5 * (t_n - C_n - C) = .625 \text{ in}$

Determination of Chord Length

$$\begin{aligned} \text{Theta}_1 &= \text{ArcCos}((L_o + R_n) / R_m) \\ &= \text{ArcCos}((22.66 + 3.75) / 84.3548) \\ &= 71.7553 \end{aligned}$$

$$\begin{aligned} \text{Theta}_2 &= \text{ArcCos}((L_o - R_n) / R_m) \\ &= \text{ArcCos}((22.66 - 3.75) / 84.3548) \\ &= 77.04622 \end{aligned}$$

$$\begin{aligned} d &= 2 * R_m * \text{Sin}((\text{Theta}_2 - \text{Theta}_1) / 2) \\ &= 2 * 84.3548 * \text{Sin}((77.04622 - 71.7553) / 2) \\ &= 7.787 \text{ in} \end{aligned}$$

N2-1ST ROW-RIGHT

Nozzle required thickness

$$\begin{aligned} \text{trn} &= P \cdot R_n / (S_n \cdot E - 0.6 \cdot P) \\ &= 83.06746 \cdot 3.75 / (16700 \cdot 1 - 0.6 \cdot 83.06746) \\ &= 0.0187 \text{ in} \end{aligned}$$

Required thickness tr from UG-37(a)(1)

$$\begin{aligned} \text{tr} &= P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P) \\ &= 83.06746 \cdot 84.25 \cdot 1 / (2 \cdot 16700 \cdot 1 - 0.2 \cdot 83.06746) \\ &= 0.2096 \text{ in} \end{aligned}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi

$\text{fr}_1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } \text{fr}_1 = 1$
 $\text{fr}_2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } \text{fr}_2 = 1$

$$\begin{aligned} A &= d \cdot \text{tr} \cdot F + 2 \cdot t_n \cdot \text{tr} \cdot F \cdot (1 - \text{fr}_1) \\ &= 7.787 \cdot 0.2096 \cdot 1 + 2 \cdot 0.25 \cdot 0.2096 \cdot 1 \cdot (1 - 1) \\ &= 1.6322 \text{ in}^2 \end{aligned}$$

Area available

$A_1 = \text{larger of the following} = 1.288 \text{ in}^2$

$$\begin{aligned} &= d \cdot (E_1 \cdot t - F \cdot \text{tr}) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot \text{tr}) \cdot (1 - \text{fr}_1) \\ &= 7.787 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= 1.288 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + t_n) \cdot (E_1 \cdot t - F \cdot \text{tr}) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot \text{tr}) \cdot (1 - \text{fr}_1) \\ &= 2 \cdot (0.375 + 0.25) \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= .207 \text{ in}^2 \end{aligned}$$

$A_2 = \text{smaller of the following} = 0.289 \text{ in}^2$

$$\begin{aligned} &= 5 \cdot (t_n - \text{trn}) \cdot \text{fr}_2 \cdot t \\ &= 5 \cdot (0.25 - 0.0187) \cdot 1 \cdot 0.375 \\ &= .434 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5 \cdot (t_n - \text{trn}) \cdot \text{fr}_2 \cdot t_n \\ &= 5 \cdot (0.25 - 0.0187) \cdot 1 \cdot 0.25 \\ &= .289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{41} &= \text{Leg}^2 \cdot \text{fr}_2 \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A_1 + A_2 + A_{41} \\ &= 1.288 + 0.289 + 0.063 \\ &= 1.64 \text{ in}^2 \end{aligned}$$

As $\text{Area} > A$ the reinforcement is adequate for $\text{MAP} = 83.06746$ at 70 Deg F

N2-1ST ROW-RIGHT

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1) \\ &= 7.5 \cdot 0.2096 \cdot 1 + 2 \cdot 0.25 \cdot 0.2096 \cdot 1 \cdot (1 - 1) \\ &= 1.572 \text{ in}^2 \end{aligned}$$

Area available

$$\begin{aligned} A1 &= \text{larger of the following} && = 1.24 \text{ in}^2 \\ &= d \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 7.5 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= 1.24 \text{ in}^2 \\ &= 2 \cdot (t + tn) \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 2 \cdot (0.375 + 0.25) \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= .207 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.24 + 0.289 + 0.063 \\ &= 1.592 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 83.06746 at 70 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{\min} &= \text{lesser of } 0.75 \text{ or } tn \text{ or } t, t_{\min} = 0.25 \text{ in} \\ t1 \text{ or } t2(\min) &= \text{lesser of } 0.25 \text{ or } 0.7 \cdot t_{\min}, t1(\min) = 0.175 \text{ in} \\ t1(\text{actual}) &= 0.7 \cdot \text{Leg} = 0.7 \cdot 0.25 = 0.175 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.3625 \geq 1.25 \cdot t_{\min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0187 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.2096 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.2096 in
The lesser of tr4 or tr5:	tr6 = 0.2096 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.2096 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAP.

Allowable stresses in joints UG-45(c) and UW-15(c)

N2-1ST ROW-RIGHT

Groove weld in tension = $0.74 \times 16700 = 12358$ psi
Nozzle wall in shear = $0.7 \times 16700 = 11690$ psi
Inner fillet weld in shear = $0.49 \times 16700 = 8183$ psi .

Strength of welded joints:

(1) Inner fillet weld in shear

$$(\pi/2) \times \text{Nozzle O.D.} \times \text{Leg} \times S_i = 1.57 \times 8 \times 0.25 \times 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\pi/2) \times \text{Mean nozzle dia.} \times t_n \times S_n = 1.57 \times 7.75 \times 0.25 \times 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\pi/2) \times \text{Nozzle O.D.} \times t_w \times S_g = 1.57 \times 8 \times 0.1875 \times 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 \times t_n) \times (E_1 \times t - F \times t_r)) \times S_v \\ &= (1.6322 - (7.787 - 2 \times 0.25) \times (1 \times 0.375 - 1 \times 0.2096)) \times 16700 \\ &= 7129.734 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{1-1} &= (A_2 + A_5 + A_{41} + A_{42}) \times S_v \\ &= (0.289 + 0 + 0.063 + 0) \times 16700 \\ &= 5878.4 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{2-2} &= (A_2 + A_3 + A_{41} + A_{43} + 2 \times t_n \times t \times f_{r1}) \times S_v \\ &= (0.289 + 0 + 0.063 + 0 + 2 \times 0.25 \times 0.375 \times 1) \times 16700 \\ &= 9009.65 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or $W_{1-1} = 5878.4$ lbf
Path 1-1 Thru (1) & (3) = $25694.62 + 35559.52 = 61254.14$ lbf
Path 1-1 is stronger than W_{1-1} so it is acceptable per UG-41(b) (1) .

Load for path 2-2 lesser of W or $W_{2-2} = 7129.734$ lbf
Path 2-2 Thru (1), (4) = $25694.62 + 29103.09 = 54797.71$ lbf
Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2) .

Reinforcement Calculations for External Pressure

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.787$ in
Normal to the vessel wall outside $2.5 \times (t_n - C_n) + t_e = .625$ in
Normal to the vessel wall inside $2.5 \times (t_n - C_n - C) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta}_1 &= \text{ArcCos}((L_o + R_n) / R_m) \\ &= \text{ArcCos}((22.66 + 3.75) / 84.38945) \\ &= 71.76306 \end{aligned}$$

$$\begin{aligned} \text{Theta}_2 &= \text{ArcCos}((L_o - R_n) / R_m) \\ &= \text{ArcCos}((22.66 - 3.75) / 84.38945) \end{aligned}$$

N2-1ST ROW-RIGHT

$$= 77.05163$$

$$\begin{aligned}d &= 2 * R_m * \sin((\text{Theta}2 - \text{Theta}1)/2) \\ &= 2 * 84.38945 * \sin((77.05163 - 71.76306)/2) \\ &= 7.787 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{aligned}L/Do &= 3.083/8 = .3854 \\ \text{From table G:} \\ \text{From table HA-3:}\end{aligned}$$

$$\begin{aligned}Do/t &= 8/0.01962 = 407.7472 \\ A &= 0.000437 \\ B &= 4858.3\end{aligned}$$

$$\begin{aligned}Pa &= 4 * B / (3 * Do/t) \\ &= 4 * 4858.3 / (3 * 8 / 0.01962) \\ &= 15.8866 \text{ psi}\end{aligned}$$

$$\text{Nozzle required thickness } t_{rn} = .01962 \text{ in}$$

Required thickness tr from UG-37(d) (1) = .2789 in

Area required

$$\text{Allowable stresses: } S_n = 14700, \quad S_v = 14700, \quad \text{psi}$$

$$\begin{aligned}fr1 &= \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr1 = 1 \\ fr2 &= \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1\end{aligned}$$

$$\begin{aligned}A &= 0.5 * (d * t_r * F + 2 * t_n * t_r * F * (1 - fr1)) \\ &= 0.5 * (7.787 * 0.2789 * 1 + 2 * 0.25 * 0.2789 * 1 * (1 - 1)) \\ &= 1.0859 \text{ in}^2\end{aligned}$$

Area available

$$A1 = \text{larger of the following} = .748 \text{ in}^2$$

$$\begin{aligned}&= d * (E1 * t - F * t_r) - 2 * t_n * (E1 * t - F * t_r) * (1 - fr1) \\ &= 7.787 * (1 * 0.375 - 1 * 0.2789) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2789) * (1 - 1) \\ &= .748 \text{ in}^2\end{aligned}$$

$$\begin{aligned}&= 2 * (t + t_n) * (E1 * t - F * t_r) - 2 * t_n * (E1 * t - F * t_r) * (1 - fr1) \\ &= 2 * (0.375 + 0.25) * (1 * 0.375 - 1 * 0.2789) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2789) * (1 - 1) \\ &= .12 \text{ in}^2\end{aligned}$$

$$A2 = \text{smaller of the following} = 0.288 \text{ in}^2$$

$$\begin{aligned}&= 5 * (t_n - t_{rn}) * fr2 * t \\ &= 5 * (0.25 - 0.01962) * 1 * 0.375 \\ &= .432 \text{ in}^2\end{aligned}$$

$$\begin{aligned}&= 5 * (t_n - t_{rn}) * fr2 * t_n \\ &= 5 * (0.25 - 0.01962) * 1 * 0.25 \\ &= .288 \text{ in}^2\end{aligned}$$

N2-1ST ROW-RIGHT

$$A41 = \text{Leg}^2 * \text{fr}2 \\ = 0.25^2 * 1 = .063 \text{ in}^2$$

$$\text{Area} = A1 + A2 + A41 \\ = 0.748 + 0.288 + 0.063 \\ = 1.099 \text{ in}^2$$

As Area > A the reinforcement is adequate for Pe = 15.82647 at 400 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$A = 0.5 * (d * \text{tr} * F + 2 * \text{tn} * \text{tr} * F * (1 - \text{fr}1)) \\ = 0.5 * (7.5 * 0.2789 * 1 + 2 * 0.25 * 0.2789 * 1 * (1 - 1)) \\ = 1.045875 \text{ in}^2$$

Area available

$$A1 = \text{larger of the following} = .721 \text{ in}^2 \\ = d * (E1 * t - F * \text{tr}) - 2 * \text{tn} * (E1 * t - F * \text{tr}) * (1 - \text{fr}1) \\ = 7.5 * (1 * 0.375 - 1 * 0.2789) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2789) * (1 - 1) \\ = .721 \text{ in}^2 \\ = 2 * (t + \text{tn}) * (E1 * t - F * \text{tr}) - 2 * \text{tn} * (E1 * t - F * \text{tr}) * (1 - \text{fr}1) \\ = 2 * (0.375 + 0.25) * (1 * 0.375 - 1 * 0.2789) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2789) * (1 - 1) \\ = .12 \text{ in}^2$$

$$\text{Area} = A1 + A2 + A41 \\ = 0.721 + 0.288 + 0.063 \\ = 1.072 \text{ in}^2$$

As Area > A the reinforcement is adequate for Pe = 15.82647 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.01962 in (E = 1)
Wall thickness per UG-45(b) (2):	tr2 = 0.0454 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b) (4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for Pe.


N4-2ND ROW-RIGHT

Opening N4 Reinforcement Calculations Per UG-37

Located on: 84" F&D HAM HEAD
User input vessel thickness: .375 in
Liquid static head included: 0 psi
Flange description: Not installed

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 28.03 degrees
End of nozzle to datum line: 16.6279 in
Nozzle calculated as hillside: yes
Projection outside vessel Lpr: 3.057 in



corrosion allow = 0 in
noz thick new $tn = .25$ in
nozzle id. new $d = 7.5$ in
fillet weld $tw1 = .25$ in
groove weld $tw2 = .1875$ in

$\leftarrow R \rightarrow$ | To head center $R = 23.01$ in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.796$ in
Normal to the vessel wall outside $2.5*(tn - Cn) + te = .625$ in
Normal to the vessel wall inside $2.5*(tn - Cn - C) = .625$ in

Determination of Chord Length

$$\begin{aligned}\text{Theta1} &= \text{ArcCos}((Lo + Rn)/Rm) \\ &= \text{ArcCos}((23.01 + 3.75)/84.35505) \\ &= 71.50487\end{aligned}$$

$$\begin{aligned}\text{Theta2} &= \text{ArcCos}((Lo - Rn)/Rm) \\ &= \text{ArcCos}((23.01 - 3.75)/84.35505) \\ &= 76.8022\end{aligned}$$

$$\begin{aligned}d &= 2*Rm*\text{Sin}((\text{Theta2} - \text{Theta1})/2) \\ &= 2*84.35505*\text{Sin}((76.8022 - 71.50487)/2) \\ &= 7.796 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{aligned}trn &= P*Rn/(Sn*E - 0.6*P) \\ &= 83.26131*3.75/(16700*1 - 0.6*83.26131) \\ &= 0.0188 \text{ in}\end{aligned}$$

N4-2ND ROW-RIGHT

Required thickness tr from UG-37(a) (1)

$$\begin{aligned} tr &= P*L*M/(2*S*E - 0.2*P) \\ &= 83.26131*84.25*1/(2*16700*1 - 0.2*83.26131) \\ &= 0.2101 \text{ in} \end{aligned}$$

Area required

Allowable stresses: Sn = 16700, Sv = 16700, psi

$$\begin{aligned} fr1 &= \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr1 = 1 \\ fr2 &= \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr2 = 1 \end{aligned}$$

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.796*0.2101*1 + 2*0.25*0.2101*1*(1 - 1) \\ &= 1.6379 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = 1.286 \text{ in}^2$$

$$\begin{aligned} &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.796*(1*0.375-1*0.2101) - 2*0.25*(1*0.375-1*0.2101)*(1-1) \\ &= 1.286 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.375+0.25)*(1*0.375-1*0.2101) - 2*0.25*(1*0.375-1*0.2101)*(1-1) \\ &= .206 \text{ in}^2 \end{aligned}$$

$$A2 = \text{smaller of the following} = 0.289 \text{ in}^2$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*t \\ &= 5*(0.25 - 0.0188)*1*0.375 \\ &= .433 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*tn \\ &= 5*(0.25 - 0.0188)*1*0.25 \\ &= .289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= Leg^2*fr2 \\ &= 0.25^2*1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.286 + 0.289 + 0.063 \\ &= 1.638 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 83.26131 at 0 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$A = d*tr*F + 2*tn*tr*F*(1 - fr1)$$

N4-2ND ROW-RIGHT

$$= 7.5*0.2101*1 + 2*0.25*0.2101*1*(1 - 1)$$
$$= 1.57575 \text{ in}^2$$

Area available

$$A1 = \text{larger of the following} = 1.237 \text{ in}^2$$

$$= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)$$
$$= 7.5*(1*0.375-1*0.2101) - 2*0.25*(1*0.375-1*0.2101)*(1-1)$$
$$= 1.237 \text{ in}^2$$

$$= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)$$
$$= 2*(0.375+0.25)*(1*0.375-1*0.2101) - 2*0.25*(1*0.375-1*0.2101)*(1-1)$$
$$= .206 \text{ in}^2$$

$$\text{Area} = A1 + A2 + A41$$
$$= 1.237 + 0.289 + 0.063$$
$$= 1.589 \text{ in}^2$$

As Area > A the reinforcement is adequate for MAWP = 83.26131 at 0 Deg F

Check the welds - From UW-16(d):

$$t_{min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{min} = 0.25 \text{ in}$$
$$t_1 \text{ or } t_2(\text{min}) = \text{lesser of } 0.25 \text{ or } 0.7*t_{min}, t_1(\text{min}) = 0.175 \text{ in}$$
$$t_1(\text{actual}) = 0.7*\text{Leg} = 0.7*0.25 = 0.175 \text{ in}$$
$$t_2(\text{actual}) = 0.1875 \text{ in}$$
$$t_1 + t_2 = 0.3625 \geq 1.25*t_{min}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0188 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.2101 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.2101 in
The lesser of tr4 or tr5:	tr6 = 0.2101 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.2101 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

$$\text{Groove weld in tension} = 0.74*16700 = 12358 \text{ psi}$$
$$\text{Nozzle wall in shear} = 0.7*16700 = 11690 \text{ psi}$$
$$\text{Inner fillet weld in shear} = 0.49*16700 = 8183 \text{ psi}$$

Strength of welded joints:

N4-2ND ROW-RIGHT

(1) Inner fillet weld in shear

$$(Pi/2)*Nozzle\ O.D.*Leg*Si = 1.57*8*0.25*8183 = 25694.62\ lbf$$

(3) Nozzle wall in shear

$$(Pi/2)*Mean\ nozzle\ dia.*tn*Sn = 1.57*7.75*0.25*11690 = 35559.52\ lbf$$

(4) Groove weld in tension

$$(Pi/2)*Nozzle\ O.D.*tw*Sg = 1.57*8*0.1875*12358 = 29103.09\ lbf$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2*tn)*(E1*t - F*tr))*Sv \\ &= (1.6379 - (7.796 - 2*0.25)*(1*0.375 - 1*0.2101))*16700 \\ &= 7260.986\ lbf \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42)*Sv \\ &= (0.289 + 0 + 0.063 + 0)*16700 \\ &= 5878.4\ lbf \end{aligned}$$

$$\begin{aligned} W2-2 &= (A2 + A3 + A41 + A43 + 2*tn*t*fr1)*Sv \\ &= (0.289 + 0 + 0.063 + 0 + 2*0.25*0.375*1)*16700 \\ &= 9009.65\ lbf \end{aligned}$$

Load for path 1-1 lesser of W or W1-1 = 5878.4 lbf

Path 1-1 Thru (1) & (3) = 25694.62 + 35559.52 = 61254.14 lbf

Path 1-1 is stronger than W1-1 so it is acceptable per UG-41(b) (1).

Load for path 2-2 lesser of W or W2-2 = 7260.986 lbf

Path 2-2 Thru (1), (4) = 25694.62 + 29103.09 = 54797.71 lbf

Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations For Nozzle MAP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.796$ in

Normal to the vessel wall outside $2.5*(tn-Cn) + te = .625$ in

Normal to the vessel wall inside $2.5*(tn-Cn-C) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta1} &= \text{ArcCos}((Lo + Rn)/Rm) \\ &= \text{ArcCos}((23.01 + 3.75)/84.3548) \\ &= 71.50481 \end{aligned}$$

$$\begin{aligned} \text{Theta2} &= \text{ArcCos}((Lo - Rn)/Rm) \\ &= \text{ArcCos}((23.01 - 3.75)/84.3548) \\ &= 76.80215 \end{aligned}$$

$$\begin{aligned} d &= 2*Rm*\text{Sin}((\text{Theta2} - \text{Theta1})/2) \\ &= 2*84.3548*\text{Sin}((76.80215 - 71.50481)/2) \\ &= 7.796\ \text{in} \end{aligned}$$

N4-2ND ROW-RIGHT

Nozzle required thickness

$$\begin{aligned} \text{trn} &= P \cdot R_n / (S_n \cdot E - 0.6 \cdot P) \\ &= 83.06746 \cdot 3.75 / (16700 \cdot 1 - 0.6 \cdot 83.06746) \\ &= 0.0187 \text{ in} \end{aligned}$$

Required thickness tr from UG-37(a)(1)

$$\begin{aligned} \text{tr} &= P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P) \\ &= 83.06746 \cdot 84.25 \cdot 1 / (2 \cdot 16700 \cdot 1 - 0.2 \cdot 83.06746) \\ &= 0.2096 \text{ in} \end{aligned}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi

$\text{fr}_1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } \text{fr}_1 = 1$

$\text{fr}_2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } \text{fr}_2 = 1$

$$\begin{aligned} A &= d \cdot \text{tr} \cdot F + 2 \cdot t_n \cdot \text{tr} \cdot F \cdot (1 - \text{fr}_1) \\ &= 7.796 \cdot 0.2096 \cdot 1 + 2 \cdot 0.25 \cdot 0.2096 \cdot 1 \cdot (1 - 1) \\ &= 1.634 \text{ in}^2 \end{aligned}$$

Area available

$$A_1 = \text{larger of the following} = 1.289 \text{ in}^2$$

$$\begin{aligned} &= d \cdot (E_1 \cdot t - F \cdot \text{tr}) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot \text{tr}) \cdot (1 - \text{fr}_1) \\ &= 7.796 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= 1.289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + t_n) \cdot (E_1 \cdot t - F \cdot \text{tr}) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot \text{tr}) \cdot (1 - \text{fr}_1) \\ &= 2 \cdot (0.375 + 0.25) \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= .207 \text{ in}^2 \end{aligned}$$

$$A_2 = \text{smaller of the following} = 0.289 \text{ in}^2$$

$$\begin{aligned} &= 5 \cdot (t_n - \text{trn}) \cdot \text{fr}_2 \cdot t \\ &= 5 \cdot (0.25 - 0.0187) \cdot 1 \cdot 0.375 \\ &= .434 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5 \cdot (t_n - \text{trn}) \cdot \text{fr}_2 \cdot t_n \\ &= 5 \cdot (0.25 - 0.0187) \cdot 1 \cdot 0.25 \\ &= .289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{41} &= \text{Leg}^2 \cdot \text{fr}_2 \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A_1 + A_2 + A_{41} \\ &= 1.289 + 0.289 + 0.063 \\ &= 1.641 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 83.06746 at 70 Deg F

N4-2ND ROW-RIGHT

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1) \\ &= 7.5 \cdot 0.2096 \cdot 1 + 2 \cdot 0.25 \cdot 0.2096 \cdot 1 \cdot (1 - 1) \\ &= 1.572 \text{ in}^2 \end{aligned}$$

Area available

$$\begin{aligned} A1 &= \text{larger of the following} && = 1.24 \text{ in}^2 \\ &= d \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 7.5 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= 1.24 \text{ in}^2 \\ &= 2 \cdot (t + tn) \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 2 \cdot (0.375 + 0.25) \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= .207 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.24 + 0.289 + 0.063 \\ &= 1.592 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 83.06746 at 70 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{min} &= \text{lesser of } 0.75 \text{ or } tn \text{ or } t, t_{min} = 0.25 \text{ in} \\ t1 \text{ or } t2 (\text{min}) &= \text{lesser of } 0.25 \text{ or } 0.7 \cdot t_{min}, t1 (\text{min}) = 0.175 \text{ in} \\ t1 (\text{actual}) &= 0.7 \cdot \text{Leg} = 0.7 \cdot 0.25 = 0.175 \text{ in} \\ t2 (\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.3625 \geq 1.25 \cdot t_{min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

$$\begin{aligned} \text{Wall thickness per UG-45(a):} &&& tr1 = 0.0187 \text{ in (E = 1)} \\ \text{Wall thickness per UG-45(b) (1):} &&& tr2 = 0.2096 \text{ in} \\ \text{Wall thickness per UG-16(b):} &&& tr3 = 0.0625 \text{ in} \\ \text{Std pipe wall per UG-45(b) (4):} &&& tr4 = 0.28175 \text{ in} \\ \text{The greater of } tr2 \text{ or } tr3: &&& tr5 = 0.2096 \text{ in} \\ \text{The lesser of } tr4 \text{ or } tr5: &&& tr6 = 0.2096 \text{ in} \end{aligned}$$

Req'd per UG-45 is the larger of tr1 or tr6 = 0.2096 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAP.

Allowable stresses in joints UG-45(c) and UW-15(c)

N4-2ND ROW-RIGHT

Groove weld in tension = $0.74 \times 16700 = 12358$ psi
Nozzle wall in shear = $0.7 \times 16700 = 11690$ psi
Inner fillet weld in shear = $0.49 \times 16700 = 8183$ psi

Strength of welded joints:

(1) Inner fillet weld in shear

$$(\pi/2) \times \text{Nozzle O.D.} \times \text{Leg} \times S_i = 1.57 \times 8 \times 0.25 \times 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\pi/2) \times \text{Mean nozzle dia.} \times t_n \times S_n = 1.57 \times 7.75 \times 0.25 \times 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\pi/2) \times \text{Nozzle O.D.} \times t_w \times S_g = 1.57 \times 8 \times 0.1875 \times 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 \times t_n) \times (E_1 \times t - F \times t_r)) \times S_v \\ &= (1.634 - (7.796 - 2 \times 0.25) \times (1 \times 0.375 - 1 \times 0.2096)) \times 16700 \\ &= 7134.934 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{1-1} &= (A_2 + A_5 + A_{41} + A_{42}) \times S_v \\ &= (0.289 + 0 + 0.063 + 0) \times 16700 \\ &= 5878.4 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{2-2} &= (A_2 + A_3 + A_{41} + A_{43} + 2 \times t_n \times t \times f_{r1}) \times S_v \\ &= (0.289 + 0 + 0.063 + 0 + 2 \times 0.25 \times 0.375 \times 1) \times 16700 \\ &= 9009.65 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or $W_{1-1} = 5878.4$ lbf
Path 1-1 Thru (1) & (3) = $25694.62 + 35559.52 = 61254.14$ lbf
Path 1-1 is stronger than W_{1-1} so it is acceptable per UG-41(b) (1).

Load for path 2-2 lesser of W or $W_{2-2} = 7134.934$ lbf
Path 2-2 Thru (1), (4) = $25694.62 + 29103.09 = 54797.71$ lbf
Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations for External Pressure

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.796$ in
Normal to the vessel wall outside $2.5 \times (t_n - C_n) + t_e = .625$ in
Normal to the vessel wall inside $2.5 \times (t_n - C_n - C) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta}_1 &= \text{ArcCos}((L_o + R_n)/R_m) \\ &= \text{ArcCos}((23.01 + 3.75)/84.38935) \\ &= 71.51266 \end{aligned}$$

$$\begin{aligned} \text{Theta}_2 &= \text{ArcCos}((L_o - R_n)/R_m) \\ &= \text{ArcCos}((23.01 - 3.75)/84.38935) \end{aligned}$$

N4-2ND ROW-RIGHT

= 76.80766

d = 2*Rm*Sin((Theta2 - Theta1)/2)
= 2*84.38935*Sin((76.80766 - 71.51266)/2)
= 7.796 in

Nozzle required thickness

L/Do = 3.057/8 = .3821
From table G:
From table HA-3:

Do/t = 8/0.01961 = 407.9551
A = 0.000441
B = 4866.1

Pa = 4*B/(3*Do/t)
= 4*4866.1/(3*8/0.01961)
= 15.904 psi

Nozzle required thickness trn = .01961 in

Required thickness tr from UG-37(d) (1) = .2787 in

Area required

Allowable stresses: Sn = 14700, Sv = 14700, psi

fr1 = lesser of 1 or Sn/Sv so fr1 =1
fr2 = lesser of 1 or Sn/Sv so fr2 =1

A = 0.5*(d*tr*F + 2*tn*tr*F*(1 - fr1))
= 0.5*(7.796*0.2787*1 + 2*0.25*0.2787*1*(1 - 1))
= 1.0864 in²

Area available

A1 = larger of the following = .751 in²

= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)
= 7.796*(1*0.375-1*0.2787) - 2*0.25*(1*0.375-1*0.2787)*(1-1)
= .751 in²

= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)
= 2*(0.375+0.25)*(1*0.375-1*0.2787) - 2*0.25*(1*0.375-1*0.2787)*(1-1)
= .12 in²

A2 = smaller of the following = 0.288 in²

= 5*(tn - trn)*fr2*t
= 5*(0.25 - 0.01961)*1*0.375
= .432 in²

= 5*(tn - trn)*fr2*tn
= 5*(0.25 - 0.01961)*1*0.25
= .288 in²

N4-2ND ROW-RIGHT

$$\begin{aligned} A41 &= \text{Leg}^2 * \text{fr2} \\ &= 0.25^2 * 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.751 + 0.288 + 0.063 \\ &= 1.102 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.82647 at 400 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= 0.5 * (d * \text{tr} * F + 2 * \text{tn} * \text{tr} * F * (1 - \text{fr1})) \\ &= 0.5 * (7.5 * 0.2787 * 1 + 2 * 0.25 * 0.2787 * 1 * (1 - 1)) \\ &= 1.045125 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = .722 \text{ in}^2$$

$$\begin{aligned} &= d * (E1 * t - F * \text{tr}) - 2 * \text{tn} * (E1 * t - F * \text{tr}) * (1 - \text{fr1}) \\ &= 7.5 * (1 * 0.375 - 1 * 0.2787) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2787) * (1 - 1) \\ &= .722 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 * (t + \text{tn}) * (E1 * t - F * \text{tr}) - 2 * \text{tn} * (E1 * t - F * \text{tr}) * (1 - \text{fr1}) \\ &= 2 * (0.375 + 0.25) * (1 * 0.375 - 1 * 0.2787) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2787) * (1 - 1) \\ &= .12 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.722 + 0.288 + 0.063 \\ &= 1.073 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.82647 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.01961 in (E = 1)
Wall thickness per UG-45(b) (2):	tr2 = 0.0454 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b) (4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for Pe.

PROCESS SYSTEMS INTERNATIONAL, INC.
WESTBOROUGH, MA

ENGINEERING
CALCULATIONS

NO: V049-1-048

PAGE 1 OF 14

REV.	DEO #	DATE	BY:	CHECK
0	0024	3-27-96	GARENA	RDC

TITLE:
DESIGN OF HAM NOZZLE
JACKING BOLT ASSEMBLIES

By: GARENA DEPT.: 744

PROJECT: LIGO VACUUM EQUIPMENT

PROJECT NO: V59049

PURPOSE: SEE BODY OF CALCULATION

METHOD:

ASSUMPTIONS:

INPUTS:

REFERENCES:

CALCULATIONS: (SEE ATTACHED)

CONCLUSIONS:

NOTES:

1.0 OBJECTIVE

The objective of this calculation is to perform the structural design and analysis for the Jacking Bolt Assemblies on the Horizontal Access Module Chamber (HAM) bellows nozzle.

2.0 METHOD OF ANALYSIS / COMPUTER PROGRAMS & VERSION

No computer programs are used in the execution of this calculation:

Jacking Bolts are placed in locations that will permit operation without interferences with other components. The overall design must not permit any of the components to extend over the flange face because of restrictions in the removal of the adjacent adapter.

The Jacking Bolt Assembly components are designed to AISC allowable stresses and by manual design methods for the greater of two conditions:

- Installation and equipment servicing during which time bellows spring forces act but no pressure loads exist.
- HAM Vessel free standing full vacuum pressure test with bellows pressure loads acting on the jacking assemblies.

Welds are sized by traditional manual calculations found in standard engineering texts.

3.0 GENERAL ASSUMPTIONS

————— None requiring confirmation —————

4.0 REFERENCES

1. ASME Boiler and Pressure Vessel Code, Section VIII, Division I, 1995 Edition
2. Roark & Young, Formulas for Stress and Strain, Fifth Edition
3. Blodgett, Design of Welded Structures
4. LIGO Vacuum Equipment Structural Design Criteria, Doc. No. V049-1-066
5. AISC Steel Construction Manual


6.0 CONCLUSIONS

The Jacking Bolt orientation around the HAM nozzle and the assembly component details are found in the body of this calculation.

The location of the "D" nozzle (electrical/instr. feedthroughs, utility) located on the vertical centerline of the HAM vessel may require relocation due to possible interference with the jacking bolts and/or its close proximity to the "B" nozzle juncture (approx. 1")

JACKING BOLT ORIENTATION

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



DESIGN LOADS

MAXIMUM WORKING SPRING RATE FOR 2" TRAVEL

6218 #/IN (HYSPAN BELLOWS)

USE 7500 #/IN FOR DESIGN

WORST CONDITION FOR 3 BOLTS LOADED

(4TH BOLT ASSUMED INEFFECTIVE)

$$2F_1 + F_2 = 15000$$

$$2F_1 \times 7 + 4F_2 = 0$$


$$F_2 = \frac{14}{41} F_1 = .341 F_1$$

$$2F_1 + .341 F_1 = 15000$$

$$F_1 = \underline{6406 \#}$$

$$F_2 = 2188 \#$$

USE 6400 # / ROD FOR DESIGN LOAD



DESIGN LOADS (VACUUM TEST)

$$F = \frac{\pi D_m^2}{4} \times 15 \text{ PSIA}$$

$$= \frac{\pi}{4} (2.5)^2 \times 15 = 46020 \#$$

$$\sum F_x + \sum F_z = 23010$$

$$\sum M_x = 0$$

$$2F_1 R \sin 42 - 2F_2 R \cos 24 = 0$$

$$F_1 \sin 42 = F_2 \cos 24$$

$$F_2 = F_1 \frac{\sin 42}{\cos 24}$$

$$\Rightarrow F_1 + F_1 \frac{\sin 42}{\cos 24} = 23010$$

$$F_1 = \frac{23010}{(1 + \frac{\sin 42}{\cos 24})} = 13282 \#$$

$$F_2 = 9728 \#$$

$$\sum M_y$$

$$F_1 \cos 42 - F_2 \sin 24 = 0$$

$$F_1 + F_1 \frac{\cos 42}{\sin 24} = 23010 \Rightarrow F_1 = \frac{23010}{(1 + \frac{\cos 42}{\sin 24})} = 8139 \#$$


$$F_2 = 14871 \#$$

$$F_{1 \text{ AVE}} = \frac{13282 + 8139}{2} = 10710 \#$$

$$F_{2 \text{ AVE}} = \frac{14871 + 9728}{2} = 12300 \#$$

$$\sum F_z \Rightarrow 2(10710) + 2(12300) = 46020$$

$$46020 = 46020 \quad \text{OK}$$




DESIGN LOAD = 12,300 # / ROD

VACUUM TEST LOAD GOVERNS

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



COMPONENT DESIGN



ROD (IN COMPRESSION) 1" ϕ x 8 THD/IN

ONE END FIXED OTHER END PINNED $K=8$ USE $K=1.0$

MAT'L A320-B8 (304^{5/8}) $F_y = 80$ KSI

ROOT DIA OF THDS = 0.833" $r = \frac{.833}{4} = .21$

$L_{EFFECTIVE} = 7 \frac{3}{16} + \frac{3}{4} - 1" = 7 \frac{3}{16}"$

$$F_c @ \frac{KL}{r} \Rightarrow \frac{1 \times 6.9375}{.21} = 33.04 \Rightarrow 35$$

FROM AISC @ $F_y = 90$ $F_c = 44.67$ KSI

$$F_c = 44.67 \times \frac{80}{90} = 39.71 \text{ KSI MAX}$$

$$f_c = \frac{P}{A} = \frac{12.3}{\frac{\pi(.833)^2}{4}} = 22.3 \text{ KSI} < 39.71 \text{ KSI} \quad \text{OK}$$

PIN (DOUBLE SHEAR) A320 B8 $F_y = 100$ KSI

$F_s = .4 F_y = 40$ KSI

$$A_{REQ'D} = \frac{P}{2 F_s} = \frac{12300}{80,000} = .15 \text{ IN}^2 \Rightarrow D_{REQ'D} = .44"$$

USE 1/2" ϕ PIN

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



FLANGE LUG

A 240-TP304 5/8"


$F_y = 30 \text{ KSI}$

SHEAR OUT AT PIN HOLE

$$f_s = \frac{P}{A_{TOTAL}} = \frac{12300}{2 \times 1.25 \times t}$$

$$F_s = .4 F_y = 12 \text{ KSI}$$

$$t = \frac{12300}{2.5 \times 12000} = .41"$$



BEARING AT PIN HOLE

$$F_B = 1.35 F_y = 40500 \text{ PSI}$$



$$f_B = \frac{P}{A_{PROJ}} = \frac{12300}{(.5 \times .5)} = 49200 > 40500 \quad \text{NG}$$

$$\text{@ } 5/8 \text{ R} \quad f_B = \frac{12300}{.625 \times .5} = 39360 < 40500 \quad \text{OK}$$


USE $t = 5/8"$

CLEVIS DETAIL

A 240 TP 304 STN STL



PIN DETAIL




22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



filename: FULLCIR.WR1
FULL CIRCULAR/TRUNNION FILLET WELD

Between part ROD and part CLEVIS



LOAD INPUT (LBS., INCH-LBS.)

F1	F2	F3	M1	M2	M3
0.00	12300.00	0.00	0.00	0.00	0.00

GEOMETRIC DIMENSIONS (FOR FLAT PLATES, INPUT D=100*d)

dw	Dp
0.838	1000.000

SECTION PROPERTIES

A	Sw	Jw	WELD STRESS (PSI)
2.633	0.552	1.103	18000

EFFECTIVE THROAT CORRECTION FACTOR
Mf
1.00

MAXIMUM WELD LOAD (f) - #/INCH
4672


REQUIRED FILLET WELD SIZE (INCHES)
w
0.367

USE 3/8 FILLET WELD

filename: FULLRECT.WR1

ALL AROUND RECTANGULAR OR SQUARE FILLET WELD

Between part FLANGE LUG and part FLANGE



LOAD INPUT (LBS., INCH-LBS.)

F1	F2	F3	M1	M2	M3
0.00	12300.00	0.00	18451.00	0.00	0.00

GEOMETRIC DIMENSIONS

a	b	WELD STRESS (PSI)	SKEWED ANGLE(90°>β<120°)
3.000	0.625	18000	90.000

SECTION PROPERTIES

A	Sw1	Sw3	J	C1	C3
7.250	4.875	2.005	7.939	1.500	0.313

EFFECTIVE THROAT CORRECTION FACTOR

Mf
1.00

MAXIMUM WELD LOAD (f) - #/INCH

f
5481

REQUIRED FILLET WELD SIZE (INCHES)

w
0.431


USE $\frac{7}{16}$ FILLET WELD

filename: CHNL_VWLD.WR1

CHANNEL-SHAPED FILLET WELDS

NOTE: FOR ALL AROUND WELD USE (f)/2 TO SIZE WELD LEG

Between part HAM NOZZLE and part NOZZLE BRACKET



LOAD INPUT (LBS., INCH-LBS.)

F1	F2	F3	M1	M2	M3
12300.00	0.00	0.00	0.00	0.00	41513.00

GEOMETRIC DIMENSIONS

a	b	WELD STRESS	SKEWED ANGLE(90°>θ<135°)
6.000	4.000	18000	90.000

SECTION PROPERTIES

A	Sw1	I3	J	C1	C3
14.000	30.000	24.381	114.381	3.000	1.143

Cp
2.857

EFFECTIVE THROAT CORRECTION FACTOR

Mf
1.00

MAXIMUM WELD LOAD (f) - #/INCH

f
4944

REQUIRED FILLET WELD SIZE (INCHES)

w
0.388

$$\frac{w}{2} = .20$$

USE 1/4" FILLET ALL AROUND
OR

1/16 FILLET OUTSIDE EDGES
(3 SIDES)

NOZZLE SHELL STRESS DURING FULL VACUUM TEST
 bracket WRC bulletin 107 design

ASME Code Addenda used - A90

Internal design pressure P = -15 psi
 Design temperature is = 70 deg F
 Corrosion allowance C = 0 in.
 Shell inner diameter, new Di = 60.5 in.
 Shell thickness, new t = .5 in.
 Mat'l is exempt from impact testing per UHA-51(a)
 Allowable tensile stress S = 18800 psi for SA 240 304 HIGH A88^
 Lug length, circ direction 2C1 = 6 in.
 Lug length, long direction 2C2 = 4 in.
 Lug interface radius = .5 in.

Applied Loads

Radial load Pr = 0 lbf
 Circumferential moment Mc = 0 lb-in
 Longitudinal moment ML = 41513 lb-in
 Circumferential shear Vc = 0 lbf
 Longitudinal shear VL = 12300 lbf

Stresses at the lug interface per WRC bulletin 107

Geometric factor gamma = 61
 Stress concentration factor Kn (tension) = 1
 Stress concentration factor Kb (bending) = 1
 Beta1 = 9.836066E-02, Beta2 = 9.836066E-02

From Fig.	Value read	beta	Circumferential (hoop) stress psi							
			Au	Al	Bu	Bl	Cu	Cl	Du	Dl
pressure stress*			-908	-908	-908	-908	-908	-908	-908	-908
4C*	10.216	.098	0	0	0	0			0	0
3C*	8.586	.098					0	0	0	0
2C-1	.075	.098	0	0	0	0				
1C	.109	.098					0	0	0	0
3A*	2.148	.098					0	0	0	0
1A	.09	.109					0	0	0	0
3B*	6.858	.098	-5559	-5559	5559	5559				
1B	.042	.098	-14000	14000	14000	-14000				
Total hoop stress			-20467	7533	18651	-9349	-908	-908	-908	-908
Primary membrane circ. stress*			-6467	-6467	4651	4651	-908	-908	-908	-908

Maximum primary membrane circ. stress = -6467 psi
 Allowable primary membrane circ. stress = $\pm 1.5 * S = \pm 28200$ psi

COMPRESS 4.20

ham

Mar. 27, 1996

The maximum primary membrane circ. stress is within allowable limits

From Fig.	Value read	beta	Longitudinal (axial) stress psi							
			Au	Al	Bu	Bl	Cu	Cl	Du	Dl
pressure stress*			-454	-454	-454	-454	-454	-454	-454	-454
4C*	10.216	.098					0	0	0	0
3C*	8.586	.098	0	0	0	0				
1C-1	.111	.098	0	0	0	0				
2C	.074	.098					0	0	0	0
4A*	3.234	.098					0	0	0	0
2A	.047	.111					0	0	0	0
4B*	2.074	.098	-1797	-1797	1797	1797				
2B	.062	.105	-19288	19288	19288	-19288				
Total Axial stress			-21539	17037	20631	-17945	-454	-454	-454	-454
Primary membrane long. stress*			-2251	-2251	1343	1343	-454	-454	-454	-454

Maximum primary membrane long. stress = -2251 psi
Allowable primary membrane long. stress = $\pm 1.5 \cdot S = \pm 28200$ psi

The maximum primary membrane long. stress is within allowable limits

Loading	Shear stress psi							
	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
torsion moment Mt	0	0	0	0	0	0	0	0
Circ. load Vc	0	0	0	0				
Long. load Vc					-2050	-2050	2050	2050
Total Shear stress	0	0	0	0	-2050	-2050	2050	2050

COMPRESS 4.20

ham

Mar. 27, 1996

At point -->	Combined stress intensity, psi							
	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Combined stress	-21539	17037	20631	-17945	4125	4125	4125	4125

Maximum combined stress = -21539 psi

Allowable combined stress = $\pm 3 \cdot S = \pm 56400$ psi

The maximum combined stress is within allowable limits.

Hyspan Precision Products, Inc.
1685 Brandywine Avenue
Chula Vista, California 91911, U.S.A.

Telephone (619) 421-1355
Telecopier (619) 421-1702

TELECOPIER TRANSMITTAL

To: PROCESS SYSTEMS INTERNATIONAL
WESTBOROUGH, MASS.

Telecopier No: (508)-898-0322

Date: 2/9/96

Total number of pages including this page 3

ATTN: GUY ARENA

QD-9317

Reference: HORIZONTAL ACCESS MODULE CHAMBER (HAM)
NOZZLE BELLOW DESIGN

Guy,

THE FOLLOWING ARE PRELIMINARY BELLOW

DESIGN CALCULATIONS FOR BOTH THE OPERATING

& MAINTENANCE MODES DESCRIBED IN YOUR

1/24/96 FAX. NOTE THE AXIAL SPRING

RATE OF 6,218 lbs./in. EQUATES TO AN APPROX.

65.5 lbs PER INCH LOAD ON THE CIRCUMFERENCE OF

THE FLANGE I.D. PLEASE LET US KNOW IF

YOU HAVE ANY QUESTION &/OR WE CAN BE

OF FURTHER HELP. HYSPAN LOOKS FORWARD TO

RECEIVING YOUR FORMAL REQUEST FOR THIS

PROJECT.

REGARDS,

From: MARTY KOESTER