

High Fidelity Probe of Optical Scatter from Point Defects

K. Kruthi¹, Mentors: G. Venugopalan², K. Arai² and R. Adhikari²

LIGO-T1900281-v1 ¹Indian Institute of Science, ²LIGO Laboratory, California Institute of Technology

Abstract

This poster describes the efforts to study the scattered light in the LIGO 40m prototype with the help of a digital CCD camera installed into the camera system that currently monitors the beam spot on the mirrors/test masses.

Backscattered Light

Current sensitivity: 10^{-23} $1/\sqrt{Hz}$ around 100 Hz Current range of LIGO: 10 Hz to 1000 Hz



Ordinary MC2 image

High Dynamic Range Images



Scattering is a critical noise source below 30 Hz.



- Backscattered light modulates the phase and amplitude of main beam and introduces a random phase noise.
- □ Loss from scattered light reduces optical squeezing and will limit the sensitivity in the future upgrades.

In-situ Measurement of Scattered Light



Mirrors/test masses are inside the vacuum chamber \Rightarrow limited access!

- Dynamic range is the ratio of intensity corresponding to the brightest region of the image and to the darkest.
- HDR image resolves the **contrast** and **image details** much better than an ordinary image which might be limited by **pixel saturation**.



Scatter Loss Map

Interpolated scatter loss map of MC2

Image of MC2 chamber and the camera system

- Using a digital CCD camera (GigE camera) we can capture images with different exposure times.
- A **two lens telescope** system is used to focus the beam spot onto the GigE camera sensor while ensuring optimum utilization of the CCD pixel array.
- By performing a **radiometric calibration** of the GigE camera, we can measure the power of scattered light from the captured images.





- □ High amount of scattering indicates large number of **point defects** in that region
- □ Identifying the regions on the mirror with maximum number of point defects and centering the beam spot on a region with few points defects \Rightarrow **Reduced scattering**

Note: The measured power of scattered light corresponds to the light scattered at a particular angle, not the total light scattered, as our setup only collects scattered light at a fixed angle as seen in schematic.

Future work

Schematic of MC2 camera setup

Uses of the Image

- Images of the mirror captured using the above setup can be used to:
- Analyze the size and spatial distribution of point scatterers.
- Estimate the **fraction of scattering** is due to point scatterers.
- Understand the effectiveness of cleaning methods of optics.
- Study how **different coatings of the mirror** affect scattering.

With the infrastructure that has been set up, we further aim to study the sources of scattering - point defects and other surface imperfections, estimate the optical loss due to scattering and characterize the random phase noise introduced due to scattered light. And thereby, gain an overall understanding of the effects of scattered light in the LIGO interferometer.

Acknowledgements

This work was undertaken as a part of LIGO-SURF program. I thank all my mentors for their support and guidance. Special thanks to Caltech, SFP, LIGO Scientific Collaboration (LSC) and IndIGO.

References:

Jigyasa Nigam, *Characterization of Test Mass Scattering*. LIGO-T1700283–v1. F Magana-Sandoval et al, Technical Note LIGO- T1400252-LSC. (2014)